

TECHNICAL SCHEDULES**TO BE FILLED BY BIDDER****Refer ITB 11.1 (b)**

PURCHASER/OWNER/ EMPLOYER/CLIENT	: MINISTRY OF MICRO, SMALL AND MEDIUM ENTERPRISES, BENGALURU
PROJECT	: TECHNOLOGY CENTRE, BENGALURU
LOCATION	: BENGALURU, KARNATAKA INDIA
CONSULTANT/CMC/ PROJECT MANAGER	: TATA CONSULTING ENGINEERS LIMITED

TABLE OF CONTENTS

1. DATA SHEET FOR PLUMBING	8
1.1. BUTTERFLY VALVES.....	8
1.2. Y STRAINER	10
1.3. WAFER CHECK VALVES	12
1.4. BALL VALVES	13
1.5. SOLENOID VALVE	14
1.6. TRANSFER PUMPS	16
1.7. FLOAT SWITCH	18
1.8. ELECTRICAL TECHNICAL DATA SHEETS.....	21
1.9. CONSTRUCTIONAL FEATURES FOR MCC	23
1.10. PIPES25	
2. DATA SHEET FOR FIRE PROTECTION SYSTEM.....	27
2.1. DATA SHEETS FOR INSTRUMENTS EQUIPMENT.....	27
2.1.1. Pressure Gauges	27
2.1.2. Pressure Switch.....	27
2.1.3. Solenoid Valve.....	28
2.1.4. Level Gauge / Indicator – Float & Cord	28
2.1.5. Float Switch	29
2.1.6. JUNCTION BOXES	31
2.2. DATA SHEETS FOR HORIZONTAL CENTRIFUGAL PUMPS	32
2.2.1. DATA SHEETS B	32
2.2.2. DATA SHEET C	34
2.3. DATA SHEETS FOR DIESEL ENGINE AND ACCESSORIES	35
2.3.1. DATA SHEETS B	35
2.3.2. DATA SHEET C	43
2.4. DATA SHEET FOR HYDRANT VALVE	44
2.4.1. DATA SHEETS B	44
2.4.2. DATA SHEETS C	44
2.5. DATA SHEET FOR BRANCH PIPES AND NOZZLES.....	45
2.5.1. DATA SHEETS B	45
2.5.2. DATA SHEETS C	46
2.6. DATA SHEET FOR FIRE HOSES WITH COUPLING	46
2.6.1. DATA SHEETS B	46
2.6.2. DATA SHEETS C	46
2.7. DATA SHEET FOR FIRE HOSES CABINETS	48
2.7.1. DATA SHEETS B	48
2.7.2. DATA SHEETS C	48
2.8. DATA SHEET FOR FIRE HOSES REELS.....	49
2.8.1. DATA SHEETS B	49
2.8.2. DATA SHEETS C	49

2.9. DATA SHEETS FOR PORTABLE FIRE EXTINGUISHERS	50
2.9.1. DATA SHEETS B	50
2.9.2. DATA SHEETS C	51
2.10. VALVES AND SPECIALITIES GENERAL REQUIREMENTS	52
2.10.1. DATA SHEET-B (GATE VALVE)	52
2.10.2. DATA SHEET-B (WAFFER CHECK VALVES)	53
2.10.3. DATA SHEET-B (BALL VALVES)	54
2.10.4. DATA SHEET-B (Y STRAINER)	54
2.10.5. DATA SHEET-B (BUTTERFLY VALVE)	55
2.10.6. DATA SHEET-C	59
2.11. FIRE WATER PIPING GENERAL REQUIREMENTS	59
2.11.1. DATA SHEET B	59
2.12. FIRE UNDERGROUND PROTECTION FOR PIPING	61
2.12.1. (DATA SHEETS A)	61
2.13. FIRE PROTECTION EQUIPMENT WET PIPE TYPE SPRINKLER SYSTEM	62
2.13.1. DATA SHEETS B	62
2.14. LOW VOLTAGE INDUCTION MOTORS	63
2.14.1. DATA SHEET-B	63
2.14.2. Low voltage induction motors data sheet-c	65
3. DATA SHEET FOR HVAC WORKS	69
3.1. SPLIT AIR-CONDITIONERS DATA SHEET for BIDDER	69
3.2. AIR-COOLED VARIABLE REFRIGERANT FLOW SYSTEM DATA SHEET for BIDDER: 72	
3.3. THERMAL INSULATION FOR COLD SURFACES DATA SHEET for BIDDER:	73
3.4. PANEL TYPE AIR FILTERS:	74
3.5. AIR WASHER DATA SHEET for BIDDER:	77
3.6. AXIAL FANS FOR VENTILATION SYSTEM	80
3.7. AIR HANDLING UNIT	82
3.8. 3.8 CONDENSER UNIT	87
4. DATA SHEET FOR COMPRESSED AIR WORKS	91
4.1. DATA SHEET B :AIR COMPRESSOR	91
4.2. DATA SHEET C : AIR COMPRESSOR	97
4.3. DATA SHEET B- AIR DRYING PLANT (REFRIGERATED TYPE)	99
4.4. WELDED UNFIRED PRESSURE VESSEL DATA SHEET C :	104
4.5. MOTOR DATASHEETS B :	104
5. DATA SHEET FOR ELECTRICAL	109
5.1. DATA SHEET A1 HIGH VOLTAGE METAL ENCLOSED SWITCHGEAR	109
5.2. DATA SHEET A2 HIGH VOLTAGE METAL ENCLOSED SWITCHGEAR	117
5.3. DATA SHEET A1 LOW VOLTAGE SWITCHGEAR	118
5.4. DATA SHEET A2 LOW VOLTAGE SWITCHGEAR	125

5.5. DATA SHEET A1 CONTROL PANEL	127
5.6. DATA SHEET A2 CONTROL PANEL	130
5.7. DATA SHEET A1 POWER FACTOR CORRECTION SYSTEM.....	131
5.8. DATA SHEET A2 POWER FACTOR CORRECTION SYSTEM.....	134
5.9. DATA SHEET A1 DISTRIBUTION TRANSFORMER.....	135
5.10. DATA SHEET A2 DISTRIBUTION TRANSFORMER.....	140
5.11. DATA SHEET A1 BUS DUCT	141
5.12. DATA SHEET A2 DISTRIBUTION TRANSFORMER.....	146
5.13. DATA SHEET A1 XLPE INSULATED H.V. POWER CABLES.....	147
5.14. DATA SHEET A1 1100V XLPE POWER CABLES.....	149
5.15. 1100V PVC INSULATED CONTROL CABLES	151
5.16. DATA SHEET A2 CABLING ACCESSORIES, CABLE TRAYS AND CONDUITS	
/ PIPES 152	
5.17. DATASHEET-A1 UPS SYSTEM.....	153
5.18. DATASHEET-A2 UPS SYSTEM.....	158
5.19. DATASHEET-A1 LEAD ACID BATTERY	161
5.20. DATASHEET-A2 LEAD ACID BATTERY	166
5.21. DATASHEET-A1 LIGHTING.....	167
5.22. DATASHEET-A1 LED LUMINAIRES	169
5.23. DATASHEET-B HIGH VOLTAGE METAL ENCLOSED SWITCHGEAR	174
5.24. DATASHEET-B LT SWITCHGEAR	185
5.25. DATASHEET-B HT TERMINATIONS.....	193
5.26. DATASHEET-B POWER TRANSFORMER	195
5.27. DATASHEET-B BUS DUCT	208
5.28. DATASHEET-B CONTROL PANEL	211
5.29. DATASHEET-B CABLE SYSTEM INSTALLATION WORKS	213
5.30. DATASHEET-B LIGHTING INSTALLATION WORKS	213
5.31. DATASHEET-B LEAD ACID BATTERIES	216
5.32. DATASHEET-B SHUNT CAPACITORS	220
5.33. DATASHEET-B LED	224

6. DATA SHEET FOR INTEGRATED BUILDING MANAGEMENT SYSTEM.. 230

6.1. Direct Digital Control (DDC) Specification	230
6.2. FIRE DETECTION AND ALARM SYSTEM.....	233
6.2.1. Fire Alarm Control Panel Specification.....	233
6.2.2. Fire Alarm Repeater Panel Specification.....	238
6.2.3. Fire Alarm Control Relay Module Specification.....	241
6.2.4. Fire Alarm Heat Detector Specification	243
6.2.5. Fire Alarm Multi-Sensor Detector Specification	246
6.2.6. Fire Alarm Beam Type Smoke Detector Specification	248
6.2.7. Fire Alarm Smoke Detector Specification.....	251
6.2.8. Fire Alarm Monitor Module Specification	253
6.2.9. Manual Call Point (MCP) Specification	255
6.2.10. SOUNDER cum STROBE Specification	257
6.2.11. Fire Alarm Fault Isolator Module Specification.....	259

6.3. PUBLIC ADDRESS SYSTEM	261
6.3.1. Microphone Specification	261
6.3.2. Loudspeaker Specification.....	262
6.3.3. Desktop Call Station	263
6.4. CLOSED CIRCUIT TELEVISION SYSTEMS.....	266
6.4.1. CCTV Camera Specification	266
6.4.2. CCTV MONITOR SPECIFICATION.....	268
6.4.3. DVR (Digital Video Recorder) SPECIFICATION	269
7. DATA SHEET FOR EXTERNAL SERVICES	272
7.1. DATA SHEET FOR HORIZONTAL CENTRIFUGAL PUMP	272
7.1.1. DATA SHEETS B	272
7.1.2. DATA SHEETS C	275
7.2. DATA SHEET FOR DOSING PUMP	275
7.2.1. DATA SHEETS B	275
7.2.2. DATA SHEETS C	276
7.3. DATA SHEET FOR SUBMERSIBLE PUMP (Raw Sewage from Equalisation Tank)	277
7.3.1. DATA SHEETS B	277
7.3.2. DATA SHEETS C	279
7.4. DATA SHEET FOR AIR BLOWER	279
7.4.1. DATA SHEETS B	279
7.4.2. DATA SHEETS C	282

TECHNICAL SPECIFICATIONS – BIDDER TO FILL

FOR

PLUMBING SYSTEM

1. DATA SHEET FOR PLUMBING

1.1. BUTTERFLY VALVES

SL. NO.	DATA SHEET A BUTTERFLY VALVES ITEM	UNIT	TO BE FILLED BY BIDDER		
1.0	GENERAL				
1.1.	SERVICE				
1.2.	TAG NOs.				
1.3.	NO. OF VALVES	No.			
1.4.	DESIGN STANDARD				
1.5.	VALVE CATEGORY				
1.6.	DISC				
1.7.	BODY TYPE				
1.8.	VALVE SIZE	NB			
1.9.	VALVE RATING / CLASS				
1.10.	FLUID HANDLED WITH ITS SPEC. GRAVITY				
1.11.	COMPANION FLANGE TYPE AND CLASS				
1.12.	TYPE OF VALVE OPERATOR				
1.13.	MAXIMUM FLOW (INDICATE THE RELATED PRESSURE ALSO)	M ³ /hr, KPa	MAX.	MIN.	OPER
1.14.	MAXIMUM FLOW VELOCITY	m/s			
1.15.	DESIGN PRESSURE	KPa			
1.16.	OPERATING PRESSURE	KPa			
1.17.	DESIGN TEMPERATURE	°C			
1.18.	OPERATING TEMPERATURE	°C			
1.19.	VALVE LOCATION				
4.0	MATERIALS OF CONSTRUCTION				
4.1	BODY				
3.2.	DISC				
3.3.	STEM				

SL. NO.	DATA SHEET A BUTTERFLY VALVES ITEM	UNIT	TO BE FILLED BY BIDDER
3.4.	SEAT		
3.5.	BODY SEAT RINGS		
3.6.	DISC SEAL RINGS		
3.7.	SEAT RETAINING RINGS		
3.8.	COMPANION FLANGE		
5.0	TESTS AND INSPECTION		
4.1.	HYDROSTATIC TEST PRESSURE FOR BODY	Kg/cm ²	
4.2.	HYDROSTATIC TEST PRESSURE FOR DISC	Kg/cm ²	
4.3.	DISC STRENGTH TEST PRESSURE	Kg/cm ²	
4.4.	ACTUATOR PERFORMANCE TEST PRESSURE	Kg/cm ²	
4.5.	AIR LEAK TEST PRESSURE	Kg/cm ²	
4.6.	ELECTRICAL CONTINUITY TEST		
4.7.	SPARES		
6.0	DISC SEAL RINGS		
5.1.	FLANGE GASKET		
5.2.	SEAT/SEAL CLAMPING BOLTS		
5.3.	'O' RING SEALS OR GLAND PACKING		
5.4.	(REF. NOTE -10)		

NOTES :-

- 0 FOR GENERAL REQUIREMENTS. HOWEVER, IN CASE OF OVERLAPPING REQUIREMENTS, THOSE OF THE
0 DATA SHEET A, TO BE CONSIDERED AS THE FINAL ONE.
- 0 THE VALVE SHALL BE DESIGNED CONSIDERING THE LARGER OF THE FOLLOWING TORQUE REQUIREMENTS
0 FOR WHICH CALCULATIONS SHALL BE SUBMITTED:
- a) CALCULATED AS PER AWWA-C504-80
- b) CALCULATED AS PER THE STANDARD TO WHICH VALVE IS DESIGNED.
- 0 FOR MANUALLY OPERATED VALVES, TORQUE REQUIRED AT HAND WHEEL SHALL NOT EXCEED 7 KG.M.
- 0 MOTOR OPERATED VALVE ACTUATOR SHALL BE RATED TO PROVIDE AN OUTPUT TORQUE OF ATLEAST
0 150% OF TORQUE REQUIRED AS PER NOTE-2 ABOVE UNLESS OTHERWISE NOTED.
- 0 THE ACTUATOR SHALL BE CAPABLE OF OPERATING IN ANY MOUNTING ANGLE.
- 0 THE TRANSMISSION UNIT SHALL BE DESIGNED TO TRANSMIT TWICE THE VALVE DESIGN TORQUE UNLESS
0 OTHERWISE NOTED.
- 0 THE ACTUATOR SHALL PROVIDE AN UNSEATING TORQUE OF AT LEAST 50% IN EXCESS OF VALVE SEATING
0 TORQUE AT THE SPECIFIED VOLTAGE UNLESS OTHERWISE NOTED.
- 0 SEGMENTAL WELDED CARBON STEEL FLANGE PLATES ABOVE 20 MM THICKNESS SHALL BE SUBJECTED TO
0 PREHEATING BEFORE WELDING AND STRESS RELIEVING AFTER WELDING AS PER IS 2825 UNLESS OTHERWISE
0 SPECIFIED.
- 0 UNLESS OTHERWISE SPECIFIED IN SECTION -C, ONE COAT OF ZINC RICH PRIMER AND TWO COATS OF
0 ENAMEL SHALL BE APPLIED TO ALL STEEL AND CAST IRON EXPOSED SURFACES. THE MINIMUM THICKNESS
0 OF COATING SHALL BE 100 MICRONS.
- 0 THE VENDOR MAY ALSO SUGGEST ANY ADDITIONAL SPARES AND TOOLS REQUIRED FOR THE SUCCESSFUL
0 OPERATION, START UP AND MAINTAINENCE OF THE VALVE.

0 IN THE ABSENCE OF ANY TEST RELATED DATA, THE RELEVANT TESTING STANDARD FOR BUTTERFLY VALVES MAY BE INDICATED.

1.2. Y STRAINER

		DATA SHEET A STRAINERS (Y TYPE)	TO BE FILLED BY BIDDER
DESIGN DATA	1.	TAG NO.	
	2.	QUANTITY REQUIRED	
	3.	LOCATION	
	4.	TYPE	
	5.	FLUID	
	6.	FLOW RATE m ³ /hr	
	7.	OPERATING PRESSURE bar	
	8.	OPERATING TEMPERATURE ° C	
	9.	DESIGN PRESSURE barg	
	10.	DESIGN TEMPERATURE ° C	
	11.	FLUID VISCOSITY (Cp) AT OP.TEMP.	
	12.	FLUID SP. GRAVITY AT OP. TEMP.	
	13.	MAX. PERMISSIBLE PR. DROP UNDER 50% CLOGGED CONDITION	
	14.	SCREEN BASKET DATA	
		1. DIA OF PERFORATIONS, mm	
		2. MIN. THICKNESS, mm	
		3. FREE STRAINING AREA	
	15.	STEAM JACKET	
		1. INLET PR. barg, OP. / DESN.	
		2. INLET TEMP. ° C, OP./DESN.	
	16.	END CONNECTIONS	
	1. SIZE, NB mm		
	2. TYPE		
	3. DETAILS/ STANDARDS		
17.	COVER		
18.	IBR APPROVAL		

MATERIALS	19. BODY	
	20. COVER	
	21. SCREEN BASKET	
	22. BOLTS/ STUDS	
	23. NUTS	
	24. GASKETS	
	25. JACKET	
	26. JACKET COUPLINGS/ FLANGES	
27. ACCESSORIES BY VENDOR:		
27.1 FOUNDATION BOLTS		
27.2 DIFFERENTIAL PRESSURE GAUGE		
27.3 DRAIN/ VENT COCK (SS 316)		
27.4 SUPPORT LEGS		
26. HYDROSTATIC TEST PRESSURE, barg		
26.1 SHELL SIDE		
26.2 JACKET SIDE		
27. VACUUM TEST REQUIRED		
28. PRESSURE DROP TEST REQUIRED		
CLEAN/ 50% CLOGGED		
29. INSPECTION:		
30.		
<u>NOTES:</u> 1. GENERAL REQUIREMENTS: 2. '*': BIDDER TO FURNISH INFORMATION. 3 GASKET SHALL BE METAL WIRE-REINFORCED AND GRAPHITED BOTH SIDES.		

1.3. WAFER CHECK VALVES

TO BE FILLED BY BIDDER		DATA SHEET A WAFER CHECK VALVES			SHEET : 1 OF 1			
GENERAL	1. TAG NO. :	4. FLUID :	SIZ mm	QUANTITY				
	2. SIZE RANGE :	5. DES. PR. :						
	3. RATING :	6. DES. TEMP. :		P0	R0	R1	R2	
	7. STANDARD :	GRADE: CT						
CONSTRUCTION FEATURES	8. TYPE :							
	9. ENDS :							
	10.							
	11.							
	12.							
	13.							
	14. OTHER REQUIREMENTS :							
MATERIALS	15. BODY :							
	16. PLATE :							
	17. SEAL :							
	18. PLATE SEAT :							
	19. SPRING :							
	20. HINGE PIN & STOP PIN :							
	21.							
TESTS & INSPECTION	24. SHELL HYDRO :							
	25. SEAT HYDRO :							
	26. INSPECTION :							
<u>NOTES:</u> 1. GENERAL REQUIREMENTS :.								

1.4. BALL VALVES

TO BE FILLED BY BIDDER		DATA SHEET A BALL VALVES		SHEET : 1 OF 1				
GENERAL	1. TAG NO. :	SIZE mm	QUANTITY					
	2. SIZE RANGE :							
	3. RATING :							
	4. GRADE :		P0	R0	R1	R2		
CONSTRUCTION FEATURES	5. PORT :	REFER SECTION F						
	6. STEM :							
	7. ENDS :							
	8. OPERATION :							
	9. ANTISTATIC FEATURE :							
	10. FIRE SAFE DESIGN :							
	11. OTHER REQUIREMENTS :							
	SIZE, (in/ mm) : INS. THK., mm :							
MATERIALS	12. BODY							
	13. BALL (MIRROR FINISHED)							
	14. STEM							
	15. SEAT							
	16. SEAL (STEM & BODY)							
	17. BOLTS, STUDS & NUTS							
	18.							
TESTS & INSPECTION	19. SHELL HYDRO :							
	20. SEAT HYDRO :							
	21. SEAT AIR :							
	22. INSPECTION :							

1.	1.5. SOLENOID VALVE	33.	Cable Entry Size : 1" ET <input type="checkbox"/> <input type="checkbox"/>
	DATA SHEET A	34.	PAINTING
	SOLENOID VALVE	35.	Protection For Rust Prevention
	GENERAL	36.	Painting Standard : As Per IS-6005, 1970
2.	Manufacturer	37.	ACCESSORIES
3.	Model No.	38.	Name Plate : Required
4.	Service	39.	Metalling enclosure for connecting flying leads: Required
5.	PROCESS DATA	40.	CODES AND STANDARDS
6.	Fluid	41.	ASME, ASTM, IEEE, IBR
7.	Pipe size	42.	Weather Proof : IS 13947 PART I
8.	Operating Pressure : kg/sQcm	43.	Ex. Proof : IS 2148 / BS EN 50014 / BS EN 50020
9.	Operating Temperature : °C	44.	TEST
10.	Operating Flow	45.	Performance; Required
11.		46.	Hydro Test : Required
12.	FEATURES	47.	Seat Leakage Test : Required
13.	Shut Off Class (Leakage)	48.	CV Test : Certificate to be furnished
14.	Type : Pilot <input type="checkbox"/> Direct <input type="checkbox"/>	49.	Coil Insulation Test : Required
15.	Body Rating : ANSI Class 300 <input type="checkbox"/> <input type="checkbox"/>	50.	Test Certificate From PESO : Required for all exproof solenoid valves
16.	Duty : Continuous <input type="checkbox"/> Intermittent <input type="checkbox"/>	51.	
17.	No. of Ports / No. of Ways : 3/2 <input type="checkbox"/> 5/2 <input type="checkbox"/>	52.	
18.	Power Supply : 230 V AC <input type="checkbox"/> 110 VAC <input type="checkbox"/> 24 VDC <input type="checkbox"/> <input type="checkbox"/>	53.	
19.	Style Of Coil : Moulded	54.	
20.	Coil Insulation : Class F for high temp. as per IEC 60085/IS 1271	55.	
21.	MATERIAL OF CONSTRUCTION	56.	
22.	Body Material : Bronze <input type="checkbox"/> SS 316 <input type="checkbox"/> <input type="checkbox"/>	57.	
23.	Seat Material : SS 316 <input checked="" type="checkbox"/> Teflon <input type="checkbox"/> <input type="checkbox"/>	58.	
24.	Plunger Material : SS316 <input type="checkbox"/> <input type="checkbox"/>	59.	
25.	Packing Material	60.	
26.	ENCLOSURE PROTECTION	61.	
27.	Weather Proof To : IP 67 & 68	62.	
28.	Ex-Proof To: Zone 1 <input type="checkbox"/> ZONE 2 <input type="checkbox"/> Group IIA <input type="checkbox"/> IIB <input type="checkbox"/> IIC <input type="checkbox"/> Temp.Class : T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> T4 <input type="checkbox"/> T5 <input type="checkbox"/> T6 <input type="checkbox"/>	63.	
29.	Intrinsic safe certified	64.	
30.	CONNECTION AND DIMENSIONS	65.	
31.	Process Connection Type : NPT <input type="checkbox"/> BSP <input checked="" type="checkbox"/>	66.	
32.	Size	67.	

NOTES:

1.	* - Bidder to furnish details.
2.	All accessories shall be supplied as applicable.
3.	The bidder shall indicate all applicable codes and standards
4.	The solenoid coil shall operate the valve even when the supply voltage drops down by 15% or goes up by 10%.
5.	The coil shall be wired to a terminal block located inside the housing. Flying lead wires of the coil are not acceptable. the material of housing shall be metallic unless otherwise indicated in data sheet.
6.	Each solenoid valve body shall be subjected to pneumatic pressure test by air / nitrogen with test pressure not less than 1.5 times the maximum working pressure (rated) of the valve. There shall not be any visible leakage during the test
7.	Each solenoid valve shall be subjected to seat leakage test by air / nitrogen with test pressure equal to maximum working pressure (rated) of the valve for one minute. There shall not be any seat leakage during this test.
8.	The coil shall be low power consumption type. Generally the power consumption of coil shall be less than 5 W.

1.6. <u>TRANSFER PUMPS</u>		TO BE FILLED BY BIDDER
<i>Pump</i>		
Make	:	
Type & Model	:	
Discharge in LPS / GPM	:	
Head (Meters of WC)	:	
Shut off Head (Meters of WC)	:	
Efficiency (%)	:	
No. of Stages		
Suction End I.D.	:	
Delivery End I.D.	:	
Details of N.P.S.H.	:	
Vibration Isolation Detail	:	
Skid Details	:	
Operating Weight	:	
Overall Dimension (MM)	:	
Mechanical Seal Detail	:	
<i>Material</i>		
Body	:	
Impeller	:	
Type of Impeller		

Shaft	:	
Is it suitable for direct coupling	:	

<i>Motor</i>	:	
Make	:	
Model	:	
Power Requirement (HP / KW)	:	
R.P.M.	:	
Rating	:	
Over Load Capacity	:	
Class of Insulation	:	
Details of Additional protection in winding	:	
Motor Efficiency	:	
It it suitable for direct coupling to pump?	:	
Type of rotary movement	:	
Method of Starting	:	
Size and type of cable for connections.	:	
Number of variable frequency drive	:	
Detail of VFD	:	

1.	DATA SHEET TO BE FILLED BY BIDDER	
1.7.	<u>FLOAT SWITCH</u>	
	GENERAL	
2.	Manufacturer :	*
3.	Model no. :	*
4.		
5.	<u>FEATURES</u>	
6.	<u>Calibrated scale board</u>	
7.	Colour of numerals :	
8.	Height of numerals :	
9.	Accuracy : +/- 5 mm <input type="checkbox"/> +/- 10 mm <input type="checkbox"/>	
10.	Range :	
11.		
12.	<u>MATERIAL OF CONSTRUCTION</u>	
13.	Float : SS 316 <input type="checkbox"/> <input type="checkbox"/>	
14.	Float cable : SS 316 <input type="checkbox"/> <input type="checkbox"/>	
15.	Anchor : SS 316 <input type="checkbox"/> <input type="checkbox"/>	
16.	Spring assembly : spring steel <input type="checkbox"/> CS with cadmium plating <input type="checkbox"/>	
17.	Board : Aluminum epoxy painted <input checked="" type="checkbox"/> Aluminum polyurethane painted <input type="checkbox"/>	
18.	Guide wires (refer note 4 & 5) : SS 316 <input type="checkbox"/> <input type="checkbox"/>	

19.	Elbows : : Cast Aluminum Aluminum epoxy painted <input type="checkbox"/> Aluminum polyurethane painted <input type="checkbox"/>
20.	Pulley: SS316 <input type="checkbox"/> Aluminum <input type="checkbox"/>
21.	Pipe enclosing float cable: GI <input type="checkbox"/> SS 316 <input type="checkbox"/>
22.	<u>CONNECTIONS & DIMENSIONS</u>
23.	Type : flanged
24.	Flange size :
25.	Flange rating
26.	
27.	<u>ACCESSORIES (REFER NOTE 3)</u>
28.	Mounting brackets
29.	Name plate / metal tag
30.	Gaskets, bolts, nuts
31.	All installation hardware
32.	
33.	<u>CODES & STANDARDS</u>
34.	Refer note - 2
35.	
36.	<u>TESTS</u>
37.	Performance :
38.	Calibration :
39.	Hydro test for the float :

	<u>DRAWINGS/DOCUMENTS</u>	
1.	Vendor shall submit data sheets, catalogue and erection sketch for review and comments by purchaser/consultant.	
2.	Vendor shall submit instruction manual for records.	

	<u>TEST CERTIFICATES</u>	
1.	Vendor shall submit all routine test certificates for purchaser/consultant's review.	

NOTES :

- 1.0 *: bidder to state / furnish details; 3: required; – not required.
- 2.0 The bidder shall indicate all applicable codes & standards.
- 3.0 All accessories shall be supplied as applicable.
- 4.0 Sufficient float & guide wire to be supplied on single length to cut at site as per requirement.
- 5.0 Option of counter weight instead of anchoring of guide wire at bottom is decided based on site condition of the Tanks
- 6.0 Refer follow-up sheets for service and application details.

1.	FLOAT TYPE LEVEL SWITCHES DATA SHEET A <u>GENERAL</u>	
2.	Manufacturer : []	*
3.	Model no.:	*
4.	FEATURES	
5.	Type: Magnetic float with guide tube <input type="checkbox"/> Tilt type <input type="checkbox"/>	[]
6.	Accuracy: ± 2 MM	
7.	Mounting: Direct <input type="checkbox"/> External chamber <input type="checkbox"/>	[]
8.	<u>GUIDED FLOAT TYPE</u>	
9.	Switch type: glass encapsulated hermetically sealed reed switch <input type="checkbox"/>	[]
10.	Minimum distance between reed switches	*
11.	No. of floats: single <input type="checkbox"/> multiple <input checked="" type="checkbox"/> Refer followup sheet	
12.	C-C distance for external chamber mounted switches: []mm	[]
13.	<u>TIPT TYPE</u>	
14.	Switch type: Microswitch encapsulated in float	
15.	No. of floats: single <input type="checkbox"/> multiple <input type="checkbox"/> Refer followup sheet	
16.	<u>ENCLOSURE PROTECTION:</u>	
17.	Housing : IP-65 <input checked="" type="checkbox"/> IP [] <input type="checkbox"/>	[]
18.	Certification/ approval type: Ex d <input type="checkbox"/> Ex ia <input type="checkbox"/> NA <input type="checkbox"/>	
19.	Housing colour: Grey <input type="checkbox"/> Black <input type="checkbox"/>	[]
20.	Ex-proof to zone: 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> Group: I <input type="checkbox"/> IIA <input type="checkbox"/> IIB <input type="checkbox"/> IIC <input type="checkbox"/> Temperature class: T1/2/3/4/5/6	
21.	<u>SUPPLY / SIGNAL</u>	
22.	Switch contacts: SPDT <input type="checkbox"/> 1 NO	[]
23.	Switch contact rating : 0.2A, 220V DC / 5A , 230VAC	[]
24.	<u>MATERIAL:</u>	
25.	External chamber with drain/ vent arrangement: CS A105 <input type="checkbox"/> SS 316 <input type="checkbox"/> PP <input type="checkbox"/>	[]
26.	Float: 316 SS <input type="checkbox"/> PP <input type="checkbox"/> Others <input type="checkbox"/>	[]
27.	Guide tube: 316 SS <input checked="" type="checkbox"/> PP <input type="checkbox"/>	
28.	Bolts & nuts : ASTM A 193 Gr.B7 / A194 Gr.2H	[]
29.	Gaskets : PTFE <input type="checkbox"/> OTHERS <input type="checkbox"/>	[]
30.	Wetted parts: SS 316 <input type="checkbox"/> PP <input type="checkbox"/> OTHERS <input type="checkbox"/>	[]
31.	Flange: SS 316 <input type="checkbox"/> PP <input type="checkbox"/>	[]

32.	Housing: Die cast Aluminium <input type="checkbox"/> SS 316 <input type="checkbox"/> Polyamide <input type="checkbox"/>	
33.	Cable for tilt switch:	
34.	Counter weight for titl type switch:	
35.		
36.	CONNECTION & DIMENSIONS	
37.	External chamber connection type: Upper side - lower side <input type="checkbox"/> Upper side - lower bottom <input type="checkbox"/>	
38.	External chamber process connection size: $\frac{1}{2}$ " <input type="checkbox"/> 1" <input type="checkbox"/> others <input type="checkbox"/> Type : NPT <input checked="" type="checkbox"/> flange <input type="checkbox"/> SW <input type="checkbox"/>	[]
39.	External chamber instrument flange: ANSI class 150 RF flanged (Refer note 3.0)	
40.	Drain arrangement for external chamber Valve <input type="checkbox"/> Plug <input type="checkbox"/>	
41.	Vent plug	
42.	Process connction for direct mounted: ANSI class 150 RF flanged(Refer note 3.0)	
43.	Cable entry: 1"ET <input type="checkbox"/> $\frac{1}{2}$ " NPT <input type="checkbox"/> others <input type="checkbox"/>	[]
44.	ACCESSORIES	
45.	Still well for direct mounting	
46.	Counter weight to keep tilt type switch cable and float in position	
47.	Name plate : Removable – SS	[]
48.	Metal tag – SS	[]
49.	Counter flanges	[]
50.	<u>CODES AND STANDARDS</u>	
51.	Refer note no. 6.0	[]
52.		

53.	SPARES	
54.	Minimum one (1) no. Or 10% of total qty., whichever is higher, for each type and model no.	
55.		
56.	TESTS	
57.	Material test / contact rating test / hydro test / calibration test	
58.	Valid type test certificate to be provided for enclosure protection .	
59.	Vendor to submit test certificates for owner / engineer's review & records	
60.	DRAWING	
61.	The vendor to submit data sheet, dimensional drawing and erection sketch for review and comments by purchaser/ consultant.	
62.	The vendor shall submit all operating and service manuals for the equipment supplied for records	

NOTES:

- 1.0 Bidder to submit list of installations and commissions for the make & type of instrument offered and user's certificates.
- 2.0 Bidder to furnish details (*); required (✓); not required (-).
- 3.0 Float size shall be suitable to process conditions and tank height. Accordingly, instrument flange size shall be selected.
- 4.0 For qty. Refer to the attached bill of material.
- 5.0 All accessories shall be supplied as specified. In addition, any other accessories required shall be supplied without any price implication to make the measurement complete to match with process requirement.
- 6.0 Bidder shall indicate all applicable codes and standards.

1.8. ELECTRICAL TECHNICAL DATA SHEETS

For MCC +PDBs+MLDBs/SLDBs/DBs (To be filled by the bidders)

S.No	Description	TO BE FILLED BY BIDDER
1	Type of Panel	
2	Type of Mounting	
3	Fault kA	
4	Thickness of CRCA sheets	
a	Structural members	
b	Covers and doors	
c	Base channel	
d	Gland plate	
5a.	Painting/ Process	
b	Paint shade; a. Inside b. Outside	
6	Details of busbars	
7	Cable Entry	
8	Enclosure Protection/	

	Ventilation	
9	Control Wiring/ Power Wiring	
a.	Voltage Circuit	
b.	Current Circuit	
c.	Minimum size of Power wiring CKt	
10	Maximum Operating Height	
11	Mounting height of Relays/Meters Control Switches	

1.9. CONSTRUCTIONAL FEATURES FOR MCC

S.No.	Description	TO BE FILLED BY BIDDER
1	MCC	
a.	Busbar Chamber	
b.	Metering Chamber	
c.	Incoming Compartment	
d.	Overall Height	
e.	Overall Depth	
f.	Overall Length	
g.	Construction	
h.	Current Density	
i.	Main Bus	
ii.	Branch Bus Rating	
iii.	Neutral Bus	
iv.	Earth Bus	
j.	Incoming and outgoing feeders.	

2	AHU Panels	
a.	Accessibility	
b.	Overall Depth	
c.	Overall Height	
d.	Incoming compartment	

1.10. PIPES

SR	Description	TO BE FILLED BY BIDDER
1	MAKE	
2	Pressure rating	
3	MOC	
4	STANDARD	

TECHNICAL SPECIFICATION TO BE FILLED BY BIDDER

FOR

FIRE PROTECTION SYSTEM

2. DATA SHEET FOR FIRE PROTECTION SYSTEM

2.1. DATA SHEETS FOR INSTRUMENTS EQUIPMENT

2.1.1. Pressure Gauges

Sr. No.	Description	Bidder
1	Type	
2	Casing	
3	Glass	
4	Dial size	
5	Wetted Parts (including accessories)	
6	2-valve manifold	
7	Diaphragm seal	
8	Pointer	
9	Movement & socket	
10	Accuracy	
11	Process Connection	
12	Over range protection	
13	Accessories	

2.1.2. Pressure Switch

Sr. No.	Description	Bidder
1	Type	
2	Casing	
3	Wetted Parts (including accessories)	
4	Repeatability	
5	Micro switch contacts	

6	Over range protection	
7	Accessories	

2.1.3. Solenoid Valve

Sr. No.	Description	Bidder
1	Type	
2	Power supply	
3	Size	
4	Material of Construction	
5	Accessories	
6	Applications	
Notes: Terminal blocks and Manual actuator shall be provided in the solenoid valves.		

2.1.4. Level Gauge / Indicator – Float & Cord

Sr. No.	Description	Qty.	Bidder
	GENERAL		
1.	Manufacturer		
2.	Model No.		
	FEATURE		
3.	Calibrated scale board		
4.	Colour of numerals		
5.	Accuracy		
6.	Enclosure		
7.	Mounting		
8.	Height of numerals		
	MATERIAL OF CONSTRUCTION		
9.	Float		

10.	Float cable		
11.	Anchor		
12.	Spring assembly		
13.	Board		
14.	Guide wires		
15.	Elbows		
16.	Flanges		
	CONNECTION & DIMENSIONS		
17.	Type		
18.	Flange size		
19.	Flange rating		
20.	Name plate/ metal tag		
	Installation hardware		

2.1.5. Float Switch

Sr. No	Description	Bidder
40.	Manufacturer :	
41.	Model no. :	
42.		
43.	FEATURES	
44.	<u>Calibrated scale board</u>	
45.	Colour of numerals :	
46.	Height of numerals :	
47.	Accuracy : +/- 5 mm <input type="checkbox"/> +/- 10 mm <input type="checkbox"/>	
48.	Range :	
49.		
50.	MATERIAL OF CONSTRUCTION	
51.	Float : SS 316 <input type="checkbox"/> <input type="checkbox"/>	
52.	Float cable : SS 316 <input type="checkbox"/> <input type="checkbox"/>	
53.	Anchor : SS 316 <input type="checkbox"/> <input type="checkbox"/>	

54.	Spring assembly : spring steel <input type="checkbox"/> CS with cadmium plating <input type="checkbox"/>	
55.	Board : Aluminum epoxy painted <input type="checkbox"/> Aluminum polyurethane painted <input type="checkbox"/>	
56.	Guide wires (refer note 4 & 5) : SS 316 <input type="checkbox"/> <input type="checkbox"/>	
57.	Elbows : : Cast Aluminum Aluminum epoxy painted <input type="checkbox"/> Aluminum polyurethane painted <input type="checkbox"/>	
58.	Pulley: SS316 <input type="checkbox"/> Aluminum <input type="checkbox"/>	
59.	Pipe enclosing float cable: GI <input type="checkbox"/> SS 316 <input type="checkbox"/>	
60.	<u>CONNECTIONS & DIMENSIONS</u>	
61.	Type : flanged	
62.	Flange size :	
63.	Flange rating	
64.		
65.	ACCESSORIES (REFER NOTE 3)	
66.	Mounting brackets	
67.	Name plate / metal tag	
68.	Gaskets, bolts, nuts	
69.	All installation hardware	
70.		
71.	CODES & STANDARDS	
72.	Refer note - 2	
73.		
74.	TESTS	
75.	Performance :	
76.	Calibration :	
77.	Hydro test for the float :	

	DRAWINGS/DOCUMENTS	
1.	Vendor shall submit data sheets, catalogue and erection sketch for review and comments by purchaser/consultant.	
2.	Vendor shall submit instruction manual for records.	

	TEST CERTIFICATES	
1.	Vendor shall submit all routine test certificates for purchaser/consultant's review.	

NOTES :

- 1.0 *: bidder to state / furnish details; :required; – not required.
- 2.0 The bidder shall indicate all applicable codes & standards.
- 3.0 All accessories shall be supplied as applicable.
- 4.0 Sufficient float & guide wire to be supplied on single length to cut at site as per requirement.
- 5.0 Option of counter weight instead of anchoring of guide wire at bottom is decided based on site condition of the Tanks
- 6.0 Refer follow-up sheets for service and application details.

2.1.6. JUNCTION BOXES

Sr. No.	Description	Qty.	Bidder	
	GENERAL			
1.	Manufacturer			
2.	Model No.			
	FEATURE			
3.	Mounting			
4.	No. of terminals			
5.	Terminal type			
6.	Terminal size			
7.	Mounting plate			
8.	Cable entry			
9.	Gland plate			
10.	Door			
11.	Lock & key			
12.	Sheet thickness			
13.	Painting			
14.	Protection class			

Sr. No.	Description	Qty.	Bidder	
	MATERIAL OF CONSTRUCTION			
15.	Enclosure			
16.	Gasket			
17.	Cable entry sealing			
18.	Name plate/ metal tag			
19.	Installation hardware			

2.2. DATA SHEETS FOR HORIZONTAL CENTRIFUGAL PUMPS

2.2.1. DATA SHEETS B

Sl. No.	Item		Bidder
1.	Designation:		
2.	Number offered		
3.	Tag numbers		
4.	Pump make and model number		
5.	Design capacity	M ³ /hr	
6.	Differential head	Mlc	
7.	Shut-off head	Mlc	
8.	Hydrostatic test pressure	Kg/cm ² (g)	
9.	Number of stages		
10.	Pump efficiency at duty point	%	
11.	Pump speed	Rpm	
12.	Pump bkw	Kw	
13.	Maximum pump power requirement	Kw	
14.	Power input to driver at duty point	Kw	
15.	Method of lubrication		
17.	Npsh required	Mlc	

18.	Driver rating	Kw	
19.	Driver speed	Rpm	
20.	Driver efficiency	%	
21.	Suction nozzle		
21.1	Orientation		
21.2	Size	Mm nb	
22.	Discharge nozzle		
22.1	Orientation		
22.2	Size	Mm nb	
23.	Type and make of mechanical seal		
24.	Type of coupling		
25.	Minimum capacity for continuous	M ³ /hr	
	Operation		
26.	Maximum allowable size of solids	Mm	
27.	External water requirement for		
	Cooling		
27.1	Flow rate	M ³ /hr	
27.2	Pressure	Kg/cm ² (g)	
28.	External water requirement for		
	Sealing		
28.1	Flow rate	M ³ /hr	
28.2	Pressure	Kg/cm ² (g)	
29.	Weight of bare pump	Kg	
30.	Weight of driver	Kg	
31.	Weight of common base plate	Kg	
32.	Moment of inertia of pump rotor	Kg-m ²	
33.	Accessories as per data sheet a to		whether included
	Be included		Yes no
34.	Outline dimensional drawing to be		Whether enclosed

	Enclosed		Yes/no
35.	Foundation drawing with static		Whether enclosed
	And dynamic loads to be enclosed		Yes/no
36.	Cross-section drawing of pump		
	With part list and materials of		Whether enclosed
	Construction and relevant		Yes/no
	Standards to be enclosed		
37.	Performance curves flow rate vs		
	Head, bkw, efficiency, npshr and		Whether enclosed
	Torque-speed curve to be enclosed		Yes/no
38.	Performance guarantee		
38.1	Capacity	M3/hr	(+) (-)
38.2	Differential head	Mlc	(+) (-)
38.3	Power consumption	Kw	(+) (-)

2.2.2. DATA SHEET C

DATA TO BE FURNISHED BY THE VENDOR AFTER THE ISSUE OF PURCHASE ORDER

- (a) List of drawings and documents to be submitted for review, approval and information with scheduled submission dates
- (b) Quality Assurance Plan (QAP)
- (c) Detailed dimensioned general arrangement drawing of pump and driver. This drawing shall indicate all the design data and information furnished in data sheets A and B.
- (d) Foundation drawing of pump and driver with static and dynamic loads, details of fixing, grouting and all relevant data required for design of foundation
- (e) Cross-section drawing of the pump with complete part list, materials of construction and relevant standards for each part
- (f) Pump performance curves flow rate Vs head, BKW, efficiency, NPSHR from zero flow to maximum flow and torque-speed curve
- (g) Scheme for pump sealing, lubrication and cooling

- (h) Driver dimensional drawing
- (i) Surface preparation and painting procedures
- (j) Catalogues, data sheets and drawings for instruments
- (k) Installation, operation and maintenance manual along with lubricant.

2.3. DATA SHEETS FOR DIESEL ENGINE AND ACCESSORIES

2.3.1. DATA SHEETS B

Sr.No	Item		Bidder
<u>1.0</u>	DIESEL ENGINE & AUXILIARIES (Design Features)		
<u>1.1</u>	Name of manufacturer / Model no.		
<u>1.2</u>	Engine rating at ISO standard reference condition	KW	
<u>1.3</u>	Engine rating at site	KW	
<u>1.4</u>	Maximum engine rating at site	KW	
<u>1.5</u>	Derating factors :		
	(a) Altitude	%	
	(b) Inlet air temperature	%	
	(c) Humidity	%	
	(d) Cooling Water Temperature	%	
	(e) Overall Derating Factors	%	
<u>1.6</u>	Period of maximum engine rating	Hour	
<u>1.7</u>	Operating speed	RPM	
<u>1.8</u>	No. of strokes/cycle		
<u>1.9</u>	No. of cylinders		
<u>1.10</u>	Arrangement of cylinders		
<u>1.11</u>	Rotation direction (viewed from free end)		
<u>1.12</u>	Compression ratio		
<u>1.13</u>	Supercharging air pressure at rated load	mm of Hg	
<u>1.14</u>	Firing order (viewed from power take-off end)		
<u>1.15</u>	Jacket Water temperature at rated load Inlet / Outlet	° C	

<u>1.16</u>	Jacket Water pressure (at engine inlet)	Kg / cm ² (g),	
<u>1.17</u>	Fuel system injector pressure	Kg / cm ² (g),	
<u>1.18</u>	Fuel system booster pump pressure	Kg / cm ² (g),	
<u>1.19</u>	Lube oil pressure at pump discharge	Kg / cm ² (g),	
<u>1.20</u>	Lube oil temperature at pump in engine sump	° C	
<u>1.21</u>	Minimum acceptable lube oil temperature at start up	° C	
<u>1.22</u>	Minimum acceptable lube oil pressure at start - up	Kg / cm ² (g),	
<u>1.23</u>	Maximum period for which the engine can operate without cooling water supply	min.	
<u>2.0</u>	DIESEL ENGINE & AUXILIARIES (Construction Features)		
<u>2.1</u>	Bed Plate :		
<u>2.1.1</u>	Material		
<u>2.1.2</u>	Construction		
<u>2.2</u>	Crankcase housing :		
<u>2.2.1</u>	Material		
<u>2.2.2</u>	Construction		
<u>2.3</u>	Cylinder heads :		
<u>2.3.1</u>	Material		
<u>2.3.2</u>	Construction		
<u>2.4</u>	Cylinder liners		
<u>2.4.1</u>	Material		
<u>2.4.2</u>	Construction		
<u>2.5</u>	Crank Shaft :		

<u>2.5.1</u>	<u>Material</u>	<u> </u>	
<u>2.5.2</u>	<u>Construction</u>	<u> </u>	
<u>2.5.3</u>	<u>Method of attachment of balance weights</u>	<u> </u>	
<u>2.6</u>	<u>Connecting rods :</u>	<u> </u>	
<u>2.6.1</u>	<u>Material</u>	<u> </u>	
<u>2.6.2</u>	<u>Construction</u>	<u> </u>	
<u>2.7</u>	<u>Connecting rod bearings :</u>	<u> </u>	
<u>2.7.1</u>	<u>Material</u>	<u> </u>	
<u>2.7.2</u>	<u>Construction</u>	<u> </u>	
<u>2.8</u>	<u>Pistons</u>	<u> </u>	
<u>2.8.1</u>	<u>Material</u>	<u> </u>	
<u>2.8.2</u>	<u>Construction</u>	<u> </u>	
<u>2.9</u>	<u>Nos. of inlet valves/cylinder head</u>	<u> </u>	
<u>2.10</u>	<u>Nos. of exhaust valves/cylinder head</u>	<u> </u>	
<u>2.11</u>	<u>Fly wheels :</u>	<u> </u>	
<u>2.11.1</u>	<u>Material</u>	<u> </u>	
<u>2.11.2</u>	<u>Construction</u>	<u> </u>	
<u>2.11.3</u>	<u>Diameter</u>	<u>mm</u>	
<u>2.11.4</u>	<u>Moment of inertia</u>	<u>Kg/sq.m</u>	
<u>2.12</u>	<u>Supercharger :</u>	<u> </u>	
<u>2.13.1</u>	<u>Type</u>	<u> </u>	
<u>2.13.2</u>	<u>Manufacturer</u>	<u> </u>	
<u>2.13.3</u>	<u>Number</u>	<u> </u>	
<u>2.13.4</u>	<u>Drive</u>	<u> </u>	
<u>2.13.5</u>	<u>Speed</u>	<u>RPM</u>	
<u>2.13.6</u>	<u>Lubrication</u>	<u> </u>	

<u>2.13.7</u>	Bearing cooling		
<u>2.14</u>	Fuel oil system :		
<u>2.14.1</u>	Type		
<u>2.14.2</u>	Filters :		
	(a) Type (b) Number (c) Location		
<u>2.14.3</u>	Engine drive booster pump :		
	(a) Type (b) Rating		
<u>2.14.4</u>	Injection pumps :		
	(a) Type (b) Number		
<u>2.14.5</u>	Injection :		
	(a) Type (b) Cooling		
<u>2.14.6</u>	AC motor driven priming pump, if any.		
	(a) Type (b) Rating		
<u>2.14.7</u>	Day tank :		
	(a) Capacity (b) Material (c) Location	<u>Litres</u>	
<u>2.14.8</u>	Characteristics of fuel oil to be used		
<u>2.15</u>	Lube oil system		
<u>2.15.1</u>	Type		
<u>2.15.2</u>	Filters :		
	(a) Type (b) Number (c) Location		
<u>2.15.3</u>	Engine driven lube oil pump :		

_____	(a) Type (b) Rating	_____	
<u>2.15.4</u>	DC motor driven standby pump, if any :	_____	
_____	(a) Type (b) Location (c) Rating	_____	
<u>2.15.5</u>	AC motor driven priming pump, if any :	_____	
_____	(a) Type (b) Location (c) Rating	_____	
<u>2.15.6</u>	Lube oil tank	_____	
_____	(a) Capacity (b) Material (c) Location	_____	
<u>2.15.7</u>	Grade of lube oil to be used	_____	
<u>2.16</u>	Jacket water system :	_____	
<u>2.16.1</u>	Type	_____	
<u>2.16.2</u>	Quality of water to be used	_____	
<u>2.16.3</u>	Quantity of water :	_____	
_____	(a) Engine cooling circuit	_____	
_____	(b) Lube oil cooler	_____	
_____	(c) Charge air cooler	_____	
<u>2.16.4</u>	Make up tank	_____	
_____	(a) Capacity (b) Material (c) Location	_____	
<u>2.16.5</u>	Engine driven pump :	_____	
_____	(a) Type	_____	
_____	(b) Rating	<u>KW</u>	
<u>2.16.6</u>	Bypass control valves :	_____	
_____	(a) Type (b) Location	_____	

2.16.7	Radiator (If provided)		
	(a) Rating of radiator fan	<u>KW</u>	
<u>2.17</u>	Air Intake System :		
	(a) Intake filter type (b) Location		
<u>2.18</u>	Exhaust gas system :		
<u>2.18.1</u>	Manifolds :		
	(a) Location (b) Size (c) Construction (d) Material		
<u>2.18.2</u>	Expansion joints :		
	(a) Number (b) Type (c) Location (d) Material		
<u>2.18.3</u>	Exhaust silencer :		
	(a) Type (b) Location		
<u>2.19</u>	Air starting system :		
2.19.1	Type		
<u>2.19.2</u>	Distributor, if any		
	(a) Drive (b) Type (c) Location		
<u>2.19.3</u>	Starting air valves, if any :		
	(a) Type (b) Location		
<u>2.19.4</u>	AC motor driven air compressor :		
	(a) Manufacturer (b) Type		

2.19.5	Air receiver :	_____	
_____	(a) Number (b) Construction (c) Material (d) Capacity	Litres	
2.19.6	Time to replenish system after six consecutive engine starts	Min	
2.19.7	Quantity of free air/start		
2.19.8	Starting air pressure	Kg/cm ²	
2.19.9	Minimum air pressure at which engine can be started	Kg/cm ²	
2.20	Terminal piping	_____	
2.20.1	Day oil tank :	_____	
_____	(a) Size (b) Type	_____	
2.22.2	Lube oil heat exchanger	_____	
	Cooling water 'IN'		
_____	(a) Size (b) Type	_____	
	Cooling water 'Out'		
	(a) Size (b) Type	_____	
2.22.3	Jacket water heat Exchanger :	_____	
	Cooling Water 'IN'		
_____	(a) Size (b) Type	_____	
_____	Cooling Water 'OUT'	_____	
_____	(a) Size (b) Type	_____	
2.21	Heat exchangers (shell and tube type)	_____	
_____	A. Construction Features :	_____	
_____	.1 Position (Horizontal/vertical) .2 Size (shell dia. X str. Tube length) .3 Type .4 Surface	_____	

	B. Shell Side		
	.1 Fluid circulated		
	.2 Quantity of fluid circulated	m^3/hr	
	.3 Temperature, inlet	$^{\circ}\text{C}$	
	.4 Temperature, outlet	$^{\circ}\text{C}$	
	C. Tube Side		
	.1 Fluid circulated	m^3/hr	
	.2 Quantity of fluid circulated		
	.3 Temperature, inlet	$^{\circ}\text{C}$	
	.4 Temperature, outlet	$^{\circ}\text{C}$	
	D. MATERIAL SPECIFICATION		
	.1 Shell		
	.2 Tubes		
	.3 Tube sheet		
	.4 Gaskets		
	.5 Bolts		
	.6 Nuts		
	.7 Channel		
	.8 Channel cover		
	.9 Flanges		
3.0	PERFORMANCE GUARANTEE		
3.1	Net electrical output at engine shaft at site after engine derating factors and auxiliary power requirements have been taken into account		
3.2	Specific Fuel oil consumption :		
	(a) Full load	g/kW hr.	

	(b) 75% load (c) 50% load (d) 25% load	g/kW hr. g/kW hr. g/kW hr.	
3.3	Lube oil consumption at rated load	Litres / hr	
3.4	Jacket water temperature 'IN' to engine	° C	
3.5	Jacket water temperature 'OUT' from engine	° C	
3.6	Lube oil temperature 'IN' to engine	° C	
3.7	Lube oil temperature 'OUT' from engine	° C	
3.8	Vibration level	mm / s	
3.9	Noise level	db (A)	
4.0	WEIGHT SCHEDULE		
4.1	Weight of engine, less flywheel including standard accessories	Kg.	
4.2	Weight of flywheel	Kg.	
4.3	Weight of day oil tank	Kg.	
4.4	Total shipping weight	Kg.	
4.5	Weight of control panel	Kg.	
4.6	Total equipment weight	Kg.	
4.7	Heaviest single piece to be handled during (a) Erection (b) Maintenance	Kg	
5.0	DIMENSIONS		
5.1	Shipping dimension of engine		
5.2	Overall dimensions of the engine including flywheel		
5.3	Overall dimensions of day oil tank		
5.4	Maintenance space required around the diesel engine		

2.3.2. DATA SHEET C

DATA TO BE SUBMITTED BY THE CONTRACTOR AFTER THE AWARD OF CONTRACT

- (a) General arrangement drawings showing overall dimensions, equipment arrangement and details and arrangement of terminals.
- (b) Equipment details drawing
- (c) Equipment foundation drawing with load details
- (d) Fuel oil system with instrumentation and control with write up
- (e) Lube oil system with instrumentation and control with write up
- (f) Governor system with write up
- (g) Piping drawing for the entire system
- (h) Detailed instruction manual for installation, operation, maintenance repairs and major overhaul
- (i) Wiring diagram of various sensing devices mentioned, on engine, air receiver, etc. control panel and governor system

2.4. DATA SHEET FOR HYDRANT VALVE

2.4.1. DATA SHEETS B

Sl. No.	Item	Unit	Bidder:
General	1. Sub vendor's name / make		/
	2.		
	3.		
	4.		
	5.		
	6.		
	7.		
	8.		

2.4.2. DATA SHEETS C

DATA TO BE FURNISHED BY THE CONTRACTOR AFTER THE AWARD OF CONTRACT

- (a) List of drawings and documents to be submitted for review, approval and
- (b) information along with scheduled submission dates

-
- (c) Quality Assurance Plan (QAP)
 - (d) Descriptive catalogues
 - (e) Dimensional drawings
 - (f) Cross-sectional drawing of hydrant valve assembly with part list and material of construction of each part
 - (g) Material test certificates
 - (h) Current ISI certificates

2.5. DATA SHEET FOR BRANCH PIPES AND NOZZLES

2.5.1. DATA SHEETS B

	Sl.no.	Item	Unit	Bidder:
General	1.	Sub-vendor's name / make		/
	2.			
	3.			
	3.			
	4.			
	5.			
	6.			
	7.			
	8.			
	9.			
	10.			
Documents	11.	Dimensional drawings of branch pipe with nozzle is enclosed?		Yes / no
	12.			
	13.			
	14.			
	15.			
	16.			

2.5.2. DATA SHEETS C

DATA TO BE FURNISHED BY THE CONTRACTOR AFTER THE AWARD OF CONTRACT

- (a) Technical Data Sheet
- (b) Quality Assurance Plan (QAP)
- (c) Dimensional outline drawing, Part list with material specifications.
- (d) Material test certificates
- (e) Current ISI Certificate

2.6. DATA SHEET FOR FIRE HOSES WITH COUPLING

2.6.1. DATA SHEETS B

	Sl. No.	Item	Bidder	
General	1.	Sub-vendor's name / make		/
	2.	Brand name of the product offered		
	3.	Design code for hose		
	4.	Design code for coupling		
	5.	Manufacturer's catalogues for hoses and delivery couplings to be enclosed		Yes / no
	6.			
	7.			
	8.			
	9.			
	10.			
	11.			

2.6.2. DATA SHEETS C

DATA TO BE FURNISHED BY THE CONTRACTOR AFTER THE AWARD OF CONTRACT

- (a) Technical data Sheet
- (b) Quality Assurance Plan (QAP)
- (c) Dimensional outline drawing, Part list with material specifications.
- (d) Material test certificates

-
- (e) Hose proof pressure and bursting pressure test certificates
 - (f) Coupling hydrotest pressure test certificates
 - (g) Any other document / details as required as per approved QAP
 - (h) Current ISI certificates

2.7. DATA SHEET FOR FIRE HOSES CABINETS

2.7.1. DATA SHEETS B

	Sl. No.	Item	Unit	Bidder
General	1.	Sub-vendor's name / make		/
	2.	Dimensions		L b d
	2.1	Suitable for hydrants	Mm	X x
	2.3	Suitable for hydrant and hose reel assembly	Mm	X x
	3.	Whether tac approved		-na-
	4.			
	5.			
	6.			
	7.			
	8.			
	9.			
	10.			
Documents	11.	Dimensional drawings of cabinets to be		Whether enclosed : yes/no
		Enclosed		
	12.	Cross-sectional drawings of		Whether enclosed : yes/no
		Cabinets to be enclosed		
	13.			
	14.			
	15.			
	16.			

2.7.2. DATA SHEETS C

DATA TO BE FURNISHED BY THE CONTRACTOR AFTER THE AWARD OF CONTRACT

- (a) Technical data Sheet
- (b) Quality Assurance Plan (QAP)
- (c) Dimensional outline drawing indicating plan, elevation and end views showing arrangement of accessories, Part list with material specifications.

-
- (d) Cabinet supporting arrangement

2.8. DATA SHEET FOR FIRE HOSES REELS

2.8.1. DATA SHEETS B

	Sl no.	Item	Bidder:
General	1.	Subvendor's name / make	/
	2.	Descriptive catalogues listing all	
		Items and accessories with brief	Yes/no
		Specifications to be enclosed	
	3.	Overall dimensional drawing of	
		Hose reel to be enclosed	Yes/no
	4.	Whether tac approved	-na-
	5.	Whether isi marked	Yes/no
	6.	Whether certified by any	
		Authorities	Yes/no

2.8.2. DATA SHEETS C

DATA TO BE FURNISHED BY THE CONTRACTOR AFTER THE
AWARD OF CONTRACT

- (a) Schedule of drawings and documents to be submitted along with submission dates
- (b) Quality Assurance Plan (QAP)
- (c) Descriptive catalogues
- (d) Dimensional drawings
- (e) Cross-sectional drawing of hose reel assembly with part list and material of construction of each part
- (f) Current ISI certificates
- (g) Material test certificates

2.9. DATA SHEETS FOR PORTABLE FIRE EXTINGUISHERS

2.9.1. DATA SHEETS B

Sl no	Type	Capacity	Make	Isi marked	Catalouge for each type to be enclosed. Whether enclosed
1.	Sand/water bucket	10.0 lit		Yes/no	Yes/no
2.1	Carbon dioxide	2.0 kg		Yes/no	Yes/no
2.2		3.0 kg		Yes/no	Yes/no
2.3		4.5 kg		Yes/no	Yes/no
2.4		6.5 kg		Yes/no	Yes/no
2.5		9.0 kg		Yes/no	Yes/no
2.6		22.5 kg		Yes/no	Yes/no
2.7		6 to 7 kg × 2 nos.		Yes/no	Yes/no
2.8					
2.9					
3.1	Chemical foam	9.0 lit		Yes/no	Yes/no
3.2		50.0 lit		Yes/no	Yes/no
3.3		150.0 lit		Yes/no	Yes/no
3.4					
4.1	Mechanical foam	9.0 lit		Yes/no	Yes/no
4.2		135.0 lit		Yes/no	Yes/no
4.3					
5.1	Soda acid	9.0 lit		Yes/no	Yes/no
5.2		50.0 lit		Yes/no	Yes/no
6.1	Abc dry chemical powder	0.5 kg		Yes/no	Yes/no
6.2		1.0 kg		Yes/no	Yes/no
6.3		2.0 kg		Yes/no	Yes/no
6.4		6.0 kg		Yes/no	Yes/no
6.5		9.0 kg		Yes/no	Yes/no
6.6		1.0 kg		Yes/no	Yes/no
6.7		2.0 kg		Yes/no	Yes/no

Sl no	Type	Capacity	Make	Isi marked	Catalouge for each type to be enclosed. Whether enclosed
6.8		5.0 kg		Yes/no	Yes/no
6.9		10.0 kg		Yes/no	Yes/no
6.10		25.0 kg		Yes/no	Yes/no
6.11		50.0 kg		Yes/no	Yes/no
6.12		75.0 kg		Yes/no	Yes/no
				Yes/no	Yes/no
7.1	Halon 1211	1.25 kg		Yes/no	Yes/no
7.2		2.5 kg		Yes/no	Yes/no
7.3		4.0 kg		Yes/no	Yes/no
7.4		5.0 kg		Yes/no	Yes/no
7.5		6.5 kg		Yes/no	Yes/no
8.1	Water(gas cartridge)	9.0 lit		Yes/no	Yes/no
8.2					

2.9.2. DATA SHEETS C

DATA TO BE FURNISHED BY THE CONTRACTOR AFTER THE AWARD OF CONTRACT

- (a) List of drawings and documents to be submitted for review, approval and information along with scheduled submission dates
- (b) Quality Assurance Plan (QAP)^a
- (c) Descriptive catalogues for each type of extinguisher
- (d) Detailed dimensional drawings for each type of extinguisher with trolley (wherever applicable)
- (e) Cross-sectional drawing of hydrant valve assembly with part list and material of construction of each part
- (f) Dimensional drawing of supporting stand for each type of floor mounted extinguisher
- (g) Fixing detail for each type of wall mounted and column mounted extinguisher

2.10.1. DATA SHEET-B (GATE VALVE)

General	1.	Tag no.:					Size	Quantity			
	2.	Size range:									
	3.	Rating:					Mm	P0	R0	R1	R2
	4.	Grade:									
	5.	Fluid :									
Construction features	8.	Stem :									
	9.	Ends :									
	11.	Bonnet :									
	12.	Wedge :									
	13.	Operator :									
	14.	Seat :									
		:									
	15.	Other requirements :									
		Conforming to									
Materials	16.	Body/ bonnet	:								
	17.	Wedge	:								
	18.	Stem	:								
	19.	Body seat ring	:								
	20.	Wedge facing ring	:								
	21.	Gland packing	:								
	22.	Gasket	:								
	23.	Bolts & nuts	:								
	24.	Handwheel	:								
Tests & inspection	25.	Shell hydro	:								
	26.	Seat hydro	:								
	27.										
	28.	Inspection :									

Notes: 1. General requirements: as per valves and specialities general requirements
2. Additional tests indicated as 'b' in shops inspection requirements shall also be carried out when it is applicable.

2.10.2. DATA SHEET-B (WAFER CHECK VALVES)

General	1.	Tag no.	:		4. Fluid	:	Size	Quantity			
	2.	Size range	:		5. Des. Pr.	:					
	3.	Rating	:		6. Des. Temp.	:	Mm	P0	R0	R1	R2
	7.	Standard			Grade:						
Construction features	8.	Type	:								
	9.	Ends	:								
			:								
	10.		:								
	11.		:								
	12.		:								
	13.		:								
	14.	Other requirements	:								
			:								
			:								
Materials	15.	Body	:								
	16.	Plate	:								
	17.	Seal	:								
	18.	Plate seat	:								
	19.	Spring	:								
	20.	Hinge pin & stop pin	:								
	21.		:								
Tests & inspection	24.	Shell hydro	:								
	25.	Seat hydro	:								
	26.	Inspection :									

Notes: 1. General requirements: as per valves and specialities general requirements
2. Additional tests indicated as 'b' in shops inspection requirements shall also be carried out when it is applicable.

2.10.3. DATA SHEET-B (BALL VALVES)

General	1.	Tag no.	:	--			Size	Quantity			
	2.	Size range	:								
	3.	Rating	:					P0	R0	R1	R2
	4.	Grade	:								
Construction features	5.	Port	:				Refer boq				
	6.	Stem	:								
	7.	Ends	:								
	8.	Operation	:								
	9.	Antistatic feature	:	Not required							
	10.	fire safe design (api 607)	:	Not required							
	11.	other requirements	:	Three piece construction							
		Size, (in/ mm) :									
	Ins. Thk., mm :										
Materials	12.	Body	:								
	13.	Ball (mirror finished)	:								
	14.	Stem	:								
	15.	Seat	:								
	16.	Seal (stem & body)	:								
	17.	Bolts, studs & nuts	:								
	18.										
Tests & inspection	19.	Shell hydro	:			Barg					
	20.	Seat hydro	:			Barg					
	21.	Seat air	:			Barg					
	22.	Inspection :									
<p>Notes: 1. General requirements: as per valves and specialities general requirements</p> <p>2. Additional tests indicated as 'b' in shops inspection requirements shall also be carried out when it is applicable.</p>											

2.10.4. DATA SHEET-B (Y STRAINER)

Design data	1.	Tag no.		
	2.	Quantity required		
	3.	Location		
	4.	Type		
	5.	Fluid		
	6.	Flow rate	m ³ /hr	
	7.	Operating pressure	barg	
	8.	Operating temperature	° c	
	9.	Design pressure	barg	
	10.	Design temperature	° c	
	11.	Fluid viscosity (cp) at op.temp.		
	12.	Fluid sp. Gravity at op. Temp.		
	13.	Max. Permissible pr. Drop Under 50% clogged condition		
	14.	Screen basket data		
		1. Dia of perforations, mm		
	2. Min. Thickness, mm			
	3. Free straining area			
15.	Steam jacket			

		1. Inlet pr. Barg, op. / desn.	
		2. Inlet temp. ° c, op./desn.	
	16.	End connections	
		1. Size, nb mm	
		2. Type	
		3. Details/ standards	
	17.	Cover	
	18.	lbr approval	
Materials	19.	Body	
	20.	Cover	
	21.	Screen basket	
	22.	Bolts/ studs	
	23.	Nuts	
	24.	Gaskets	
	25.	Jacket	
	26.	Jacket couplings/ flanges	
ests & inspection	27.	Accessories by vendor:	
	27.1	Foundation bolts	
	27.2	Differential pressure gauge	
	27.3	Drain/ vent cock (ss 316)	
	27.4	Support legs	
	26.	Hydrostatic test pressure, barg	
	26.1	Shell side	
	26.2	Jacket side	
	27.	Vacuum test required	
	28.	Pressure drop test required	
		Clean/ 50% clogged	
	29.	Inspection: as per a) shop inspection and testsand	
	30.		
Notes: 1. General requirements: as per valves and specialties general requirements			
2. Additional tests indicated as 'b' in shops inpection requirements shall also be carried out when it is applicable.			
3. '*': Bidder to furnish information.			
4. Additional tests indicated as 'b' in shops inpection requirements shall also be carried out when it is applicable.			
5. Gasket shall be metal wire-reinforced and graphited both sides.			

2.10.5. DATA SHEET-B (BUTTERFLY VALVE)

Sl. No.	Item	Unit	
1.0	General		
5.5.	Service		
5.6.	Tag nos.		
5.7.	No. Of valves	No.	

Sl. No.	Item	Unit			
5.8.	Design standard				
5.9.	Valve category (in case api std.is being considered)				
5.10.	Disc				
5.11.	Body type				
5.12.	Valve size	Nb			
5.13.	Valve rating / class				
5.14.	Fluid handled with its spec. Gravity				
5.15.	Companion flange type and class				
5.16.	Type of valve operator				
5.17.	Maximum flow (indicate the related pressure also)	M ³ /hr, Kpa			
5.18.	Maximum flow velocity	M/s			
5.19.	Design pressure	Kpa			
5.20.	Operating pressure	Kpa			
5.21.	Design temperature	⁰ c			
5.22.	Operating temperature	⁰ c			
5.23.	Valve location				
5.24.	Maximum differential pressure	Kpa			
5.25.	Shut off class / requirements				
5.26.	Valve flange face				
5.27.	Type of mating flange				
5.28.	Drilling standard				
5.29.	Surface finish				
5.30.	Preferred face to face dimension	Mm			
5.31.	Power supply	Phase ,v, hz,			
5.32.	Air / hydraulic supply pressure	Bar			
5.33.	Valve opening / closing time	Secs			
5.34.	Fail safe position of actuator				
5.35.	Shut off applicability				
5.36.	Frequency of valve operation				
5.37.	Valve shaft orientation				
5.38.	Fire tested				
5.39.	Electric continuity between shaft /				

Sl. No.	Item	Unit	
	body / disc		
5.40.	Motor spec. (for motorised actuator only)		
5.41.	Application of valve for dead – end service		
5.42.	Application of valve for bi-directional service.		
6.	Accessories		
6.1.	Floor stand		
6.2.	Companion flange with bolts, nuts & gaskets		
6.3.	Lifting lugs		
6.4.	Tapped holes in lug		
6.5.	Extension spindle		
6.6.	Torque & limit switch mechanism		
6.7.	End limit switches		
6.8.	Adjustable seat		
6.9.	Reduction gear unit		
6.10.	Locking device		
6.11.	Valve position indicator		
6.12.	Body lining		
6.13.	Auxilliary hand wheel		
6.14.	Blow out proof stem		
7.	Additional requirement		
7.1.	Painting(refer note-9)		
7.2.	Seismic qualification of valve required If yes, indicate the document no. For response spectrum or equivalent data which the vendor has to refer		
7.3.	Any other requirement		
8.	Materials of construction		
8.1.	Body		
8.2.	Disc		
8.3.	Stem		
8.4.	Seat		
8.5.	Body seat rings		

Sl. No.	Item	Unit	
8.6.	Disc seal rings		
8.7.	Seat retaining rings		
8.8.	Companion flange		
9.	Tests and inspection		
9.1.	Additional tests indicated as 'b' in shops inspection requirements shall also be carried out when it is applicable.		
9.2.	Hydrostatic test pressure for body	$\frac{\text{Kg}}{\text{cm}^2}$	
9.3.	Hydrostatic test pressure for disc	$\frac{\text{Kg}}{\text{cm}^2}$	
9.4.	Disc strength test pressure	$\frac{\text{Kg}}{\text{cm}^2}$	
9.5.	actuator performance test pressure	$\frac{\text{Kg}}{\text{cm}^2}$	
9.6.	Air leak test pressure	$\frac{\text{Kg}}{\text{cm}^2}$	
9.7.	Electrical continuity test		
10.	spares		
10.1.	Disc seal rings		
10.2.	Flange gasket		
10.3.	Seat/seal clamping bolts		
10.4.	'O' ring seals or gland packing		
10.5.			

NOTES:-

- For general requirements refer valve and specialities. However, in case of overlapping requirements, those of the data sheet a, to be considered as the final one.
- The valve shall be designed considering the larger of the following torque requirements for which calculations shall be submitted:
 - Calculated as per awwa-c504-80
 - Calculated as per the standard to which valve is designed.
- For manually operated valves, torque required at hand wheel shall not exceed 7 kg.m.
- Motor operated valve actuator shall be rated to provide an output torque of atleast 150% of torque required as per note-2 above unless otherwise noted.
- The actuator shall be capable of operating in any mounting angle.
- The transmission unit shall be designed to transmit twice the valve design torque unless otherwise noted.
- The actuator shall provide an unseating torque of at least 50% in excess of valve seating torque at the specified voltage unless otherwise noted.
- Segmental welded carbon steel flange plates above 20 mm thickness shall be subjected to preheating before welding and stress relieving after welding as per is 2825 unless otherwise specified.

9. Unless otherwise specified in section –c, one coat of zinc rich primer and two coats of enamel shall be applied to all steel and cast iron exposed surfaces. The minimum thickness of coating shall be 100 microns.
10. The vendor may also suggest any additional spares and tools required for the successful operation, start up and maintenance of the valve.
11. In the absence of any test related data, the relevant testing standard for butterfly valves may be indicated.

2.10.6. DATA SHEET-C

Data to be furnished by the vendor after the

Issue of purchase order

- (a) List of drawings and documents to be submitted for review, approval or information with scheduled submission dates.
- (b) Quality Assurance Plan (QAP)
- (c) Drawings showing outline dimensions, clearance dimensions for disassembly, weight, part numbers, materials of construction, test pressures, statutory and any special requirements, sizes, tag numbers and quantities. All information covered in data sheets A and B shall be incorporated in this drawing. The PURCHASER'S identifying tag numbers shall be shown on each drawing or on a sheet attached to the drawing with proper cross-references.
- (d) Operation and maintenance manuals

2.11. FIRE WATER PIPING GENERAL REQUIREMENTS

2.11.1. DATA SHEET B

Scope	1. Supply of pipes and fittings:	Design data	8. Piping:
	2. Supply of valves and specialities:		9. Welding: as per specification
			10. Underground protection:
	3. Supply of structural steel for pipe supports		
	4. Erection, testing and commissioning of piping system:		11.-Valve chambers: brick masonry/ Stone masonry/rcc as per drg
	5. Excavation and back filling:	Tests and inspection	
	6. Valve chambers with covers (wherever necessary):		(note 1)
			13.
	7. Painting and corrosion protection:		14.
			15.

Notes:	
1.	Additional tests indicated as 'b' in shops inspection requiremets shall also be carried out when it is applicable.
	Also be carried out when these are applicable.
*	bidder shall submit the drawing and the same shall be revised to incorporate the comments of client / consultant before being released for construction.

2.12. FIRE UNDERGROUND PROTECTION FOR PIPING

2.12.1. (DATA SHEETS A)

General and materials	1.	Supply of all coating and	By contractor
		Wrapping materials	
	2.	Soil resistivity	
	3.	Type of underground protection	
	4.		
Application	5.	Application methodology	
	6.		
Testing	7.	Coating thickness	
	8.	Bond/ adhesion test for coating /	
		Wrapping tapes	
	9.	Holiday test	
Documents	10.	Documents required after the	
		Award of contract	

2.13. FIRE PROTECTION EQUIPMENT WET PIPE TYPE SPRINKLER SYSTEM

2.13.1. DATA SHEETS B

General	1. Standard:	Materials of construction (contd.)	11.3 clapper:
	2. Area to be covered:		
			11.4 clapper facing:
	3. Hazard class:		11.5 handhole cover:
	4. Quality of water: raw water		11.6 clapper/ handhole gasket:
Construction features	5.		11.7
	6.		11.8
	7. Installation control valve:	12. Sprinkler:	
	7.1 size:		
	7.2 pressure at inlet:		
	7.3 end connection:		
			13.
	7.4 water motor gong		14.
		15.	
	8. Sprinkler:	Companion specifications	16. P&i diagram:
	8.1 standard:		
	8.2 type:		17. Ga drawing:
	8.3 nominal temperature rating:		18. Pump:
			19. Piping:
	9.		
	10.		20. Instruments:
	11. Installation control valve:		21. Control panel:
	11.1 body:		
			22.
11.2 seat ring:	23.		
	24.		
Tests and	25.	Approved sub-	33. Installation control valve:
			33.1
			33.2
			33.3

			33.4
	for installation controlvalve and sprinkler		33.5
	27.		34. Sprinkler:
	28.		34.1
	29.		34.2
	30.		34.3
	31.		34.4
	32.		34.5
<u>Notes</u>			
1.	Test connection at the remotest nozzle shall be provided.		
2.	Additional tests indicated as 'b' in shops inspection requirements shall also be carried out when it is applicable.		

2.14. LOW VOLTAGE INDUCTION MOTORS

2.14.1. DATA SHEET-B

1.0	Application			
2.0	Manufacturer			
3.0	Country of Origin			
4.0	Applicable Standards			
5.0	Efficiency Category(For Energy Efficient Motors only)			
6.0	Rated			
	(a)	Output	kW	
	(b)	Speed	RPM	
	(c)	Frame size		
7.0	Type of Duty (IS 325 or equivalent)			
8.0	(a)	Supply Conditions		
	i)	Rated Voltage	V	
	ii)	No. of Phases	No(s).	
	iii)	Frequency	Hz	

	(b)	Allowable Variations in		
		i)	Voltage	%
		ii)	Frequency	%
		iii)	Combined	%
9.0	Current			
	(a)	Full Load Amps		
	(b)	Starting		% FL
10.0	Method of Starting			
11.0	Insulation			
11.1	Class of Insulation			
11.2	Whether Tropicalised		Yes/No	
12.0	(a)	Ref. Ambient Temp.		deg.C
	(b)	Temp. rise of windings by Res. Method		
		i)	Stator	deg.C
		ii)	Rotor	deg.C
	(c)	Temp. rise of bearings		deg.C
13.0	Degree of Protection (IS 4691 or equivalent)			
14.0	Suitable for Outdoor Operation		Yes/No	
15.0	Normal winding connection		Star/Delta	
	(i)	Stator		
	(ii)	Rotor		
16.0	Space heater Rating Terminal box		Watts	
	(i)	Type & No. of Terminals brought Out		
	(ii)	Fault withstand capacity at rated voltage & duration		
	(iii)	Maximum size of Aluminium armoured cable that can be Terminated		cores X Sq mm

17.0	Dimensional Dwg. Enclosed	Yes/No	
18.0	Torque		
	a) Full load torque	kg-m	
	b) Starting torque	% FLT	
	c) Pull out Torque	% FLT	
	d) Pull up Torque	% FLT	
19.0	Efficiency (%)		
	a) Full Load Efficiency		
	b) 75% Load Efficiency		
	c) 50% Load Efficiency		
	d) 25% Load Efficiency		
20	LUBRICATION ARRANGEMENT		

2.14.2. Low voltage induction motors data sheet-c

- (a) Information to be submitted by the vendor
- (b) After award of contract
- (c) Technical particulars as per data sheet B of tender specification. (Based on motor manufacturer)
- (d) Type and frame size:
- (e) Starting time (Secs)
- (f) With 100% voltage at terminals
- (g) With minimum voltage at terminals (at ____ % Rated voltage)
- (h) With 110% voltage at terminals
- (i) Safe stall time at 100/110% rated voltage under hot/cold condition.
- (j) Type and size of cable for which gland is provided in the terminal box :
- (k) Type of bearings and expected life.
- (l) Total weight of motor (kg)
- (m) Weight of Stator (kg)
- (n) Weight of Rotor (kg)
- (o) Motor GD2:
- (p) Efficiency (%)
- (q) Full Load Efficiency
- (r) 75% Load Efficiency
- (s) 50% Load Efficiency

-
- (t) 25% Load Efficiency
 - (u) Power Factor
 - (v) Full Load Power Factor
 - (w) 75% Load Power Factor
 - (x) 50% Load Power Factor
 - (y) 25% Load Power Factor
 - (z) Torque (% FLT)
 - (aa) Starting
 - (bb) Maximum (Pullout torque)
 - (cc) Pull up torque
 - (dd) Type of Enclosure
 - (ee) Cooling designation
 - (ff) Space heaters
 - (gg) Rated voltage/number
 - (hh) Rating total
 - (ii) Separate terminal box provided
 - (jj) Motor reactances (Pu)
 - (kk) Sub transient reactance
 - (ll) Transient reactance
 - (mm) Steady state reactance
 - (nn) Guaranteed losses (kW)
 - (oo) Iron loss
 - (pp) Copper loss
 - (qq) Friction, Windage & Stray losses.
 - (rr) Motor outline dimension drawing (Number of copies as per distribution schedule)
 - (ss) Type test certificates (Number of copies as per distribution schedule)
 - (tt) Speed torque curve at rated & minimum starting voltage with Speed/Torque curve of the driven equipment superimposed.
 - (uu) Current - speed curve.
 - (vv) Current - time curve.
 - (ww) Efficiency, power factor, slip, current against output curve.
 - (xx) Thermal withstand characteristic for motors of 100 kW & above - Hot & Cold.

-
- (yy) Negative sequence current Vs time curve for motor of 100 kW & above.
- (zz) Rotor voltage/Rotor current (for wound motors).

TECHNICAL SPECIFICATION TO BE FILLED BY BIDDER

FOR

HVAC WORKS

3. DATA SHEET FOR HVAC WORKS

3.1. SPLIT AIR-CONDITIONERS DATA SHEET for BIDDER

SL. NO.	ITEM	UNIT	
1.0	GENERAL		
1.1	DESIGNATION		
1.2	NUMBERS REQUIRED	Nos.	
1.3	TAG NUMBERS		
1.4	REFRIGERANT USED		
1.5	STAR RATING (BEE)		
1.6	OPERATION		
2.0	DESIGN DATA		
2.1	REQUIRED MINIMUM ACTUAL CAPACITY REQUIRED	TR	
2.2	DESIGN OUTDOOR CONDITIONS		
2.2.1	DRY BULB TEMPERATURE	°C	
2.2.2	WET BULB TEMPERATURE	°C	
2.3	DESIGN INDOOR CONDITIONS		
2.3.1	DRY BULB TEMPERATURE	°C	
2.3.2	WET BULB TEMPERATURE	°C	
3.0	INDOOR UNIT		
3.1	TYPE		
3.2	REQUIRED DEHUMIDIFIED AIR FLOW CAPACITY OF EACH INDOOR UNIT		
3.3	FILTRATION		
3.3.1	ANTIDUST FILTERS (PRE-FILTERS)		
3.3.2	DEODORIZATION FILTERS		
3.3.3	ANTI-BACTERIA FILTERS		
3.4	ULTRAVIOLET SCREEN		
3.5	FAN TYPE		
3.6	FAN SPEED		
3.7	FAN MOTOR TYPE		
3.8	NOISE LEVEL @ 1.0 M FROM UNIT	dB(A)	

SL. NO.	ITEM	UNIT	
3.9	NO. OF UNITS / OUTDOOR		
3.10	RETURN GRILLE		
3.11	COOLING COIL		
3.12	FINS		
3.13	ANTI-CORROSIVE COATING ON COIL		
4.0	OUTDOOR UNIT		
4.1	COMPRESSOR		
4.2	VIBRATION ISOLATORS		
4.3	NOISE LEVEL @ 1.0 M FROM UNIT	dB(A)	
4.4	ANTI-CORROSIVE COATING ON BODY		
4.5	ANTI-CORROSIVE COATING ON COIL		
4.6	FAN TYPE		
4.7	FAN SPEED		
5.0	ELECTRICAL		
5.1	OUTDOOR MOTOR		
5.2	POWER SUPPLY		
5.3	POWER SUPPLY LOCATION		
5.4	MINIMUM CABLE LENGTH WITH PLUG & SOCKET	m	
6.0	INTERCONNECTED PIPING		
6.1	MAXIMUM PERMISSIBLE DISTANCE BETWEEN IDU AND ODU		
6.1.1	VERTICAL	m	
6.1.2	TOTAL	m	
6.2	INSULATED REFRIGERANT PIPING BETWEEN IDU AND ODU	m	
6.3	ACCESSORIES IN REFRIGERANT PIPING		
6.3.1	ECONOMIZER		
6.3.2	SIGHT GLASS		
6.4	INSULATED CONDENSATE DRAIN PIPING		
7.0	ACCESSORIES, AUXILIARIES AND SERVICES		

SL. NO.	ITEM	UNIT	
7.1	CORDLESS REMOTE CONTROLLER		
7.2	OCCUPANCY SENSOR IN IDU		
7.3	ON-OFF TIMER		
7.4	MOUNTING FRAME FOR IDU & ODU WITH ALL ACCESSORIES		
7.5	MOUNTING FRAME WITH EPOXY COATING		
7.6	SEQUENTIAL CONTROLLER		
8.0	SPARES AND MAINTENANCE TOOLS AND TACKLES		
8.1			
8.2	ESSENTIAL SPARES		
8.3	SPECIAL TOOLS		
9.0	PERFORMANCE GUARANTEES		
9.1	CAPACITY OF EACH SAC AT DESIGN CONDITION	TR	
9.2	TOTAL POWER INPUT AT DESIGN CONDITION	kW	
9.3	DEHUMIDIFIED AIR FLOW OF INDOOR UNIT	m ³ /hr	
9.4	NOISE LEVEL		
9.4.1	AT INDOOR UNIT @ 1.0 M	dB(A)	
9.4.2	AT OUTDOOR UNIT @ 1.0 M	dB(A)	
10.0	COST LOADING AND PENALTY		
10.1	FOR DIFFERENTIAL TOTAL POWER INPUT AT DESIGN CONDITIONS	Rs/kW	
11.0	TESTS AND INSPECTION		
11.1	AS PER STANDARD		

3.2. AIR-COOLED VARIABLE REFRIGERANT FLOW SYSTEM DATA SHEET for BIDDER:

1.0 Make	Dakin/ Bluestar/ Voltas
2.0 Casing	CS/ (CS/ CAST AL)/ EN8
3.0 Type: Ductable/ Cassete/ High wall	Ductable/Package Floor Mounted/ High wall
4.0 Dimension WxDxH (M)	Ducatble -
	Package Floor Mounted
	High wall
	VRF Table is given below
5.0 Cooling Capacity	
6.0 Air quantity at max. Speed	
And 1 m long duct collar CMH	
7.0 Air quantity at min. Speed	
And 1.0 m. Long duct collar CMH	
8.0 Whether auxiliary drain pan	
Provided: Yes/No.	Yes/No.
9.0 Make & model of room thermostat.	
10.0 Whether acoustic lined	Yes/No.
duct collar included in Unit price	Yes/No.
11.0 Does Indoor Unit have return air plenum. Yes/No.	Yes/No.
12.0 Noise Level at 1 m distance:	db
OUTDOOR	
1. Manufacturer	Dakin/ Bluestar/ Voltas
2. Type	
3. Model	
4. Overall dimensions (mm) WxDxH	
5. Operating Weight (kg.)	300
6. No. of fans	
7. CMH per fan	
8. Outlet velocity (Mts. Per min)	
9. Tip speed (Mts per min)	
10. Compressor Type	
11. Vibration isolator	Rubber pads
12. Noise Level at 1 m distance:	db

3.3. THERMAL INSULATION FOR COLD SURFACES DATA SHEET for BIDDER:

SL. NO.	ITEM		
1.	INSULATION MATERIALS		
1.1	EQUIPMENT		
1.2	PIPING SYSTEMS		
1.3	AIR-CONDITIONING DUCT		
2	INSULATION ADHESIVES		
3.	VAPOUR BARRIERS		
4.	FINISHING MATERIALS		
4.1	EQUIPMENT		
4.2	PIPING SYSTEMS		
4.3	AIR-CONDITIONING DUCT		
5.0	DENSITY OF EACH OF THE INSULATING MATERIALS	Kg/M ³	
6.0	IS ANY INSULATION MATERIAL CORROSIVE TO CARBON STEEL OR ALLOY STEEL SURFACE IN CONTACT		
7.0	INSULATION THICKNESSES FOR ALL INSULATION MATERIALS SELECTED, IN THE FORMAT SIMILAR TO THAT IN DATA SHEET A, TO BE ENCLOSED.		

3.4. PANEL TYPE AIR FILTERS:

SL. NO.	ITEM	UNIT	
1.	DESIGNATION		
2.	NUMBER OFFERED:		
3.	TAG NUMBERS:		
4.	MAKE AND MODEL NUMBER		
5.	PLACE OF MANUFACTURE		
6.	NORMAL CAPACITY AT SUCTION	M ³ /Hr	
	CONDITIONS		
7.	STATIC PRESSURE	mmW C	
8.	STATIC EFFICIENCY	%	
9.	MATERIALS OF CONSTRUCTION		
9.1	CASING		CS /GI WITH 220 GSM ON BOTH SIDES
9.2	IMPELLER		CS / CAST AL / PP / PPG / PAG
9.3	SHAFT		EN 8 /
10.	IMPELLER DIAMETER	mm	
11.	IMPELLER SPEED	RPM	
12.	POWER REQUIREMENT		
12.1.	POWER INPUT TO FAN AT DUTY POINT (BKW)	KW	
12.2	MAXIMUM POWER REQUIREMENT AT SELECTED SPEED	KW	
12.3	MOTOR RATING	KW	

SL. NO.	ITEM	UNIT	
12.4	POWER INPUT TO MOTOR AT DUTY POINT	KW	
13	WEIGHT OF FAN-MOTOR ASSEMBLY	Kg	
14.	NOISE LEVEL AT 1.5 M DISTANCE FROM FAN	dB(A)	
15.			
SL. NO.	ITEM	UNIT	
	DOCUMENTS TO BE ENCLOSED		WHETHER ENCLOSED
16	GENERAL ARRANGEMENT DRAWING WITH		YES / NO
	MAJOR DIMENSIONS		
17.	PARTS LIST WITH CODES AND MATERIALS		YES / NO
	OF CONSTRUCTION		
18.	RATING CHARTS OR TABLES WITH		YES / NO
	SELECTION MARKED		
19.	PERFORMANCE CURVE WITH DUTY POINT		YES / NO
	MARKED		
20.	FAN MOUNTING DETAILS WITH WALL		YES / NO
	OPENING REQUIREMENTS		
21.	RECOMMENDED SPARE PARTS LIST FOR		YES / NO
	2 YEARS NORMAL OPERATION		
	PERFORMANCE GUARANTEES		

SL. NO.	ITEM	UNIT	
22.	CAPACITY AT SUCTION CONDITIONS	M3/Hr	(+) (-)
23.	STATIC PRESSURE	mmW C	(+) (-)
24.	POWER CONSUMPTION	KW	(+) (-)

3.5. AIR WASHER DATA SHEET for BIDDER:

	SL. NO.	ITEM		
GENERAL	1.	DESIGNATION		AIR WASHER FOR
	2.	NUMBERS OFFERED		(W + S)
	3.	TAG NUMBERS		
	4.	MAKE, MODEL NUMBER AND PLACE OF		
		MANUFACTURE		
	5.	OVERALL SIZE L x B x H	mm	x x
	6.	EPOXY PAINTING OF CS MATERIALS		YES / NO
DESIGN DATA	7.	TYPE OF AIR WASHER		SPRAY TYPE / RIGID MEDIA PAD TYPE
	8.	AIR HANDLING CAPACITY	M ³ /Hr	
	9.	SATURATION EFFICIENCY	%	
	10.	MAXIMUM FACE AIR VELOCITY	M/Sec	
	11.	AIR SIDE PRESSURE DROP	mmW C	
	12.	RECIRCULATING WATER FLOW RATE	M ³ /Hr	
	13.	MAKE-UP WATER FLOW RATE	M ³ /Hr	
	14.	SPRAY TYPE		
	14.1	NUMBER OF SPRAY BANKS		
	14.2	NUMBER OF SPRAY NOZZLES PER SPRAY BANK		
	14.3	NUMBER OF FLOODING NOZZLES		
	14.4	CAPACITY OF EACH SPRAY NOZZLE	M ³ /Hr	
	14.5	CAPACITY OF EACH FLOODING NOZZLE	M ³ /Hr	
	14.6	PRESSURE DROP THROUGH SPRAY NOZZLE	Kg/cm ²	
	14.7	PRESSURE DROP THROUGH FLOODING		
		NOZZLE	Kg/cm ²	

	14.8	PRESSURE REQUIRED AT INLET OF SPRAY		
		HEADER	Kg/cm ² g	
	SL. NO.	ITEM		
DESIGN DATA (CONTINUED)	14.9	PRESSURE REQUIRED AT INLET OF		
		FLOODING NOZZLE HEADER	Kg/cm ² g	
	14.10	NUMBER OF SUCTION SCREENS		
	14.11	SIZE OF EACH SUCTION SCREEN L x B	mm	x
	15.	RIGID MEDIA PAD TYPE		
	15.1	DEPTH OF PAD	mm	
	15.2	OVERALL SIZE OF PAD L x B	mm	x
	15.3	METHOD OF CLEANING		
	15.4	FREQUENCY OF CLEANING	DAYS	
MATERIALS OF CONSTRUCTION	16.	TANK		
	17.	CATWALK		
	18.	AIR DISTRIBUTION PLATES		
	19.	SPRAY NOZZLES		
	20.	FLOODING NOZZLES		
	21.	INSPECTION DOOR		
	22.	ELIMINATOR PLATES		
	23.	SUCTION SCREEN		
	24.	PAD FOR RIGID MEDIA PAD TYPE		
ACCESSORIES		TO BE INCLUDED		YES / NO
	25.	MAKE-UP WITH FLOAT VALVE AND		
		QUICK-FILL CONNECTIONS WITH ISOLATING		YES / NO
		VALVE, ETC.		
	26.	DRAIN WITH ISOLATING VALVE AND		
		OVERFLOW CONNECTION, ETC.		YES / NO
	27.	MARINE LIGHTS		YES / NO
	28.	INSPECTION DOOR		YES / NO
	29.	SUPPORTING FRAME WORK FOR ITEMS AT		
		SL. NO. 16 TO 24 AND 27 ABOVE		YES / NO

	SL. NO.	ITEM		
		TO BE INCLUDED		YES / NO
	30.	WATER LEVEL SWITCH WITH ALARM AND INTERLOCKING WITH PUMP		YES / NO
	31.	ACCESS LADDERS WITH HANDRAILS AND MONKEY LADDERS		YES / NO
	32.	SUCTION SUMP COVER		YES / NO

3.6. AXIAL FANS FOR VENTILATION SYSTEM

SL. NO.	ITEM		
1.	DESIGNATION		
2.	NUMBER OFFERED		
3.	TAG NUMBERS		
4.	TYPE		
5.	MAKE AND MODEL NUMBER		
6.	PLACE OF MANUFACTURE		
7.	NORMAL CAPACITY AT SUCTION		
	CONDITIONS	M ³ /Hr	
8.	STATIC PRESSURE	Mm WC	
9.	STATIC EFFICIENCY	%	
10.	MATERIALS OF CONSTRUCTION		
10.1	CASING		
10.2	IMPELLER		
10.3	SHAFT		
11.	IMPELLER DIAMETER	mm	
12.	IMPELLER SPEED	RPM	
13.	POWER REQUIREMENT		
13.1	POWER INPUT TO FAN AT DUTY POINT (BKW)	KW	
13.2	MAXIMUM POWER REQUIREMENT AT		
	SELECTED SPEED	KW	
13.3	MOTOR RATING	KW	
13.4	POWER INPUT TO MOTOR AT DUTY POINT	KW	
14.	WEIGHT OF FAN-MOTOR ASSEMBLY	Kg	
15.	MINIMUM CAPACITY FOR STABLE		
	OPERATION	M ³ /Hr	

SL. NO.	ITEM		
16.	NOISE LEVEL AT 1.5 M DISTANCE FROM FAN	dB(A)	
	DOCUMENTS TO BE ENCLOSED		
17.	GENERAL ARRANGEMENT DRAWING WITH		
	MAJOR DIMENSIONS		
18.	PARTS LIST WITH CODES AND MATERIALS		
	OF CONSTRUCTION		
19.	RATING CHARTS OR TABLES WITH		
	SELECTION MARKED		
20.	PERFORMANCE CURVE WITH DUTY POINT		
	MARKED		
21.	FAN MOUNTING DETAILS WITH WALL		
	OPENING REQUIREMENTS		
22.	RECOMMENDED SPARE PARTS LIST FOR		
	2 YEARS NORMAL OPERATION		
	PERFORMANCE GUARANTEES		
23.	CAPACITY AT SUCTION CONDITIONS	M ³ /Hr	_____
24.	STATIC PRESSURE	Mm WC	
25.	POWER CONSUMPTION	KW	

3.7. AIR HANDLING UNIT

	SL. NO.	BIDDER ITEM	units	
GENERAL	1.	DESIGNATION		AIR HANDLING UNIT FOR
	2.	NUMBERS OFFERED		(W + S)
	3.	TAG NUMBERS		
	4.	TYPE		SINGLE SKIN/DOUBLE SKIN
				DRAW / BLOW THROUGH
	5.	MAKE, MODEL NUMBER AND PLACE OF MANUFACTURE		
	6.	MATERIAL AND GAUGE OF CASING		
	7.	OVERALL SIZE (L) x (W) x (H)	mm	x x
	8.	MINIMUM SERVICE SPACE REQUIRED ON ALL SIDES FOR MAINTENANCE	mm	
	9.	OPERATING WEIGHT	Kg	
	10.	TYPE OF VIBRATION ISOLATORS		
	11.	NOISE LEVEL AT 1.5 M DISTANCE	dB (A)	
	12.	MARINE LIGHTS		YES / NO
	13.	PAINTING OF FAN AND MS STRUCTURAL FRAME WORK		
FILTERS	14.	PRE-FILTERS		YES / NO
	14.1	MAKE AND MODEL NUMBER		
	14.2	NUMBER OF FILTERS		
	14.3	SIZE OF EACH FILTER (L) x (W) x (H)	mm	x x
	14.4	RATED CAPACITY OF EACH FILTER	M3/Hr	
	14.5	AIR FACE VELOCITY	M/Sec	

	14.6	FILTER MEDIA		
	14.7	EFFICIENCY	%	DOWN TO MICRONS
	14.8	PRESSURE DROP IN CLEAN CONDITION	mmWC	
FILTERS (CONTINUED)	14.9	PRESSURE DROP IN CLOGGED CONDITION	mmWC	
	15.	FINE FILTERS		YES / NO
	15.1	MAKE AND MODEL NUMBER		
	15.2	NUMBER OF FILTERS		
	15.3	SIZE OF EACH FILTER (L) x (W) x (H)	mm	x x
	15.4	RATED CAPACITY OF EACH FILTER	M3/Hr	
	15.5	AIR FACE VELOCITY	M/Sec	
	15.6	FILTER MEDIA		
	15.7	EFFICIENCY	%	DOWN TO MICRONS
	15.8	PRESSURE DROP IN CLEAN CONDITION	mmWC	
	15.9	PRESSURE DROP IN CLOGGED CONDITION	mmWC	
	16.	HEPA FILTERS		YES / NO
	16.1	MAKE AND MODEL NUMBER		
	16.2	NUMBER OF FILTERS		
	16.3	SIZE OF EACH FILTER (L) x (W) x (H)	mm	x x
	16.4	RATED CAPACITY OF EACH FILTER	M3/Hr	
	16.5	AIR FACE VELOCITY	M/Sec	
	16.6	FILTER MEDIA		
	16.7	EFFICIENCY	%	DOWN TO MICRONS
	16.8	PRESSURE DROP IN CLEAN CONDITION	mmWC	

	16.9	PRESSURE DROP IN CLOGGED CONDITION	mmWC	
COOLING COIL	17.	TYPE OF COIL		CHILLED WATER/BRINE/DX
	18.	COOLING CAPACITY	TR	
	19.	ENTERING AIR DRY BULB TEMPERATURE	OC	
	20.	ENTERING AIR WET BULB TEMPERATURE	OC	
	21.	LEAVING AIR DRY BULB TEMPERATURE	OC	
	22.	LEAVING AIR WET BULB TEMPERATURE	OC	
	23.	NUMBER OF ROWS DEEP	NOS.	
	24.	NUMBER OF FINS/CM	NOS.	
COOLING COIL (CONTINUED)	25.	AIR FACE VELOCITY	M/Sec	
	26.	FINNED COIL FACE AREA	M2	
	27.	TUBE OUTSIDE DIAMETER AND THICKNESS	mm	AND
	28.	CHILLED WATER/BRINE FLOW RATE	M3/Hr	
	29.	CHILLED WATER/BRINE INLET TEMPERATURE	OC	
	30.	CHILLED WATER/BRINE OUTLET TEMPERATURE	OC	
	31.	CHILLED WATER/BRINE PRESSURE DROP	Kg/cm2	
	32.	AIR SIDE PRESSURE DROP	mmWC	
	33.	REFRIGERANT TEMPERATURE FOR DX-COIL	OC	
	34.	TYPE		STEAM/HOT WATER/ ELECTRIC STRIP HEATERS WITH CONTROLS IN STEPS
	35.	HEATING CAPACITY	KW	
HEATING COIL	36.	NUMBER OF ROWS DEEP	NOS.	
	37.	NUMBER OF FINS/CM	NOS.	
	38.	AIR FACE VELOCITY	M/Sec	
	39.	FINNED COIL FACE AREA	M2	
	40.	TUBE OUTSIDE DIAMETER AND THICKNESS	mm	AND
	41.	AIR SIDE PRESSURE DROP	mmWC	

	42.	STEAM		
	42.1	STEAM FLOW RATE	Kg/Hr	
	42.2	STEAM INLET PRESSURE	Kg/cm2 g	
	43.	HOT WATER		
	43.1	HOT WATER FLOW RATE	M3/Hr	
	43.2	HOT WATER INLET TEMPERATURE	OC	
	43.3	HOT WATER OUTLET TEMPERATURE	OC	
	43.4	HOT WATER PRESSURE DROP	Kg/cm2	
COIL	44.	ELECTRIC STRIP HEATER		
	44.1	NUMBER OF STEPS		
	44.2	RATING OF EACH STEP	KW	
HUMIDIFIER	45.	TYPE		PAN / STEAM
	46.	PAN HUMIDIFIER		
	46.1	MAXIMUM WATER CONSUMPTION	M3/Hr	
	46.2	ELECTRICAL HEATER RATING	KW	
	47.	STEAM HUMIDIFIER		
	47.1	STEAM FLOW RATE	Kg/Hr	
	47.2	STEAM INLET PRESSURE AT CONTROL	Kg/cm2 g	
		VALVE		
FAN	48.	MAKE AND MODEL NUMBER		
	49.	TYPE		FORWARD CURVED / BACKWARD CURVED
	50.	CAPACITY	M3/Hr	
	51.	STATIC PRESSURE	mmWC	
	52.	DISCHARGE DIRECTION		HORIZONTAL / VERTICAL
	53.	IMPELLER SPEED	RPM	
	54.	FAN OUTLET AIR VELOCITY	M/Sec	
	55.	CLASS OF CONSTRUCTION		I / II / III
	56.	BRAKE POWER / LIMIT LOAD	KW	/
	57.	MOTOR RATING / SYNCHRONOUS SPEED	KW / RPM	/ /
	58.	POWER INPUT TO MOTOR AT DUTY POINT	KW	
	59.	VIBRATION ISOLATORS		
	59.1	MAKE AND MODEL NUMBER		

	59.2	VIBRATION DAMPENING EFFICIENCY	%	
	60.			
	61.			
MIXING BOX AND DAMPER	62.	MIXING BOX		YES / NO
	63.	FRESH AIR DAMPER		YES / NO
	64.	SIZE OF FRESH AIR DAMPER	mm	x
	65.	RETURN AIR DAMPER		YES / NO
	66.	SIZE OF RETURN AIR DAMPER	mm	x
	67.	TYPE OF FRESH AND RETURN AIR DAMPERS		MANUAL / ELECTRIC /
				PNEUMATIC
	68.	SUPPLY AIR DAMPER		YES / NO
	69.	SIZE OF SUPPLY AIR DAMPER	mm	x
	70.	TYPE OF SUPPLY AIR DAMPER		MANUAL / ELECTRIC /
				PNEUMATIC
MISCELLANEOUS		DOCUMENTS TO BE ENCLOSED		WHETHER ENCLOSED
	71.	SPARE PARTS LIST		YES / NO
	72.	PERFORMANCE CURVE AND RATING		
		CHARTS WITH OPERATING POINTS		
		MARKED FOR FILTERS, COOLING COIL,		YES / NO
		HEATING COIL AND FAN		
	73.	DETAILED DESCRIPTION AND DESIGN		
		PARAMETERS OF HUMIDIFIER PACKAGE		YES / NO

3.8. 3.8 CONDENSER UNIT

GENERAL	1.	DESIGNATION					
	2.	NUMBERS OFFERED		(W+S)			
	3.	TAG NUMBERS					
	4.	MAKE /MODEL NUMBER					
	5.	PLACE OF MANUFACTURE					
	6.	NOMINAL CAPACITY OF EACH CONDENSING					
		UNIT(CNU)	TR				
	7.	CAPACITY OF EACH CNU AT SPECIFIED DESIGN CONDITION	TR				
	8.	REFRIGERANT		R22 / R 134a			
	9.	OVERALL SIZE OF EACH CNU L x D x H	mm	x	x		
	10.	CLEARANCE REQUIRED ON ALL SIDES OF EACH CNU	mm	FRONT	BACK	SIDES	TOP
	11.	OPERATING WEIGHT	Kg				
	12.	NOISE LEVEL AT 1.86 M DISTANCE :					
	12.1	COMPRESSOR	dBA				
	12.2	CONDENSER FAN(IF AIR COOLED)	dBA				
COMPRESSOR	13.	NUMBER OF REFRIGERATION CIRCUITS/ CNU	Nos.				
	14.	TOTAL INPUT POWER AT SPECIFIED DESIGN					
		CONDITIONS PER CNU	kW				
	15.	TYPE OF VIBRATION ISOLATORS					
	16.	TYPE , MAKE AND MODEL NUMBER					
	17.	NUMBER OF COMPRESSORS PER CNU	Nos.				
COMPRESSOR (CONTD.)	18.	PLACE OF MANUFACTURE					
	19.	SUCTION TEMPERATURE	°C				
	20.	SUCTION PRESSURE	Kg/cm ₂ g				
	21.	CONDENSING TEMPERATURE	°C				

22.	CONDENSING PRESSURE	Kg/cm ₂ g	
23.	OPERATING SPEED AT SPECIFIED	RPM	

CONDENSER		DESIGN CONDITION			
	24.	CAPACITY AT SPECIFIED DESIGN CONDITION PER COMPRESSOR	TR		
	25.	BKW AT SPECIFIED DESIGN CONDITION PER COMPRESSOR	BKW		
	26.	MOTOR RATING PER COMPRESSOR	kW		
	27.	CAPACITY CONTROL AVAILABLE		YES / NO	
	28.	IN STEPS OF			
	29.	TYPE , MAKE AND MODEL NUMBER			
	30.	WATER COOLED CONDENSER			
	30.1	NUMBER OF CONDENSERS PER CNU	Nos.		
	30.2	HEAT REJECTION CAPACITY AT SPECIFIED DESIGN CONDITIONS PER CONDENSER	KCal/ Hr		
	30.3	TOTAL HEAT REJECTION CAPACITY AT SPECIFIED DESIGN CONDITIONS PER CNU	KCal/ Hr		
	30.4	CONDENSER COOLING WATER FOULING FACTOR	HR.SQ FT ⁰ F/ BTU		
	30.5	COOLING WATER FLOW RATE/ CONDENSER	M ³ /Hr		
	30.6	COOLING WATER INLET TEMPERATURE	°C		
	30.7	COOLING WATER OUTLET TEMPERATURE	°C		
	30.8	WATER VELOCITY IN TUBES	M/Sec		
	30.9	WATER SIDE PRESSURE DROP	Kg/cm ₂		
	31.	AIR COOLED CONDENSER			
	31.1	NUMBER OF CONDENSERS PER CNU	Nos.		
	31.2	HEAT REJECTION CAPACITY AT SPECIFIED	KCal/ Hr		
		DESIGN CONDITIONS PER CONDENSER			
	31.3	TOTAL HEAT REJECTION CAPACITY AT SPECIFIED DESIGN CONDITIONS PER CNU	KCal/ Hr		
	31.4	MAXIMUM PERMISSIBLE DISTANCE BETWEEN CNU AND INDOOR UNIT	M	VERTICAL	TOTAL
	31.5	CONDENSER FANS			
	31.5.1	NUMBERS IN EACH CONDENSER			
	31.5.2	CAPACITY OF EACH FAN	M ³ /Hr		

	31.5.3	STATIC PRESSURE	mmW C	
	31.5.4	IMPELLER MATERIAL		
	31.5.5	BRAKE POWER OF EACH FAN	kW	
	31.5.6	INPUT POWER OF EACH FAN	kW	
	31.5.7	MOTOR RATING OF EACH FAN	kW	
MAKE OF ACCESSORIES	32.	HIGH AND LOW PRESSURE CUT OUTS		
	33.	THERMOSTAT		
	34.	SOLENIOD VALVE		
	35.	SINGLE PHASE PREVENTOR		
	36.	STARTERS		
	37.	VIBRATION ISOLATORS		
	38.	CONTROL PANEL		
PERFORMANCE GUARANTEE	39.	CAPACITY OF EACH CNU AT DESIGN CONDITIONS	TR	
	40.	TOTAL POWER INPUT AT DESIGN CONDITIONS	kW	
	41.	NOISE LEVEL AT 1.86 M DISTANCE FROM CNU	dBA	
GENERAL	42.	CONFIRM THAT UNITS CAN BE INSTALLED,		
		OPERATED AND SERVICED IN AVAILABLE		
		PLANT ROOM SPACE		YES/NO
	43.	CONFIRM THAT UNITS ARE SUITABLE FOR		
		SPECIFICIED VOLTAGE AND FREQUENCY		YES/NO
	44.	PERFORMANCE CURVE/RATING CHARTS		
		ENCLOSED.		YES/NO

TECHNICAL SPECIFICATION TO BE FILLED BY BIDDER

FOR

COMPRESSED AIR WORKS

4. DATA SHEET FOR COMPRESSED AIR WORKS

4.1. DATA SHEET B :AIR COMPRESSOR

TO BE FILLED BY BIDDER

	SL. NO.	CONTRACTOR ITEM				
GENERAL	1.	DESIGNATION		COMPRESSORS FOR		
	2.	NUMBER OFFERED		(W+S)		
	3.	TAG NUMBERS				
	4.	TYPE OF COMPRESSOR		RECIPROCATING/CENTRIFUGAL/SCREW		
				LUBRICATED / NON-LUBRICATED		
	5.	MAKE AND MODEL NUMBER				
	6.					
	7.					
				RECIP	CENT	SCREW
	8.	NUMBER OF STAGES				
COMPRESSOR DATA	9.	NUMBER OF CYLINDERS PER			NA	NA
		STAGE				
	10.	TYPE OF CYLINDER		VER / HOR	NA	NA
	11.	CYLINDER LINER PROVIDED		YES / NO	NA	NA
	12.	SINGLE ACTING /DOUBLE		SINGLE/		
		ACTING		DOUBLE	NA	NA
	13.	CAPACITY (FAD)	M ³ / Hr			
	14.	MASS FLOW RATE	Kg/Hr	NA		NA
	15.	TYPE OF SUCTION AND		PLATE /	IGV/	BUTTERFLY
		DISCAHRGE VALVE		CHANNE L	BUTTERFL Y	/ PISTON
				TYPE	VALVE (OP)	VALVE (OP)
					AT SUCTION	AT SUCTION
	16	SUCTION PRESSURE	Kg/cm ² (g)			
	17.	DISCHARGE PRESSURE	Kg/cm ² (g)			
		LEGEND : RECIP = RECIPROCATING, CENT= CENTRIFUGAL, VER = VERTICAL,				

		HOR = HORIZONTAL,IGV = INLET GUIDE VANES, OP = OPTIONAL, NA = NOT APPLICABLE

	SL. NO.	CONTRACTOR ITEM				
				RECIP	CENT	SCREW
COMPRESSORS DATA (CONTD.)	18.	SUCTION TEMPERATURE -				
		EACH STAGE	⁰ C			
	19.	DISCHARGE TEMPERATURE -				
		EACH STAGE	⁰ C			
	20.	SELECTED COMPRESSOR SPEED	RPM			
	21.	BKW AT SELECTED COMPRESSOR				
		SPEED	KW			
	22.	RECOMMENDED MAXIMUM				
		SPEED	RPM			
	23.	BKW AT RECOMMENDED				
		MAXIMUM SPEED	KW			
	24.	VOLUMETRIC EFFICIENCY	%			
	25.	MECHANICAL EFFICIENCY	%			
	26.	MOTOR RATING AND SPEED	KW/RP M	/	/	/
	27.	LUBE OIL CONSUMPTION				
		FOR EACH COMPRESSOR	LPM			
	28.	LUBE OIL PUMP DRIVEN BY				
		COMPRESSOR MOTOR		YES/ NO	YES/ NO	YES/ NO
	29.	MOTOR RATING, IF LUBE OIL				
		PUMP IS DRIVEN BY SEPARATE	KW			
		MOTOR				
	30.	AUXILIARY LUBE OIL PUMP		WHETHER PROVIDED		
		TO BE PROVIDED			YES/ NO	
	31.	AUXILIARY LUBE OIL PUMP		/	/	/
		MOTOR RATING AND SPEED	KW/RP M			
	32.	TYPE AND MAKE OF BEARINGS				
	33.	COOLING WATER				

		REQUIREMENTS (NOTE 1)				
33.1		FOR COMPRESSOR COOLING				
33.1.1		FLOW RATE	M ³ / Hr			
33.1.2		INLET AND MINIMUM OUTLET		/	/	/
		PRESSURE	Kg/cm ² (g)			
33.1.3		INLET AND MAXIMUM OUTLET		/	/	/
		TEMPERATURE	⁰ C			
33.2		FOR BEARING COOLING - IF REQUIRED				
33.2.1		FLOW RATE	M ³ / Hr			
33.2.2		INLET AND MINIMUM OUTLET		/	/	/
		PRESSURE	Kg/cm ² (g)			
33.2.3		INLET AND MAXIMUM OUTLET		/	/	/
		TEMPERATURE	⁰ C			
33.2.4						
33.2.5						
34.		INTAKE FILTER TYPE				
34.1		FILTER ELEMENT				
34.2		RATED CAPACITY	M ³ / Hr			
34.3		EFFICIENCY	%			
34.4		DESCRIPTIVE LITERATURE TO BE ENCLOSED		WHETHER ENCLOSED		
					YES/ NO	
34.5						
35.		CAPACITY CONTROL				
35.1		TYPE AND NUMBER OF STEPS		BY SPEED VARIATION / AT CONSTANT SPEED AND		
35.2		METHOD EMPLOYED IN CASE OF CONSTANT SPEED TYPE				
35.3		CONTROL SYSTEM WRITE-UP TO		WHETHER ENCLOSED		
		BE ENCLOSED		YES/ NO		
35.4		WIRING AND TUBING DIAGRAM		WHETHER ENCLOSED		
		WITH CONTROL SCHEME TO BE		YES / NO		

		ENCLOSED				
	36.	EQUIPMENT AND ACCESSORIES				
		MOUNTED ON COMMON BASE				
		FRAME WITH THE COMPRESSOR				
	36.1	WEIGHT OF ENTIRE UNIT MOUNTED				
		ON COMMON BASE FRAME	Kg			
	36.2	OVERALL DIMENSIONS OF		X	X	X
		COMMON BASE FRAME L X W	M			
	37.	EQUIPMENT AND ACCESSORIES				
		MOUNTED ON SEPARATE BASE				
		FRAME				
	37.1	WEIGHT OF EQUIPMENT AND ACCESSORIES MOUNTED ON SEPARATE BASE FRAME	Kg			
	37.2	OVERALL DIMENSIONS OF		X	X	X
		SEPARATE BASE FRAME L X W	M			
	38.	NAME AND OVERALL DIMENSIONS OF SINGLE LARGEST COMPONENT TO BE LIFTED L X W X H	M	X	X	X
	39.	NAME AND WEIGHT OF HEAVIEST SINGLE COMPONENT TO BE LIFTED	Kg			
INTER-COOLERS / AFTER-				RECIP	CENT	SCREW
	40.	SUCTION FLANGE - FIRST STAGE SIZE/ STANDARD/ RATING	mm NB/			
	41.	DISCHARGE FLANGE - FINAL STAGE - SIZE/ STANDARD/ RATING	mm NB/			
	42.	IF DRIVE MOTOR IS TO BE FURNISHED BY THE PURCHASER				
	42.1	RATING/ SPEED	KW/RP M			
	42.2	STARTING TORQUE	Kg M			

42.3	DIRECTION OF ROTATION OF MOTOR AS VIEWED FROM COUPLING END		/	/	/	
43.	ALL THE ACCESSORIES AS CALLED FOR IN DATA SHEET A TO BE INCLUDED		WHETHER INCLUDED YES / NO			
44.			I/C			A/C
			1 STG	2 STG	3 STG	
45.	DESIGNATION					
46.	NUMBER OFFERED					
47.	TAG NUMBERS					
48.	TYPE		VER/ HOR			VER/HOR
49.	CAPACITY (FAD)	M ³ /Hr				
50.	COOLING WATER FLOW RATE	M ³ / Hr				
51.	AIR/ GAS INLET/OUTLET TEMPERATURE	⁰ C	/	/	/	/
52.	COOLING WATER INLET/ MAXI-MUM OUTLET TEMPERATURE	⁰ C	/	/	/	/
			I/C			A/C
53.	AIR/ GAS INLET AND OUTLET PRESSURE	Kg/cm ² (g)	/	/	/	/
54.	COOLING WATER INLET/ MINIMUM OUTLET PRESSURE	Kg/cm ² (g)	/	/	/	/
55.	COOLING SURFACE AREA	M ²				
56.	DESIGN PRESSURE - AIR/ GAS SIDE	Kg/cm ² (g)				
57.	DESIGN PRESSURE - WATER SIDE	Kg/cm ² (g)				
58.	CODE OF CONSTRUCTION					
59.	CORROSION ALLOWANCE	mm	3	3	3	3
60.	NUMBER OF PASSES					
61.	EMPTY WEIGHT	Kg				
62.	OPERATING WEIGHT	Kg				
63.	WATER FILLED WEIGHT	Kg				

RECEIVERS	64.	ALL THE ACCESSORIES		WHETHER INCLUDED		
		AS CALLED FOR IN DATA SHEET A				
		TO BE INCLUDED		YES / NO		
	65.	DESIGNATION		RECEIVERS FOR		
	66.	NUMBER OFFERED				
	67.	TAG NUMBERS				
	68.	TYPE		VER/ HOR	VER/ HOR	VER/ HOR
	69.	CAPACITY	M ³			
	70.	SIZE				
	70.1	DIAMETER	mm			
	70.2	HEIGHT TAN TO TAN	mm			
	71.	DESIGN PRESSURE	Kg/cm ² (g)			
RECEIVERS (CONTD.)	72.	CODE OF CONSTRUCTION				
	73.	CORROSION ALLOWANCE	mm			
	74.	THICKNESS				
	74.1	SHELL	mm			
	74.2	DISHED ENDS	mm			
	75.	WEIGHT				
	75.1	EMPTY	Kg			
	75.2	OPERATING	Kg			
	75.3	FILLED WITH WATER	Kg			
	76.	ALL THE ACCESSORIES AS CALLED		WHETHER INCLUDED YES / NO		
		FOR IN DATA SHEET A TO BE				
		INCLUDED				
MISCELLANEOUS	77.	ALL THE VALVES, SPECIALITIES,		WHETHER INCLUDED YES / NO		
		INSTRUMENTS, COUNTER FLANGES,				
		FOUNDATION BOLTS ETC. AS CALLED FOR IN DATA SHEET A AND				
		AS PER ENCLOSED P & I D TO BE		YES / NO		
		INCLUDED				
PERFORMANCE GUARANTEES	78.	CAPACITY OF COMPRESSOR	M ³ / Hr	(+)	(-)	
	79.	DISCHARGE PRESSURE	Kg/cm ² (g)	(+)	(-)	
	80.	POWER CONSUMPTION	KW	(+)	(-)	
	81.	TEMPERATURE OF AIR AT OUTLET OF AFTER-COOLER	⁰ C	(+)	(-)	
	82.	COOLING WATER FLOW RATE	M ³ / Hr	(+)	(-)	

	83.	COOLING WATER OUTLET TEMP.	⁰ C	(+)	(-)
	84.	COOLING WATER PRESSURE DROP	Kg/cm ² (g)	(+)	(-)
	85.				
	Notes 1. IF AIR COOLED COMPRESSOR IS OFFERED, CONTRACTOR TO FURNISH COOLING SYSTEM DETAILS LIKE NATURAL OR FORCED COOLING, FAN CAPACITY, MOTOR RATING ETC. LEGEND : I/C = INTER-COOLER, A/C = AFTER-COOLER, STG = STAGE				
	<u>NOTES TO CONTRACTOR</u> 1. DATA SPECIFIED IN DATA SHEET-A HAS NOT BEEN REPRODUCED IN DATA SHEET-B. IN CASE OF DEPARTURE FROM DATA SHEET-A, CONTRACTOR SHALL BRING OUT THE SAME IN SCHEDULE OF DEVIATIONS, FAILING WHICH IT SHALL BE CONSTRUED THAT CONTRACTOR COMPLIES WITH THE REQUIREMENTS STIPULATED IN DATA SHEET-A. 2. THIS DATA SHEET SHALL BE FILLED UP COMPLETELY AND A COPY SHALL BE ENCLOSED WITH EACH COPY OF THE BID.		SIGNATURE OF CONTRACTOR DATE		

4.2. DATA SHEET C : AIR COMPRESSOR

DATA TO BE FURNISHED BY THE CONTRACTOR AFTER THE

AWARD OF CONTRACT

1. List of drawings and documents to be submitted for review, approval and information with scheduled submission dates
2. Quality Assurance Plan (QAP)
3. Calculations for compressor capacity, drive motor rating, selection of speed reducers and couplings. Torsional vibration analysis for centrifugal and screw compressors
4. Thermal design calculations for inter-coolers, after-coolers and oil-coolers
5. Detailed P&I diagram showing clearly the scope of supply of equipment, piping with line sizes and material specifications, valves, specialties, instrumentation and control and all the accessories. All equipment, lines, valves, specialties and instruments shall be tagged as per the PURCHASER's procedure to be given to the successful CONTRACTOR. All terminal points shall be clearly identified. All design data and

other information furnished in data sheets A and B shall be covered either in this drawing or other relevant drawings or documents mentioned below.

6. Detailed equipment list and bill of materials of all items in the CONTRACTOR's scope
7. Sub-vendor list for all bought-out items
8. Mechanical design calculations for inter-coolers, after-coolers, oil-coolers, moisture and oil separator and receivers
9. Characteristic curves of compressors. For centrifugal compressors, in addition to curves for operating conditions, characteristic curves shall be submitted considering minimum and maximum ambient temperature, minimum and maximum humidity and minimum and maximum frequency conditions
10. Dimensioned to-scale equipment layout drawing showing all equipment, accessories, relevant external dimensions, location and elevation of terminal points, details of piping and electrical connections to be made by the PURCHASER, clearances required for erection, dismantling, operation and maintenance
11. Dimensioned cross-section drawings of compressors and other proprietary items with part list and materials of construction
12. Detailed fabrication drawings of all fabricated equipment like inter-coolers, after-coolers, air receivers etc.
13. Line designation schedule for all lines in the CONTRACTOR'S scope
14. List of valves, specialities and instruments in the CONTRACTOR'S scope with tag numbers, type, makes, pressure ratings, materials of construction and ranges for instruments etc.
15. Manufacturer's drawings, data sheets and catalogues for valves, specialities and instruments etc.
16. Dimensioned to-scale piping layout drawing for piping in the CONTRACTOR's scope with allowable forces and moments on the piping nozzles and displacement of the nozzles
17. Overall foundation plan, base frame drawing for each equipment, static and dynamic loads on each of the anchor bolts and dimensional details of pockets and anchor bolts
18. Motor drawings
19. Electrical control wiring diagrams with all interlocks
20. Control philosophy, interlock description and logic diagrams

21. Dimensional to-scale general arrangement and section drawings of MCC and instrument control panel with complete bill of materials
22. List of alarms and trip settings
23. Erection, start-up, operation and maintenance manual complete with lubrication schedule etc.

4.3. DATA SHEET B– AIR DRYING PLANT (REFRIGERATED TYPE)

SL. NO.	ITEM	UNIT	SPECIFICATION
1.0	GENERAL		
1.1	DESIGNATION		AIR DRYING PLANT FOR
1.2	NUMBER REQUIRED		
1.3	TAG NUMBERS		
1.4	OPERATION	Hrs/D AY	CONTINUOUS / INTERMITTENT
1.5	LOCATION		INDOOR / OUTDOOR
1.6	INLET AIR QUALITY		OIL FREE OR OIL CONTAMINATED COMPRESSED AIR
1.7	APPLICABLE CODE		IS 11989 / ISO-8573-1 (2.4.7.1)
2.0	DESIGN DATA		
2.1	DESIGN CAPACITY (FAD)	M ³ /H r	
2.2	OPERATING PRESSURE	Kg/c m ² (g)	
2.3	DESIGN PRESSURE	Kg/c m ² (g)	

SL. NO.	ITEM	UNIT	SPECIFICATION
2.4	MAXIMUM ALLOWABLE PRESSURE DROP ACROSS AIR DRYING PLANT	Kg/c m ²	0.5
2.5	AIR INLET TEMPERATURE	°C	
2.6	AIR OUTLET TEMPERATURE	°C	
2.7	OUTLET AIR DEW POINT (NOTE 1)		
2.7.1	AT ATMOSPHERIC PRESSURE	°C	(-) 15
2.7.2	AT OPERATING PRESSURE	°C	(+) 3
2.8	QUALITY OF COOLING WATER (CW)		
2.9	CW INLET TEMPERATURE		
2.10	MAXIMUM ALLOWABLE CW OUTLET TEMPERATURE	°C	
SL. NO.	ITEM	UNIT	
2.11	CW INLET PRESURE	Kg/c m ² (g)	
2.12	MAXIMUM ALLOWABLE CW PRESSURE DROP	Kg/c m ²	
2.13	CONTROL POWER SUPPLY	V	
2.14	P&I DIAGRAM NO.		
2.15	PIPING		REFER PIPING MATERIAL SPECIFICATION (PMS)
2.16	TYPE OF REFRIGERANT		R407C, R410A, R134
3.0	AIR-TO-AIR HEAT EXCHANGER		
3.1	DESIGN CODES		ASME SEC VIII DIV 1 AND TEMA C
3.2	CORROSION ALLOWANCE	mm	1.5

SL. NO.	ITEM	UNIT	SPECIFICATION
3.3	SHELL		SA 106 GR B / IS 2002 GR 2
3.4	TUBES		COPPER/ADMIRALITY BRASS AS PER BS EN 1057(NOTE 2)
3.5	TUBE SHEET		IS 2002 GR 2 / SA 105
3.6	BAFFLE PLATES		IS 2062 GR B / IS 2002 GR 2
3.7	MOISTURE SEPARATOR		
			CENTRIFUGAL TYPE WITH DEMISTER PAD AND AUTOMATIC DRAIN TRAP
4.0	CONTROLS (NOTE 3)		
4.1	CONTROL SIGNAL LAMPS FOR POWER, CONTROL SUPPLY ON		REQUIRED
4.2	SWITCHES/PUSH BUTTONS FOR		
4.2.1	COMPRESSOR ON / OFF		REQUIRED
4.2.2	ACKNOWLEDGE/RESET/ TEST		REQUIRED
4.2.3	AUTO/MANUAL CHANGEOVER SELECTOR SWITCH		REQUIRED
4.3	ANNUNCIATION SYSTEM		REQUIRED
5.0	MISCELLANEOUS		
5.1	BY PASS ARRANGEMENT FOR THE PLANT REQUIRED		YES / NO
5.2	ALL THE VALVES, SPECIALITIES, INSTRUMENTS AND ACCESSORIES AS PER ENCLOSED P&ID		REQUIRED
5.3	COUNTER FLANGES FOR ALL THE CONNECTIONS AT BATTERY LIMITS WITH NUTS, STUDS BOLTS, GASKETS AND WASHERS		YES / NO

SL. NO.	ITEM	UNIT	SPECIFICATION
	REQUIRED		
5.4	FLANGES		AS PER ANSI B16.5
5.5	FOUNDATION BOLTS REQUIRED		YES / NO
5.6	ERECTION BY CONTRACTOR		YES / NO
5.7	ERECTION SUPERVISION BY CONTRACTOR		YES / NO
6.0	PAINTING		
6.1	PRIMER		RED OXIDE/ EPOXY
6.1.1	NUMBER OF COATS		
6.1.2	DRY FILM THICKNESS PER COAT	μ	
6.2	FINISH PAINT		SYNTHETIC ENAMEL / EPOXY /
	NUMBER OF COATS		
	DRY FILM THICKNESS PER COAT	μ	
7.0	COMPANION SPECIFICATIONS		
7.1	INSULATION		
8.0	SPARES AND MAINTENANCE TOOLS AND TACKLES		
8.1			
8.2	ESSENTIAL SPARES		
9.0	TESTS AND INSPECTION		
9.1			
9.2			
10.0	PERFORMANCE GUARANTEES		
10.1	DESIGN CAPACITY (FAD)		

SL. NO.	ITEM	UNIT	SPECIFICATION
		M3/H r	(+)
		M3/H r	(-) 0.00
10.2	OUTLET AIR DEW POINT AT ATMOSPHERIC		
	PRESSURE	°C	(+) 0.00
		°C	(-)
10.3	PRESSURE DEW POINT AT OUTLET		
		°C	(+) 0.00
		°C	(-)
10.4	AIR PRESSURE DROP ACROSS THE PLANT		
		Kg/c m ²	(+) 0.00
		Kg/c m ²	(-)
10.5	TOTAL POWER CONSUMPTION PER CYCLE		
		KW	(+) 0.00
		KW	(-)
11.0	COST LOADING AND PENALTY		
11.1	TOTAL POWER CONSUMPTION / CYCLE	Rs.	/ KW

4.4. WELDED UNFIRED PRESSURE VESSEL DATA SHEET C :

DATA TO BE FURNISHED BY THE VENDOR AFTER THE ISSUE OF PURCHASE ORDER

1. Schedule of complete design calculations, drawings and documents to be submitted along with submission dates
2. Quality Assurance Plan (QAP)
3. Complete design calculations
4. General arrangement drawing indicating overall dimensions, complete design data, general notes, BOM, specifications of each of the pressure and non-pressure parts, nozzle schedule with nozzle tag number, service, size, nozzle wall thickness, complete end connection details, nozzle elevations, locations, and orientation, support details, locations and orientation etc. Operating weight, erection weight and weight filled with water shall be indicated.
5. Detailed fabrication drawing for each part and welding details
6. Details of internals
7. Details of external cleats and structurals
8. Welding procedure

4.5. MOTOR DATASHEETS B :

TO BE FILLED BY BIDDER

1.	Application/Designation		
2.	Manufacturer		
3.	Applicable standards		
4.	Country of Origin		
5.	Efficiency Category(For Energy Efficient Motors only)		
6.	Rated		
	a) Output	KW	
	b) Speed	RPM	
	c) Frame size		
7.	Type of Duty (CI.10.2 of IS 325 OR CL-9.3 OF IS 4722)		
8.	Supply conditions		

	a) 1) Rated voltage	V	
	2) No. of phases		
	3) Frequency	Hz	
	b) Allowable Variations in		
	1) Voltage	%	
	2) Frequency	%	
	3) Combined	%	
	c) Permissible Unbalance in Supply Voltage	%	
9.	Current		
	a) Full Load	Amps	
	b) Starting	% FL	
10.	Method of Starting		
11.	Insulation		
11.1	Class of Insulation		
11.2	Whether Tropicalised	Yes/ No	
12.	a) Reference ambient Temperature		
	b) Temp. rise by res. Method		
	Stator	⁰ C	
	Rotor	⁰ C	
	c) Temp. rise of bearing	⁰ C	
13.	Type of bearing Lubricating Grease / Oil		
14.	Facility for On line Greasing of bearing for motors above 15kW		
15.	Degree of Protection(IS 4691 or equivalent)		
16.	Suitable for Outdoor Operation		Yes/No
17.	Normal winding connection		Star/Delta
18.	Space Heater rating	Watt	
19.	Noise level	db	
20.	(i) Type & No. of Terminals brought Out		
	(ii) Fault withstand capacity at rated voltage & duration		
	iii) Maximum size of Aluminium armoured cable that can be Terminated	cores X Sq	

		mm	
21.	Dimensional Dwg. Enclosed		
22.	Torque		
22.1	Full Load	Kg-m	
22.2	Starting torque	%FL T	
22.3	Pull out Torque	%FL T	
22.4	Pull up Torque	%FL T	

INFORMATION TO BE SUBMITTED BY THE CONTRACTOR

AFTER AWARD OF CONTRACT

- 1.0 Technical particulars as per data sheet B of tender specification. (Based on motor manufacturer)
- 2.0 Type and frame size :
- 3.0 Starting time (Secs)
- 3.1 With 100% voltage at terminals
- 3.2 With minimum voltage at terminals (at ____ % Rated voltage)
- 3.3 With 110% voltage at terminals
- 4.0 Safe stall time at 100/110% rated voltage under hot/cold condition.
- 5.0 Type and size of cable for which gland is provided in the terminal box :
- 6.0 Type of bearings and expected life.
- 7.0 Total weight of motor (kg)
- 7.1 Weight of Stator (kg)
- 7.2 Weight of Rotor (kg)
- 8.0 Motor GD^2 :
- 9.0 Efficiency (%)
- 9.1 Full Load Efficiency
- 9.2 75% Load Efficiency
- 9.3 50% Load Efficiency
- 9.4 25% Load Efficiency
- 10.0 Power Factor
- 10.1 Full Load Power Factor
- 10.2 75% Load Power Factor
- 10.3 50% Load Power Factor
- 10.4 25% Load Power Factor
- 11.0 Torque (% FLT)
- 11.1 Starting

11.2	Maximum (Pullout torque)
11.3	Pull up torque
12.0	Type of Enclosure
13.0	Cooling designation
14.0	Space heaters
14.1	Rated voltage/number
14.2	Rating total
14.3	Separate terminal box provided
15.0	Motor reactances (Pu)
15.1	Subtransient reactance
15.2	Transient reactance
15.3	Steady state reactance
16.0	Guaranteed losses (kW)
16.1	Iron loss
16.2	Copper loss
16.3	Friction, Windage & Stray losses.
17.0	Motor outline dimension drawing (Number of copies as per distribution schedule)
18.0	Type test certificates (Number of copies as per distribution schedule)
19.0	Speed torque curve at rated & minimum starting voltage.
20.0	Current - speed curve.
21.0	Current - time curve.
22.0	Efficiency, power factor, slip, current against output curve.
23.0	Thermal withstand characteristic for motors of 100 kW & above - Hot & Cold.
24.0	Negative sequence current Vs time curve for motor of 100 kW & above.
25.0	Rotor voltage/Rotor current (for wound motors).

TECHNICAL SPECIFICATIONS – BIDDER TO FILL

FOR

ELECTRICAL SYSTEM

5. DATA SHEET FOR ELECTRICAL

DATA SHEET A1 - TECHNICAL REQUIREMENTS

DATA SHEET A2 - CODAL REQUIREMENTS

DATA SHEET B - TO BE FILLED BY BIDDER

5.1. DATA SHEET A1 HIGH VOLTAGE METAL ENCLOSED SWITCHGEAR

SL. NO.		ITEM	UNIT	TECHNICAL PARTICULARS
1.0 SWITCHGEAR RATINGS	1.1	NOMINAL SYSTEM VOLTAGE PHASES & FREQUENCY	VOLTS, PH, HZ	33000V, 3Ph, 50Hz
	1.2	SYSTEM NEUTRAL EARTHING		EFFECTIVELY EARTHED
	1.3	MAXIMUM SYSTEM VOLTAGE	VOLTS	36000V
	1.4	POWER FREQUENCY WITHSTAND VOLTAGE	kV (rms), 1 min	70
	1.5	1.2/50 μ SEC. IMPULSE WITHSTAND VOLTAGE	kV (peak),	170
	1.6	SHORT CIRCUIT WITHSTAND		
	1.6.1	SHORT TIME (1 SEC.) AT RATED VOLTAGE	kA (rms)	25kA for 1 sec
	1.6.2	SHORT TIME (3 SEC.) AT RATED VOLTAGE	kA (rms)	--
	1.6.3	DYNAMIC RATING	kA (peak	62.5kA
	1.7	REFERENCE SITE AMBIENT TEMPERATURE		<input type="checkbox"/> 40 ⁰ C <input type="checkbox"/> 45 ⁰ C <input checked="" type="checkbox"/> 50 ⁰ C
	1.8	CONTINUOUS CURRENT RATING OF BUS BARS UNDER REFERENCE SITE AMBIENT TEMP.		REFER. SR. NO. 2.0 BELOW
	1.9	MAXIMUM TEMPERATURE OF BUS BARS AND DROPPERS/CONNECTORS UNDER CONDITIONS SPECIFIED – SR. NOS. 1.7 and 1.8 ABOVE		90 ⁰ C FOR BUSBARS HAVING NON-SILVER PLATED JOINTS 105 ⁰ C FOR BUSBARS HAVING SILVER PLATED JOINTS

SL. NO.		ITEM		UNIT		TECHNICAL PARTICULARS	
2.0 SWITCHGEAR RATINGS	SR. NO.		BUS BARS COPPER (TINNED) ALUMINIUM	CABLE ENTRY		TOTAL NO. OF CUBICLES PER SWITCHGEAR	REMARKS (DIMENSIONAL LIMITS IF ANY)
			AMPS.	TOP	BOTTOM		
	2.1	HT PANEL-3 VCB SWITCHGEAR	630, ALUMINIUM		BOTTOM	03	HEIGHT < / = 2.3 M INCLUDING BASE FRAME
SWITCHGEAR CONSTRUCTIONAL REQUIREMENTS	3.1	CLEARANCE IN AIR PHASE TO PHASE		mm		320	
	3.2	BUS BAR INSULATION		–		<input type="checkbox"/> HEAT SHRUNK <input checked="" type="checkbox"/> HR – PVC <input type="checkbox"/> ENCAPSULATED <input type="checkbox"/> BARE	
	3.3	DEGREE OF PROTECTION		–		- IP 4X: ENCLOSURE - IP 2X: PARTITION BETWEEN COMPARTMENTS	
	3.4	BUS DUCT CONNECTION		–		<input type="checkbox"/> REQUIRED <input checked="" type="checkbox"/> NOT REQUIRED <input type="checkbox"/> SEE PROJECT DWG.	
	3.5	EARTHING BUS		MATERIAL		<input checked="" type="checkbox"/> Cu <input type="checkbox"/> Al <input type="checkbox"/> GI	
				SIZE		50 x 06mm Cu	
	3.6	COLOUR FINISHED SHADE					

SL. NO.		ITEM	UNIT	TECHNICAL PARTICULARS
	3.6.1	INTERIOR		RAL 7032 POWDER COATED MINIMUM THICKNESS 80 MICRONS
	3.6.2	EXTERIOR		ENAMEL <input checked="" type="checkbox"/> EPOXY LIGHT GREY SEMI GLOSSY SHADE 631 FO IS:5
4.1 CIRCUIT BREAKERS	4.1	BREAKER PARTICULARS		
	4.1.2	CIRCUIT BREAKER TYPE (REF. SPEC. CL. 3.1.4)		<input type="checkbox"/> SF6 <input checked="" type="checkbox"/> VCB
	4.1.3	VOLTAGE, FREQUENCY, & NO.OF PHASES	VOLTS, Ph, Hz	33000V, 3Ph, 50Hz
	4.1.4	RATED OPERATING DUTY		O-3 MIN-CO-3 MIN-CO
	4.1.5	RATED CURRENT AT REFERENCE SITE AMBIENT TEMPERATURE		AS PER PROJECT DRAWING(S)
	4.1.6	RATED BREAKING CURRENT	kA (rms)	25
	4.1.7	RATED MAKING CURRENT	kA (peak)	66
	4.1.8	SHORT TIME CURRENT WITHSTAND FOR 1 SEC. DURATION.	kA (rms)	25
	4.1.9	ASYMMETRICAL BREAKING CURRENT		
		(a) AC COMPONENT	kA (rms)	kA (rms) – BY BIDDER
		(b) D.C. COMPONENT	kA	kA – BY BIDDER
	4.1.10	TOTAL OPENING TIME	CYCLES / mSEC	LESS THAN 3 CYCLES
	4.1.11	TOTAL CLOSING TIME	CYCLES / mSEC	LESS THAN 5 CYCLES
	4.1.12	OPERATING MECHANISM, TYPE	–	NORMAL - SPRING CHARGING FOR CLOSING AND TRIPPING EMERGENCY - MANUAL TRIP AND SPRING CHARGED FOR CLOSING AND TRIPPING

SL. NO.		ITEM	UNIT	TECHNICAL PARTICULARS
	4.1.13	MINIMUM NO. OF AUXILIARY CONTACTS	–	6 ‘NO’ + 6 ‘NC’ FOR PURCHASER’S USE
	4.1.14	AUXILIARY CONTROL VOLTAGE		
4.1 CIRCUIT BREAKERS (CONTD.)		(a) FOR CLOSING/TRIPPING COIL	VOLTS	110V DC
		(b) FOR SPRING CHARGING MOTORS	VOLTS	230V AC
		(c) FOR SPACE HEATERS & LIGHTING	VOLTS	230V AC
	4.1.15	BREAKER APPLICATION		
		(a) TRANSFORMER CONTROL		YES / NO
		(b) MOTOR CONTROL		YES / NO
		(c) FURNACE CONTROL		YES / NO
		(d) CAPACITOR CONTROL		YES / NO
4.2 VACUUM CONTACTOR	4.2	VACUUM CONTACTOR	–	NA
	4.2.1	APPLICATION (CONTROLLED EQPT.)	–	MOTOR, CAPACITOR
	4.2.2	MAX. SYSTEM VOLTAGE & FREQUENCY	V. Hz.	NA
	4.2.3	NO. OF POLES	–	ONE TWO THREE
5.0 MECHANISM	5.1	SPRING CHARGING	–	YES NO
	5.2	TYPE	–	AC — DC UNIVERSAL
	5.3	RATING VOLTAGE	V	230
	5.4	RATING	kW	BIDDER TO SPECIFY
	5.5	OTHER	–	MECH & ELECT INDICATIONS REQUIRED WITH REMOTE INDICATIONS
6.0 DISCONNECTORS	6.1	APPLICATION (CONTROLLED EQPT.)	–	NA
	6.2	TYPE	–	NA
	6.3	RATED CURRENT AT REFERENCE SITE AMBIENT TEMPERATURE	–	NA
	6.4	RATED MAKING & BREAKING CAPACITIVE CURRENT	A	NA

SL. NO.		ITEM	UNIT	TECHNICAL PARTICULARS
	6.5	S.C. WITHSTAND CURRENTS	–	NA
		a) MOMENTARY	kA (peak)	NA
		b) 1 SEC. CURRENT	kA (rms)	NA
	6.6	OPERATING MECHANISM CLOSING & OPENING		MOTORISED MANUAL
		CONTROL VOLTAGE	VOLTS	□ AC □ DC
	6.7	MINIMUM NO. OF AUX. CONTACTS	–	2 NO. + 2 NC.
	6.8	HRC FUSES (RATING TO SUIT APPLN.)	SEE PROJ. DRAWINGS	REQUIRED NOT REQUIRED
7.0 CURRENT TRANSFORMER	7.1	TYPE		CAST RESIN BAR PRIMARY
	7.2	SYSTEM VOLTAGE & FREQUENCY		33000 VOLT, 50Hz
	7.3	CLASS OF INSULATION		CLASS-B OR BETTER
	7.4	RATED PRIMARY CURRENT & RATIO		REFER SINGLE LINE DIAGRAM
	7.5	ACCURACY CLASS & BURDEN	METERING	AS PER SLD
			PROTN.	CL.PS/ 5P20 /AS PER SLD
	7.6	SHORT TIME 1 SEC. CURRENT RATING & DYNAMIC RATING	kA (rms) kA (peak)	25kA 66kA
	7.7	CORE BALANCE CTs SHALL BE SUITABLE FOR CABLE SIZES OF THE RESPECTIVE FEEDERS AND SHALL BE COMPLETE WITH SUITABLE SUPPORTS.	-	NA
8.0 VOLTAGE TRANSFORMERS	8.1	TYPE	–	CAST RESIN
	8.2	RATED VOLTAGE		
	8.2.1	PRIMARY (P1)	Volts	$33000/\sqrt{3}$
	8.2.2	SECONDARY (S1)	Volts	$110/\sqrt{3}$
	8.2.3	SECONDARY (S2)	Volts	--
	8.3	METHOD OF CONNECTION		
	8.3.1	PRIMARY (P1)	P1	STAR EARTHED

SL. NO.		ITEM	UNIT	TECHNICAL PARTICULARS
	8.3.2	SECONDARY (S1)	S1	STAR EARTHED
	8.3.3	SECONDARY (S2)	S2	OPEN DELTA STAR EARTHED - REF SLD
	8.4	RATED VOLTAGE FACTOR	–	1.2 CONT., 1.9 TIMES FOR 8 HOURS.
	8.5	CLASS OF INSULATION	–	CLASS – B OR BETTER
	8.6	PROVISION OF PT & ALARM ON EATHING TROLLEY		YES/ NO
9.0 H.V.FUSE	9.1	RATED CURRENT	A	NA
	9.2	VOLTAGE CLASS	kV	NA
	9.3	SYM. INTERRUPTING RATING	kA (rms)	NA
10.0 METERS	10.1	TYPE		DIGITAL/ ANALOGUE
	10.2	ACCURACY CLASS	–	FOR INDICATING INSTRUMENTS: 1.5 OR BETTER, MICROPROCESSOR BASED WITH RS 485 PORT
11.0 RELAYS	11.1	TYPE	–	ELECTRO-MAGNETIC SOLID-STATE NUMERICAL - REF SLD
	11.2	OTHER SPECIFICATION	–	SUITABLE FOR 1A CT SEC (REFER SLD)
12.0 LIST OF ESSENTIAL SPARES	12.1	ONE COMPLETE POLE OF EACH BREAKER		NA
	12.1.1	A. RATING	SET	--
	12.1.2	A. RATING	SET	--
	12.1.3	A. RATING	SET	--
	12.2	LOOSE BREAKER COMPLETE WITH OPERATING MECHANISM AND TRUCK MOUNTED		

SL. NO.		ITEM	UNIT	TECHNICAL PARTICULARS
	12.2.1	A. RATING	SET	--
	12.2.2	A. RATING	SET	--
	12.2.3	A. RATING	SET	--
	12.2.4	A. RATING	SET	--
	12.3	CLOSING & TRIPPING COILS SET	SET	THREE
	12.4	SPRING CHARGING MECHANISM	SET	NA
	12.5	SPRING CHARGING MOTOR ALONE	SET	NA
	12.6	SET OF GASKETS FOR ALL RATINGS	SET	TWO
	12.7	VACUUM CONTACTORS		
	12.7.1	ONE COMPLETE SET	EA	NA
	12.7.2	OPERATION COIL SET	EA	NA
12.0 LIST OF ESSENTIAL SPARES (CONTD.)	12.8	BUSBAR SUPPORT INSULATORS	SET	TWO
	12.9	AUXILIARY SWITCH ASSEMBLY	EA	TWO
	12.10	LIMIT POSITION SWITCH	EA	TWO
	12.11	LOCAL/REMOTE SELECTOR SWITCH	EA	TWO
	12.12	BREAKER CONTROL SWITCH	EA	TWO
	12.13	BUS SEAL OFF BUSHING	SET	TWO
	12.14	PROTECTIVE RELAYS:	–	ONE OF EACH APPLICABLE TYPE
		DEVICE NO. RELAY FUNCTION	QTY	
	12.14.1	49 THERMAL OVERLOAD	SET	NA
	12.14.2	50 S/C PHASE SHORT CIRCUIT	SET	
	12.14.3	50 N EARTH SHORT CIRCUIT	SET	
	12.14.4	51 PHASE OVERLOAD	SET	
	12.14.5	51 N EARTH OVERLOAD	SET	
	12.14.6	50 LR LOCKED ROTOR	SET	NA
	12.14.7	27 UNDER VOLTAGE	SET	

SL. NO.		ITEM	UNIT	TECHNICAL PARTICULARS
	12.14.8	64 RESIDUAL CURRENT	SET	NA
	12.14.9	86 LOCKOUT (MASTER)	SET	
	12.14.10	87 T TRANSFORMER DIFFERENTIAL	SET	NA
	12.14.11	95 FUSE FAILURE	SET	NA
	12.14.12	AUX.RELAYS OF ALL CONFIG.	SET	
	12.14.13	TIMERS OF ALL RATINGS	SET	
12.0 LIST OF ESSENTIAL SPARES (CONTD.)	12.15	INDICATING LAMP	-	MUILT CHIP LED TYPE
	12.15.1	RED, YELLOW, BLUE, GREEN, AMBER	SET	THREE OF EACH TYPE
	12.16	CAST RESIN CURRENT TRANSFORMER	SET	ONE OF EACH RATING
	12.17	CAST RESIN VOLTAGE TRANSFORMER	SET	ONE NO. AS PER SLD.
	12.18	INSTRUMENTS		
	12.18.1	AMMETER	SET	ONE
	12.18.2	VOLTMETER	SET	ONE
	12.18.3	WATTMETER	SET	NA
	12.18.4	WATT HOUR METER	SET	ONE
	12.19	FUSES		
	12.19.1	HRC HV FOR VT	EA	ONE EACH
	12.19.2	HRC LV OF DIFFERENT RATINGS	SET	--
		NOTES : 1) ITEM TICK MARKED TO BE PROVIDED IN SPECIFIED QUANTITY. 2) UNIT PRICES TO BE INDICATED BY THE BIDDER IN QUOTATION APART FROM ABOVE LIST OF SPARES, BIDDER TO INDICATE LIST OF RECOMMENDED SPARES FOR 3 YEARS OF TROUBLE FREE OPERATION.		

5.2. DATA SHEET A2 HIGH VOLTAGE METAL ENCLOSED SWITCHGEAR

SL. NO.	DESCRIPTION	REFERENCE STANDARDS
APPLICABLE STANDARDS	1 METAL ENCLOSED SWITCHGEAR	<input checked="" type="checkbox"/> IS : 3427 IEC : 60265
	2 CIRCUIT BREAKERS	IS : 13118 <input checked="" type="checkbox"/> IEC : 62271
	3 SWITCHES & SWITCH DISCONNECTORS ABOVE 1000 V & UPTO 11 KV	<input checked="" type="checkbox"/> IEC : 60265
	4 (OFF LOAD) DISCONNECTORS	<input checked="" type="checkbox"/> IEC : 62271
	5 ARRENGEMENT FOR SWITCHGEAR BUSBARS, MAIN CONNECTION AND AUXILIARY WIRING	<input checked="" type="checkbox"/> IS :5578,11353 IEC :
	6 BUSBARS	
	6.1 COPPER	
	6.2 ALUMINIUM	<input checked="" type="checkbox"/> IS: 5082 IEC:
	7 BUSBAR SUPPORT INSULATORS	<input checked="" type="checkbox"/> IS : 2544 IEC :
	8 DEGREE OF PROTECTION	<input checked="" type="checkbox"/> IS : 3427 IEC :60529
	9 CURRENT TRANSFORMERS	<input checked="" type="checkbox"/> IS : 2705 IEC : 60044
	10 POTENTIAL TRANSFORMERS	<input checked="" type="checkbox"/> IS : 3156 IEC : 60044
	11 A.C. ELECTRICITY METERS	<input checked="" type="checkbox"/> IS : 722 IEC :
	12 ELECTRICAL INDICATING INSTRUMENTS	<input checked="" type="checkbox"/> IS : 1248 IEC : 60051
	13 ELECTRICAL RELAYS FOR POWER SYSTEM PROTECTION	<input checked="" type="checkbox"/> IS : 3231 IEC :60255
	14 HIGH VOLTAGE FUSES	<input checked="" type="checkbox"/> IS : 9385 IEC :60282
	15 HRC FUSES	<input checked="" type="checkbox"/> IS : 13703 IEC : 60269
	16 CODE OF PRACTICE FOR PHOSPATING IRON AND STEEL	<input checked="" type="checkbox"/> IS : 6005 IEC :
	17 SF ₆ GAS	IS : <input checked="" type="checkbox"/> IEC : 60376
	18 H.V. CABLE TERMINATION	IS : <input checked="" type="checkbox"/> IEC : 62329
NOT E	1. EQUIPMENT, ACCESSORIES, COMPONENTS / PARTS, RAW MATERIALS AND TEST SHALL IN GENERAL CONFORM TO : IS <input checked="" type="checkbox"/> IEC <input checked="" type="checkbox"/> ANSI <input type="checkbox"/>	

5.3. DATA SHEET A1 LOW VOLTAGE SWITCHGEAR

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
1.0	<u>SWITCHGEAR & BUSBAR RATING</u>		
1.1	RATED VOLTAGE, PHASES & FREQUENCY		415 V, 3 Ph, 4 WIRE, 50 Hz
1.2	SYSTEM NEUTRAL EARTHING: (EFFECTIVELY/ NON EFFECTIVELY)		EFFECTIVELY EARTHED
1.3	MAXIMUM SYSTEM VOLTAGE		456.5 VOLTS (415+10%)
1.4	ONE MINUTE POWER FREQUENCY VOLTAGE		
	A) POWER CIRCUITS B) CONTROL CIRCUITS C) AUX. CIRCUITS CONNECTED TO SEC. OF CTS	VOLTS VOLTS VOLTS	2500 1500 2000
1.5	CONTINUOUS CURRENT RATING OF BUSBARS UNDER SITE REFERENCE AMBIENT TEMPERATURE		REFER ITEM-2 BELOW AND ENCLOSED SLD
1.6	REFERENCE AMBIENT TEMPERATURE	°C	50
1.7	MAXIMUM TEMPERATURE OF BUSBARS, DROPPERS AND CONTACTS AT CONTINUOUS CURRENT RATING UNDER SITE REFERENCE AMBIENT TEMPERATURE	°C	85
1.8	SHORT CIRCUIT WITHSTAND FOR BUSBARS AND DROPPERS A) SHORT TIME (1 SEC.) AT 415V B) DYNAMIC RATING	KA (RMS) KA (PEAK)	50/ 35 105/ 73.5
1.9	STANDARD APPLICABLE		AS PER DATA SHEET-A2
2.0	<u>SWITCHGEAR CONSTRUCTIONAL REQUIREMENTS</u>		
2.1	THICKNESS OF SHEET STEEL COLD ROLLED HOT ROLLED	mm mm	AS PER SECTION-D FRAME 2.0 DOORS 2.0 COVERS 1.6 FRAME DOORS COVERS

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
2.2	DEGREE OF ENCLOSURE PROTECTION	AS PER IS:13947	IP-52 FOR INDOOR PANELS & IP-55 FOR OUTDOOR PANELS
2.3	DEGREE OF ENCLOSURE PROTECTION AGAINST EXTERNAL MECHANICAL IMPACTS		AS PER IEC - 62262
2.4	COLOUR FINISH SHADE AS PER IS:5 INTERIOR EXTERIOR		GLOSSY WHITE RAL 7032/ 631 LIGHT GREY SEMI GLOSSY SHADE
2.5	EARTHING BUS MATERIAL SIZE	mm	GI TO SUIT SHORT CIRCUIT LEVEL
2.6	PURCHASER'S EARTHING CONDUCTOR MATERIAL SIZE	mm	GI 75 x12 mm
2.7	CLEARANCES IN AIR OF LIVE PARTS		PHASE TO PHASE : 25.4 MM PHASE TO EARTH : 19.4 MM
2.8	METAL ENCLOSED BUSDUCT/ BUS TRUNKING ENTRY TO CUBICLES IF REQUIRED		TOP/ BOTTOM INDOOR/ OUTDOOR
2.9	FORM OF SEPARATION AS PER IEC 60439-1		PANELS HAVING ACB AS INCOMER – FORM 4A; OTHER PANELS – FORM 3B
2.10	REQUIREMENT OF ARC RESISTANCE FEATURE		YES/ NO
3.0	<u>STARTERS</u>		
3.1	TYPE		UPTO 7kW – DOL, 8kW to 45kW - Y-Δ, >45kW – RELAY PROTECTION
3.2	CONTACTOR RATED DUTY		AS PER IS:13947
3.3	UTILISATION CATEGORY		AS PER IS:13947
3.4	CONTROL SCHEME & BILL OF MATERIAL ENCLOSED	YES /NO	IF YES, REF.NO. SEE ENCLOSED DWG LIST IN SECTION-C
3.5	CONTROL TRANSFORMER :		NOT APPLICABLE

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
3.5.1	SEPARATE FOR EACH MODULE	YES/NO	NO
3.5.2	COMMON FOR EACH SWITCHGEAR SECTION WITH 100% STANDBY	YES/NO	NO
3.6	SINGLE PHASING PREVENTOR REQUIRED	YES/NO	YES
3.7	STANDARD APPLICABLE		AS PER DATA SHEET-A2
3.8	THERMAL OVER LOAD RELAY RESET		HAND/ AUTO
4.0	<u>CIRCUIT BREAKER</u>		
4.1	CIRCUIT BREAKER TYPE		AIR CIRCUIT BREAKER
4.2	VOLTAGE, FREQUENCY & NO. OF PHASES		415 V, 3 PHASE, 4 WIRE, 50 Hz
4.3	RATED BREAKING DUTY		B-0.3 SEC-MB-3 SEC-MB
4.4	RATED BREAKING CAPACITY (a) MVA (b) kA(RMS) AT 415V 0.25 P.F.		36/ 26 50/ 36
4.5	SHORT CIRCUIT WITHSTAND CURRENT FOR 1 SEC. DURATION	kA	50/ 36
4.6	RATED MAKING CURRENT	kA(PEAK	105/ 75.6
4.7	RATED CURRENT AT SITE REFERENCE AMBIENT TEMPERATURE	A	REFER 415V SLDs
4.8	TYPE OF OPERATING MECHANISM		MANUAL SPRING ASSISTED/ MANUAL SPRING CHARGED/ MOTOR WOUND SPRING CHARGED
4.9	KEY INTERLOCKING REQUIRED		YES/ NO
4.10	SHUNT TRIP REQUIRED		YES/ NO
4.11	PROTECTION REQUIRED (a) RELAYS/ SERIES RELEASES (b) RELAY TYPE & SETTINGS (c) UNDER VOLTAGE RELEASE REQUIRED SETTING		AS PER SLD, YES/ NO DG PCC PANEL WITH/ WITHOUT TIME DELAY

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
4.12	MINIMUM NO OF AUXILIARY CONTACTS		6 'NO' + 6 'NC'
4.13	CONTROL VOLTAGE (a) FOR SPRING CHARGING MOTOR (b) FOR CLOSING/TRIPPING	V AC/ DC	230V, 1 PH, AC 230V, 1 PH, AC UPS SUPPLY
4.14	EMERGENCY MANUAL OPERATION REQUIRED IN ADDITION TO ELECTRICAL OPERATING DEVICES (a) FOR SPRING CHARGING & CLOSING (b) FOR TRIPPING		YES/ NO YES/ NO
4.15	ANNUNCIATOR REQUIRED		YES / NO
4.16	STANDARDS APPLICABLE		AS PER DATA SHEET-A2
5.0	<u>MCCB's</u>		
5.1	MOULDED CASE CIRCUIT BREAKERS TO BE PROVIDED. (a) FOR MOTOR CONTROL CIRCUITS (b) FOR OTHER CIRCUITS		YES/ NO YES/ NO
5.2	VOLTAGE, FREQUENCY & NO OF PHASES		415 V, 50 Hz, 3 PHASE, 4 WIRE
5.3	RATED OPERATING DUTY		AS PER IS
5.4	RATED BREAKING CAPACITY (AT 415V 0.25 P.F.)	kA(RMS)	36/ 25/ 16
5.5	RATED MAKING CURRENT	kA (Peak)	75.6/ 52.5/ 33.6
5.6	RATED CURRENT AT SITE REFERENCE AMBIENT TEMPERATURE		REFER 415V SLDs
5.7	ON/OFF OPERATION MANUAL REMOTE POWER OPERATED		YES/ NO YES /NO
5.8	RELEASES REQUIRED OVER LOAD INVERSE TIME UNDER VOLTAGE		YES/ NO YES /NO
5.9	STANDARDS APPLICABLE		AS PER DATA SHEET-A2

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
	<u>NOTES:</u> (a) MCCB SHALL BE PROVIDED IN DQ STARTER FEEDERS OF AUXILIARY MCC (b) NO SWITCH FUSE UNITS SHALL BE USED (c) OUTGOING OF AMF CUM DG SWITCHGEAR SHALL BE 1200A MOULDED CASE CIRCUIT BREAKER WITHOUT RELEASES		
6.0	<u>ESSENTIAL SPARES</u>		
	DESCRIPTION		ESSENTIAL SPARES TO BE FURNISHED (REFER NOTE-2)
6.1	COMPLETE BREAKER WITH OPERATING MECHANISM AND RELEASES WHERE SPECIFIED I) A II) A III) A IV) A		
	CLOSING & TRIPPING COILS		
6.2	SPRING, CHARGING MOTORS, ALONG WITH CLOSING & TRIPPING SPRINGS IN CASE OF SPRING OPERATED BREAKERS		10% OF EACH RATING WITH MINIMUM 1NO.
6.3	AUXILIARY CONTACT BLOCKS		10% OF EACH RATING WITH MINIMUM 1NO.
6.4	MOVING AUXILIARY CONTACT BLOCKS		10% OF EACH RATING WITH MINIMUM 1NO.
6.5	BREAKER CONTROL SWITCHES		10% OF EACH RATING WITH MINIMUM 1NO.
6.6	LOCAL/REMOTE SELECTOR SWITCHES		10% OF EACH RATING WITH MINIMUM 1NO.
6.7	PROTECTIVE RELAYS I) 50 S/C II) 49 III) 50N IV) 50 LR V) 27 VI) 51 VII) AUXILIARY RELAYS VIII) TIMERS		

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
6.8	INDICATING LAMPS WITH SERIES RESISTORS : I) RED II) GREEN III) AMBER IV) V)		10% OF EACH RATING WITH MINIMUM 5NOS. OF EACH TYPE.
6.9	CURRENT TRANSFORMERS I) II) III) IV) V) VI) VII)		10% OF EACH RATING WITH MINIMUM 1NO.
6.10	VOLTAGE TRANSFORMERS I) II) III) IV) V)		10% OF EACH RATING WITH MINIMUM 1NO.
6.11	CONTRTOL TRANSFORMERS RATIO 415/110V I) II) III) IV) V)		10% OF EACH RATING WITH MINIMUM 1NO.
6.12	INSTRUMENTS : I) AMMETER FOR 5A OPERATION II) VOLTMETER FOR 110V OPERATION		10% OF EACH RATING WITH MINIMUM 1NO.
6.13	CONTACTORS, RATING : I) II) III) IV) V)		10% OF EACH RATING WITH MINIMUM 1NO.

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
6.14	BI-METALLIC THERMAL ELEMENTS TO SUIT MOTORS OF FOLLOWING RATINGS : I) II) III) IV) V) VI) VII)		NA
6.15	POWER FUSES TO SUIT CIRCUITS OF FOLLOWING RATINGS : I) II) III) IV) V) VI) VII)		NA
6.16	CONTROL CIRCUIT FUSES		
6.17	PUSH BUTTONS : I) START II) STOP		
7.18	HEAVY DUTY AIR BREAK SWITCHES I) II) III) IV) V) VI) VII)		NA
7.19	MCBs FOR SPACE HEATERS		

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
7.20	CONTROL CABLE GLANDS TO SUIT FOLLOWING CABLE SIZES; I) II) III) IV) V) VI) VII)		
7.21	IN ADDITION TO ABOVE ITEMS QUANTITIES AND ITEMISED PRICES OF FOLLOWING ITEMS AND ANY OTHER ITEMS RECOMMENDED BY THE BIDDER SHALL BE FURNISHED I) ARCING CONTACTS OF BREAKERS II) ARC CHUTES III)		
NOTES : 1) ITEM TICK MARKED TO BE PROVIDED 2) RECOMMENDED QUANTITY AND UNIT PRICES TO BE INDICATED BY THE BIDDER IN HIS QUOTATIONS			

5.4. DATA SHEET A2 LOW VOLTAGE SWITCHGEAR

1.	SWITCHGEAR GENERAL REQUIREMENTS	<input checked="" type="checkbox"/> IS:13947-1	<input type="checkbox"/> BSEN:60947	<input checked="" type="checkbox"/> IEC:60439-1
2.	AC CIRCUIT BREAKERS	<input type="checkbox"/> BSEN 60947-2	<input type="checkbox"/> BS:3871(PI)	<input checked="" type="checkbox"/> IEC 947-2
3.	FACTORY BUILT ASSEMBLIES OF SWITCHGEAR AND CONTROL GEAR FOR VOLTAGES UPTO AND INCLUDING 1000V A.C. & 1200 V D.C	<input checked="" type="checkbox"/> IS:8623	<input type="checkbox"/> BS:5486	<input type="checkbox"/> IEC:439
4.	AIR BREAK SWITCHES	<input checked="" type="checkbox"/> IS:13947	<input type="checkbox"/> BSEN:60947-3	<input type="checkbox"/> IEC-947-3

5.	MINIATURE CIRCUIT BREAKERS	<input checked="" type="checkbox"/> IS:8828	<input type="checkbox"/> BS:3871	<input type="checkbox"/> IEC:
6.	HRC CARTRIDGE FUSES	<input type="checkbox"/> IS:13703(P2)	<input type="checkbox"/> BS:88	<input type="checkbox"/> IEC-769
7.	D TYPE FUSES	<input type="checkbox"/> IS:8187	<input type="checkbox"/> BS:	<input type="checkbox"/> IEC:
8.	CONTACTORS	<input checked="" type="checkbox"/> IS:13947	<input type="checkbox"/> BSEN-60947-1	<input type="checkbox"/> IEC:9474-1
9.	STARTERS	<input checked="" type="checkbox"/> IS:13947	<input type="checkbox"/> BSEN-60947-4-1	<input type="checkbox"/> IEC:947-4-1
10.	CONTROL SWITCHES/PUSH BUTTONS	<input checked="" type="checkbox"/> IS:13947	<input type="checkbox"/> BS:	<input type="checkbox"/> IEC:
11.	CURRENT TRANSFORMERS	<input checked="" type="checkbox"/> IS:2705	<input type="checkbox"/> BS:7626	<input type="checkbox"/> IEC:60044
12.	VOLTAGE TRANSFORMERS	<input checked="" type="checkbox"/> IS:3156	<input type="checkbox"/> BS:7625	<input type="checkbox"/> IEC:60044
13.	RELAYS	<input checked="" type="checkbox"/> IS:3231	<input type="checkbox"/> BS:142	<input type="checkbox"/> IEC:255
14.	INDICATING INSTRUMENTS	<input checked="" type="checkbox"/> IS:1248	<input type="checkbox"/> BS:89	<input type="checkbox"/> IEC:51
15.	ARRANGEMENT FOR BUSBARS MAIN CONNECTIONS AND ACCESSORIES	<input checked="" type="checkbox"/> IS:5578 <input checked="" type="checkbox"/> IS:11353	<input type="checkbox"/> BS:159	<input type="checkbox"/> IEC:
16.	AC ELECTRICITY METERS	<input checked="" type="checkbox"/> IS:8530	<input type="checkbox"/> BS:37	<input type="checkbox"/> IEC:
17.	DEGREE OF PROTECTION	<input checked="" type="checkbox"/> IS:13947(P1)	<input type="checkbox"/> BS:	<input type="checkbox"/> IEC:947-1
18.	THE PERFORMANCE OF AC CONTROL GEAR EQUIPMENT RATED UPTO 600 V FOR USE ON HIGH PROSPECTIVE FAULT CURRENT SYSTEM	<input checked="" type="checkbox"/> IEC:62262 <input type="checkbox"/> IS:	<input type="checkbox"/> BS:	<input type="checkbox"/> IEC:
19.	CODE OF PRACTICE FOR INSTALLATION AND MAINTENANCE OF SWITCHGEAR	<input checked="" type="checkbox"/> IS:10118	<input type="checkbox"/> BS:	<input type="checkbox"/> IEC:
20.	CLIMATE PROOFING OF ELECTRICAL EQUIPMENT	<input checked="" type="checkbox"/> IS:	<input type="checkbox"/> BS:	<input type="checkbox"/> IEC:

21.	CODE OF PRACTICE FOR PHOSPHATING IRON AND STEEL	<input checked="" type="checkbox"/> IS: 6005 <input type="checkbox"/> BS: 3169 <input type="checkbox"/> IEC:
22.	WROUGHT ALUMINIUM AND ALUMINIUM ALLOYS FOR ELECTRICAL PURPOSES	<input checked="" type="checkbox"/> IS:5082 <input type="checkbox"/> BS:2898 <input type="checkbox"/> IEC:
23.	CONTROL TRANSFORMER FOR SWITCHGEAR AND CONTROL GEAR FOR VOLTAGE NOT EXCEEDING 110V AC	<input checked="" type="checkbox"/> IS:12021 <input type="checkbox"/> BS: <input type="checkbox"/> IEC:
24.	TESTING GUIDE	<input checked="" type="checkbox"/> ANSI / IEEE C.37.20.7
	EQUIPMENT, ACCESSORIES, COMPONENT PARTS, RAW MATERIALS AND TESTS SHALL BE IN GENERAL CONFORM TO IEC: <input checked="" type="checkbox"/> IS: <input checked="" type="checkbox"/> BS	

5.5. DATA SHEET A1 CONTROL PANEL

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
1.0	<u>GENERAL PARTICULARS</u>		
1.1	DESIGNATION		RTCC, MARSHALLING BOX
1.2	LOCATION	INDOOR / OUTDOOR	INDOOR
1.3	DESIGN AMBIENT TEMPERATURE	⁰ C	50
1.4	TYPE OF MOUNTING	FLOOR / PEDESTAL / COLUMN /WALL	FLOOR, TRANSFORMER TANK
1.5	CABLE ENTRY		

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
	A) TOP / BOTTOM		TOP / BOTTOM - AS PER SITE CONDITION
	B) GLANDS / CONDUITS -SIZE		AS PER REQUIREMENT
	C) GLANDS IF REQUIRED	YES/NO	YES
1.6	PURCHASER'S EARTHING CONDUCTOR		
	A) MATERIAL	COPPER / ALUMINIUM / G I	G I
	B) TYPE	STRIPS / ROPE / WIRE./ ROD	STRIPS
	C) SIZE		75 x12 mm
1.7	PAINTING		MIN. THICKNESS 80 MICRONS
	A) COLOUR FINISH		
	OUTSIDE		RAL 7032 SIEMENS GREY (PEBBLE GREY) WITH TEXTURED FINISH – FOR RTCC AND COLOUR SHADE 632 OF IS-5 FOR MARSHALLING BOX.
	INSIDE		GLOSSY WHITE
	B) EPOXY PAINT REQUIRED	YES/NO	YES – POWDER COATED
1.8	CONTROL SCHEME & BILL OF MATERIAL, ENCLOSED If NO, TO BE FURNISHED BY VENDOR	NO	TO BE FURNISHED BY BIDDER

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
2.0	VOLTAGE		
2.1	POWER DEVICES, MOTOR DRIVES, ETC.		
	A) SUPPLY VOLTAGE	415V, 3PH / 3PH -N, 50Hz/ 240V, 1PH-N, 50Hz	415V, 3PH-N, 50Hz/ 230V, 1PH-N, 50Hz
	B) DUPLICATE FEED	PROVIDE D/ NOT PROVIDE D	NOT PROVIDED
2.2	CONTROL VOLTAGE	V, AC/DC	230V AC
2.3	CONTROL TRANSFORMER	REQD./ NOT REQD.	REQUIRED
2.4	SPACE HEATER/ LIGHTING SUPPLY VOLTAGE		230 V, 1-PH, 50 Hz
3.0	OTHER PARTICULARS WHEN APPLICABLE		
3.1	STARTERS TYPE		DOL
3.2	CONTACTOR RATED DUTY (AS PER IS:2459 & 8544)		BY BIDDER
NOTES:			
The Bidder shall also indicate his recommendation of spares, in addition to above, if necessary.			

5.6. DATA SHEET A2 CONTROL PANEL

1.	APPLICABLE STANDARDS			
2.	SWITCHGEAR GENERAL REQUIREMENTS	<input checked="" type="checkbox"/> IS 4237	<input type="checkbox"/> BSEN	<input type="checkbox"/> IEC 60947
3.	FACTORY BUILT ASSEMBLIES OF SWITCHGEAR AND CONTROL GEAR FOR VOLTAGES UPTO AND INCLUDING 1000V. A.C. & 1200 V. D.C.	<input checked="" type="checkbox"/> IS:8623	<input type="checkbox"/> BS : 5486	<input type="checkbox"/> IEC 60439-1
4.	AIR BREAK SWITCHES	<input checked="" type="checkbox"/> IS-13947	<input type="checkbox"/> BSEN 60947-3	<input type="checkbox"/> IEC60405
5.	MINIATURE CIRCUIT BREAKERS	<input checked="" type="checkbox"/> IS:8828	<input type="checkbox"/> BS: 3871	<input type="checkbox"/> IEC IEC- (PI)
6.	H.R.C. CARTRIDGE FUSES	<input checked="" type="checkbox"/> IS :13703	<input type="checkbox"/> BS-88	<input type="checkbox"/> IEC 60269-1 & IEC 60269-2 & IEC-60269-4
7.	D TYPE FUSES	<input checked="" type="checkbox"/> IS-8187	<input type="checkbox"/> BS :	<input type="checkbox"/> IEC:
8.	CONTACTORS	<input checked="" type="checkbox"/> IS-13947	<input type="checkbox"/> BS-775	<input type="checkbox"/> IEC-947-4-1
9.	STARTERS	<input checked="" type="checkbox"/> IS-13947	<input type="checkbox"/> BSEN-60947	<input type="checkbox"/> IEC-947-4-2
10.	CONTROL SWITCHES/PUSH BUTTONS	<input checked="" type="checkbox"/> IS-13947	<input type="checkbox"/> BS	<input type="checkbox"/> IEC
11.	CURRENT TRANSFORMERS	<input checked="" type="checkbox"/> IS-2705	<input type="checkbox"/> BS-60044-1	<input type="checkbox"/> IEC- 60185
12.	POTENTIAL (VOLTAGE) TRANSFORMERS	<input checked="" type="checkbox"/> IS-3156	<input type="checkbox"/> BS-7625	<input type="checkbox"/> IEC-60186
13.	RELAYS	<input checked="" type="checkbox"/> IS-3231	<input type="checkbox"/> BS-142	<input type="checkbox"/> IEC-60255
14.	INDICATING INSTRUMENTS	<input checked="" type="checkbox"/> IS-1248	<input type="checkbox"/> BS-89	<input type="checkbox"/> IEC-60051
15.	ARRANGEMENT FOR BUS BARS, MAIN CONNECTIONS AND ACCESSORIES	<input checked="" type="checkbox"/> IS-5578 & IS-11353	<input type="checkbox"/> BS-159	<input type="checkbox"/> IEC

16.	A.C. ELECTRICITY METERS	<input checked="" type="checkbox"/> IS-722	<input type="checkbox"/> BS-5685	<input type="checkbox"/> IEC
17.	DEGREE OF PROTECTION	<input checked="" type="checkbox"/> IS-13947	<input type="checkbox"/> BS:	<input type="checkbox"/> IEC-60947-1
18.	THE PERFORMANCE OF A.C. CONTROL GEAR EQUIPMENT RATED UP TO 660V FOR USE ON HIGH PROSPECTIVE FAULT CURRENT SYSTEM	<input checked="" type="checkbox"/> IS	<input type="checkbox"/> BS	<input type="checkbox"/> IEC
19.	CODE OF PRACTICE FOR INSTALLATION AND MAINTENANCE SWITCHGEAR	<input checked="" type="checkbox"/> IS-10118	<input type="checkbox"/> BS:	<input type="checkbox"/> IEC
20	CLIMATE PROOFING OF ELECTRICAL EQUIPMENT	<input checked="" type="checkbox"/> IS-3202	<input type="checkbox"/> BS	<input type="checkbox"/> IEC
21.	CODE OF PRACTICE FOR PHOSPHATING IRON & STEEL	<input checked="" type="checkbox"/> IS-6005	<input type="checkbox"/> BS-3189	<input type="checkbox"/> IEC
22.	WROUGHT ALUMINIUM & ALUMINIUM ALLOYS FOR ELECTRICAL PURPOSES	<input checked="" type="checkbox"/> IS-5082	<input type="checkbox"/> BS-2898	<input type="checkbox"/> IEC-114

5.7. DATA SHEET A1 POWER FACTOR CORRECTION SYSTEM

1.0	ITEM	UNIT	TECHNICAL PARTICULAR
1.1	APPLICATION/DESIGNATION		P.F. IMPROVEMENT/ HARMONIC FILTERS/ COMBINED P.F. + HARMONIC FILTER
1.2	ITEM NO.		APFCP
1.3	QUANTITY		TWO
1.4	RATED CAPACITY	KVAR	475
1.5	RATED VOLTAGE	VOLTS	415
1.6	FREQUENCY	Hz	50
1.7	NO OF PHASES		3
1.8	EXPECTED POWER FACTOR		0.98 OR BETTER
1.9	EXPECTED DISTORTION FACTOR		3%
1.10	APPLICABILITY OF		

	a) TCE M4-219-01	YES/NO	YES
	IF YES, WHETHER ENCLOSED	YES/NO	YES
	b) TCE M4-204-02	YES/NO	NO
	IF YES, WHETHER ENCLOSED	YES/NO	NO
2.0	DESIGN REQUIREMENT		
2.1	AMBIENT TEMPERATURE	⁰ C	50
2.2	TEMPERATURE RISE	⁰ C	AS PER IS:2834
2.3	TYPE OF MOUNTING, FLOOR/WALL/PEDESTAL		FLOOR
2.4	LOCATION INDOOR/ OUTDOOR		INDOOR
2.5	TYPE		ALL PP (DOUBLE LAYER) /MIXED DIELECTRIC
2.6	INSULATION LEVEL		1100V
2.7	SIZE OF CABLE		REFER SLD DRW NO: TCE-10106A-4000-AU-40077
2.8	CABLE GLAND REQUIRED	YES/NO	YES
2.9	SIZE OF EARTHING CONDUCTOR AND MATERIAL		REFER EARTHING SCHEMATIC LAYOUT
2.10	CAPACITOR BANK OPEN /METAL ENCLOSED CUBICILE		METAL ENCLOSED CUBICILE
2.11	TYPE OF CAPACITOR BANK CONNECTION	STAR/ DELTA	DELTA
2.12	IF STAR CONNECTED, MODE OF NEUTRAL CONNECTION - EARTHED/UNEARTHED		NA
2.13	TYPE OF ATMOSPHERE CHEMICAL WITH FUME/ NORMAL		NORMAL
3.0	SWITCHES		
3.1	TYPE OF SWITCHING AUTOMATIC/MANUAL		THYRISTERISED AUTOMATIC & MANUAL
3.2	IF AUTOMATIC A) BREAKER/SWITCH RATING I) VOLTAGE	VOLTS	REFER ENCLOSED SLD 415 V
	II) CURRENT	AMPS	REFER ENCLOSED SLD

	III) FAULT LEVEL	MVA	REFER ENCLOSED SLD
	B) VOLTAGE OPERATED	YES/NO	NO
	C) P.F. OPERATED	YES/NO	YES
	D) PARALLEL OPERATION OF CAPACITORS REQUIRED/NOT REQUIRED		NOT REQUIRED
4.0	DISCHARGE DEVICE – RESISTOR		
4.1	RATED VOLTAGE	V	RESISTOR SHALL BE SUITABLE TO DISCHARGE TO 50V WITHIN 300SEC. RATINGS TO BE DECIDED ACCORDINGLY BY BIDDER
4.2	RATED RESISTANCE	OHMS	RESISTOR SHALL BE SUITABLE TO DISCHARGE TO 50V WITHIN 300SEC. RATINGS TO BE DECIDED ACCORDINGLY BY BIDDER
4.3	RATED CONTINUOUS WATTAGE	WATTS	BY BIDDER
4.4	TYPE AND MATERIAL		BY BIDDER
5.0	VTs		NA
5.1	RATED VOLTAGE RATIO	KV	NA
5.2	BASIC IMPULSE LEVEL	KV	NA
5.3	V.A. BURDEN		NA
5.4	ACCURACY CLASS		NA
5.5	TYPE OF INSULATION USED		NA
5.6	WEIGHT AND DIMENSIONS		NA
5.7	TECHNICAL BULLETIN SHOWING COMPLETE DESIGN FEATURES OF VTs ENCLOSED	YES/NO	NA
6.0	SERIES REACTOR		
6.1	APPLICATION		DETUNED FILTER REACTOR
6.2	TYPE/MAKE		DRY TYPE IRON CORED
6.3	NO. OF PHASES		3
6.4	BIL	KV	0.456.5
6.5	FREQUENCY	Hz	50
6.6	REACTANCE IN OHMS/IN		7%

	PERCENTAGE		
6.7	CURRENT RATING	AMP	130% OF RATED CAPACITOR BANK CURENT
6.8	MAXIMUM SWITCHING SURGE FOR EACH BANK WITH & WITHOUT REACTOR		BIDDER TO SPECIFY
6.9	VOLTAGE RATING	KV	415
6.10	SHORT CIRCUIT RATING	AMP	GENERALLY 16 TIMES OF 130% RATED CURRENT OF CAPACITOR BANK FOR 3 SECONDS.
6.11	TYPE OF SHIELDING MAGNETIC/NON-MAGNETIC		NON-MAGNETIC
6.12	TYPE OF COOLING	OIL/AIR	AIR
7.0	SPECIAL TESTS TO BE CONDUCTED		
	HARMONIC MEASUREMENTS	YES/NO	NO
8.0	NOTES		

5.8. DATA SHEET A2 POWER FACTOR CORRECTION SYSTEM

1.0	APPLICABLE STANDARDS		
1.1	SHUNT CAPACITORS FOR POWER SYSTEMS		<input checked="" type="checkbox"/> IS 13585 & 13925 <input type="checkbox"/> BS <input type="checkbox"/> IEC
1.2	SERIES REACTOR		<input checked="" type="checkbox"/> IS 5553 <input type="checkbox"/> BS <input type="checkbox"/> IEC
1.3	INTERNAL FUSES AND INTERNAL OVERPRESSURE DISCONNECTORS FOR SHUNT CAPACITORS		<input checked="" type="checkbox"/> IS 12672 <input type="checkbox"/> BS <input type="checkbox"/> IEC
1.4	PORCELAIN POST INSULATORS (3.3 KV AND ABOVE)		<input type="checkbox"/> IS2544 <input type="checkbox"/> BS <input type="checkbox"/> IEC
1.5	LIGHTENING ARRESTORS (SURGE ARRESTORS)		<input type="checkbox"/> IS 15086 <input type="checkbox"/> BS <input type="checkbox"/> IEC
2.0	NOTES		

5.9. DATA SHEET A1 DISTRIBUTION TRANSFORMER

1.0	ITEM	UNIT	TECHNICAL PARTICULAR
1.1	APPLICATION/DESIGNATION		DISTRIBUTION TRANSFORMER-1
1.2	QUANTITY REQUIRED		1
1.3	INSTALLATION (INDOOR/OUTDOOR)		OUTDOOR
1.4	DEGREE OF PROTECTION AS PER IS:13947		IP 55
2.0	<u>RATINGS</u>		
2.1	RATING	KVA	2000
2.2	NUMBER OF PHASES & FREQUENCY		3 PH
2.3	TYPE OF COOLING		ONAN
2.4	NO LOAD VOLTAGE HV	V	33000
	LV	V	433
2.5	VECTOR GROUP		DYN11
2.6	PERCENTAGE IMPEDANCE	%	6.25
3.0	<u>SYSTEM VOLTAGE</u>		
3.1	NOMINAL SYSTEM VOLTAGE HV	V	33000
	LV	V	415
3.2	HIGHEST SYSTEM VOLTAGE HV	KV	36 KV
	LV	V	0.457 KV
4.0	<u>NEUTRAL EARTHING</u>		
4.1	SYSTEM NEUTRAL		
	A) EFFECTIVELY EARTHED	HV	NOT APPLICABLE (DELTA CONNECTED)
4.2	TRANSFORMER NEUTRAL		

		HV	NOT APPLICABLE (DELTA CONNECTED)
		LV	EFFECTIVELY EARTHED
5.0	<u>INSULATION WITHSTAND</u>		
5.1	IMPULSE (1.2/50 MICROSEC/WAVE)	HV	170
5.2	POWER FREQUENCY HV	KV	70
	(DRY & WET) LV	KV	3
6.0	<u>TEMPERATURE RISE</u>		
6.1	REFERENCE AMBIENT	⁰ C	45
6.2	OIL BY THERMOMETER	⁰ C	50
6.3	WINDING BY RESISTANCE	⁰ C	50
7.0	<u>TAP CHANGING GEAR</u>		
7.1	TAPS		ON LOAD
7.2	TAPPINGS ON WINDINGS	HV/LV	HV
7.3	TOTAL TAPPING RANGE		-5% TO +12%
7.4	STEPS	%	2.5%
8.0	<u>DETAILS OF TRANSFORMER OPERATING IN PARALLEL</u>		
8.1	MANUFACTURER'S NAME		
8.2	RATING	KVA	2000
8.3	FULL LOAD LOSS CORRECTED TO 75 ⁰ C		25 KW
8.4	% IMPEDANCE AT PRINCIPAL TAPPINGS		6.25%
8.5	VECTOR GROUP		DYN 11
9.1	<u>HV CABLE BOX- CABLE ENTRY</u> (TOP/ BOTTOM)		BOTTOM.

9.2	LV TERMINATION ARRANGEMENT (BUS DUCT/ CABLE BOX)		BUS DUCT.
9.3	IF CABLE BOX - CABLE ENTRY (TOP/ BOTTOM)		N A
9.4	IF BUS DUCT- ENTRY TYPE (TOP/SIDE)		TOP
9.5	<u>NEUTRAL CTS</u>		
9.6	QUANTITY		ONE - ONE
9.7	RATIO		3200/1A - 3200/1A
9.8	VA BURDEN		-- 10VA
9.9	ACCURACY CALSS		CL PS CL5P20
9.10	KNEE POINT VOLTAGE		380V ---
9.11	MAGNETIZING CURRENT AT KNEE-POINT VOLTAGE		30MA ---
10.0	<u>TERMINAL CONNECTIONS</u>		
10.1	CABLE SCHEDULE COMPLETE WITH CABLE SIZES,TERMINATION DETAILS OF EITHER SIDE /INTERCONNECTION SCHEDULE BETWEEN THE TRANSFORMER ,M. BOX ,OLTC TO RTCC PANEL		BIDDER SCOPE
10.2	ORIENTATION OF HV & LV TERMINATIONS		90 °
10.5	BUSHING TERMINALS		
	A) REQUIRED	YES/NO	YES
	B) SIZE OF PURCHASER'S TAKE OFF CONDUCTOR		
10.6	CABLE BOX, LUGS AND GLANDS		
	A) REQUIRED	YES/NO	
	B) PURCHASER'S CABLE		

	DETAILS		
11.0	<u>EARTHING TERMINAL</u>		
11.1	MATERIAL OF CONDUCTOR		GI
11.2	SIZE OF CONDUCTOR		BY BIDDER
12.0	<u>MISCELLANEOUS</u>		
12.1	WHEELS		
	A) PLAIN/FLANGED		
	B) UNIDIRECTIONAL/BIDIRECTIONAL		BIDIRECTIONAL
12.2	VACUUM WITHSTAND CAPABILITY MAIN TANK WITH BUSHING RADIATORS, FITTINGS & ACCESSORIES		
13.0	<u>OPTIONAL FITTINGS REQUIRED</u>		
13.1	DIAL TYPE THERMOMETER WITH TWO CONTACTS FOR OIL TEMP. AS PER CLAUSE 7.1 OF SECTION-D	YES/NO	YES
13.2	MAGNETIC OIL LEVEL GAUGE WITH LOW OIL LEVEL ALARM CONTACT AS PER CLAUSE 7.2 OF SECTION D	YES/NO	YES
13.3	GAS AND OIL ACTUATED (I.E.BUCHHOLZ) RELAY	YES/NO	YES
13.4	GAS SAMPLING DEVICE AS PER CLAUSE 7.4 OF SECTION-D	YES/NO	YES
13.5	WINDING TEMPERATURE INDICATOR AS PER CLAUSE 7.5 OF SECTION-D	YES/NO	YES
13.6	ONLOAD TAP CHANGING MECHANISM AS PER CLAUSE	YES/NO	YES

	7.6 OF SECTION-D		
13.7	VALVES PER CLAUSE 7.7 OF SECTION-D	YES/NO	YES
13.8	FOUR PLAIN ROLLERS IN PLACE OF FIXING CHANNELS	YES/NO	YES
14.0	<u>EVALUATION & PENALTY</u>		
14.1	FORMULA FOR EVALUATION OF BIDS		
14.2	RATES OF PENALTY FOR EXCEEDING THE GUARANTEED LOSSES		
15.0	<u>NOTES</u>		
16.0	<u>ESSENTIAL SPARES</u>		
16.1	COMPLETE SET OF GASKETS		
16.2	BUSHING OF EACH TYPE		
16.3	CT OF EACH TYPE		
16.4	DIAL TYPE THERMOMETER		
16.5	OIL LEVEL GAUGE		
16.6	COMPLETE SET OF WINDING TEMPERATURE INDICATING EQUIPMENT		
16.7	EXPLOSION VENT DIAPHRAGMS		
16.8	SILICA-GEL BREATHER		
16.9	BUCHHOLZ RELAY OR FAULT PRESSURE RELAY		
16.10	ONE VALVE OF EACH TYPE		
	NOTES:		
	1. ITEMS TICK MARKED TO BE PROVIDED.		
	2. RECOMMENDED QUANTITIES AND UNIT PRICES TO BE INDICATED BY THE BIDDER IN HIS QUOTATIONS.		

5.10. DATA SHEET A2 DISTRIBUTION TRANSFORMER

1.0	<u>APPLICABLE STANDARDS</u>		
1.1	POWER TRANSFORMER		IS:2026, BS:171 IEC 176
1.2	FITTINGS AND ACCESSORIES		IS:3639, BS: IEC
1.3	DISTRIBUTION TRANSFORMER		IS:1180, BS: IEC
1.4	LOADING OF OIL IMMERSED TRANSFORMER		IS:6600, BS:CP:1010 IEC 354
1.5	OIL		IS:335, BS: 148 IEC:296
1.6	BUSHING FOR > 1000 V, AC		IS:2099, BS: 223 IEC:137
1.7	BUSHING FOR ≤ 1000 V, AC		IS:7421, BS: IEC
1.8	DEGREE OF PROTECTION		IS:13947, BS: IEC:144
1.9	TESTS & TOLERANCES ON GUARANTEED PARTICULARS		IS:2026, BS:171 IEC:176
1.10	BUCHHOLZ RELAY		IS:3637, BS: IEC
1.11	ELECTRICAL INSULATION CLASSIFIED BY THERMAL STABILITY		IS:3637, BS: IEC
1.12	CLIMATE PROOFING		IS:3202, BS: 1014 IEC
2.0	<u>NOTES</u>		
2.1	EQUIPMENT, ACCESSORIES, COMPONENTS /PARTS RAW MATERIALS AND TESTS SHALL IN GENERAL CONFORM TO IS BS IEC		

5.11. DATA SHEET A1 BUS DUCT

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
1.0	<u>DESIGN PARTICULARS</u>		
1.1	TYPE OF BUS DUCT		BUS DUCT - ALUMINUM (SANDWICH TYPE)
1.2	TYPE OF COOLING		AIR NATURAL COOLED
1.3	INSTALLATION INDOOR/OUTDOOR		BUS DUCT - INDOOR
1.4	NOMINAL SERVICE VOLTAGE	KV	0.433
1.5	RATED VOLTAGE CLASS	KV	1.1
1.6	CONTINUOUS CURRENT RATING OF BUS DUCTS UNDER SITE CONDITIONS	A	3200
1.7	BASIC IMPULSE INSULATION LEVEL (1.2 X 50 MICRO SECOND WAVE)	KV (PEAK)	-
1.8	ONE MINUTE POWER FREQUENCY WITHSTAND VOLTAGE	KV (PEAK)	2.5KV
1.9	MOMENTARY CURRENT RATING	KA (PEAK)	125KA FOR 1 SEC
1.10	SHORT TIME CURRENT RATING FOR ONE SECOND	KA (RMS)	50
1.11	DESIGN MAXIMUM TEMPERATURE (HOT SPOT) OF BUSBARS AT RATED CURRENT (a) PLAIN JOINT (b) SILVER PLATED JOINTS	°C	80 DEG C

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
1.12	DESIGN MAXIMUM TEMPERATURE (HOT SPOT) OF ENCLOSURE AT RATED CURRENT	°C	70 DEG C
1.13	BUSBAR MATERIAL		ALUMINUM
1.14	BUSBAR SECTION	SQ.MM.	BY BIDDER
1.15	BUS ENCLOSURE MATERIAL & THICKNESS	MM	2MM THICK- G I/ EXTRUDED ALUMINUM
1.16	SHAPE OF ENCLOSURE		BY BIDDER
1.17	MATERIAL OF PHASE BARRIERS & THICKNESS		BY BIDDER
1.18	PHASE CLEARANCE (MINIMUM) - PHASE TO PHASE - PHASE TO EARTH	MM	SHALL WITHSTAND POWER FREQUENCY VOLTAGE WITHOUT BREAKDOWN
1.19	TYPE OF JOINTS BETWEEN ADJACENT SECTIONS OF BUS CONDUCTOR WELDED/BOLTED		BOLTED
2.0	<u>INSULATORS AND SEAL OFF BUSHING</u>		
2.1	RATED VOLTAGE	KV	0.433
2.2	<u>ONE MINUTE POWER FREQUENCY WITHSTAND VOLTAGE</u>		
2.2.1	DRY	KV (RMS)	2.5KV
2.2.2	WET	KV (RMS)	--
2.3	IMPULSE WITHSTAND VOLTAGE (1.2 X 50 MICRO-SECOND WAVE)	KV	--
2.4	MINIMUM CREEPAGE DISTANCE	MM	50

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
2.5	MATERIAL OF INSULATORS		EPOXY/ MULTILAYER POLYESTER
2.6	CURRENT RATING OF SEAL OF BUSHINGS	A	BY BIDDER
2.7	MATERIAL OF SEAL OFF BUSHINGS		BY BIDDER
2.8	END CABLE TAP BOX		REFER SLD DWG NO. TCE-10106A-4000-AU-40077
2.9	PHASE TRANSPOSITION CHAMBER		BY BIDDER
2.10	NEUTRAL BUS		REFER SLD DWG NO. TCE-10106A-4000-AU-40077
3.0	<u>LINKS</u>		BY BIDDER
3.1	<u>DISCONNECTING LINKS</u>		
3.1.1	QUANTITY		
3.1.2	RATED CURRENT	A	
3.1.3	REFERENCE DWGS.		
3.2	<u>SHORTING LINKS</u>		
3.2.1	LOCATION		
4.0	<u>BUS DUCTS TENTATIVE LENGTH</u>		
4.1	BUS DUCT LENGTH.	M	
4.2	90° BEND		
4.3	TEES		
4.4	NO. OF TERMINATIONS		

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
5.0	<u>GENERAL</u>		
5.1	<u>EARTHING CONDUCTOR</u>		
5.1.1	MATERIAL SIZE		GL. SUITABLE FOR 50KA.
5.2	<u>FINISH OF BUS ENCLOSURE</u>		
5.2.1	EXTERIOR		-
5.2.2	INTERIOR		-
5.3	LAYOUT DRAWING REFERENCE NO.		-
5.4	RAIN HOOD REQUIRED	YES/NO	NO
6.0	<u>TESTS</u>		
6.1	ROUTINE TEST		AS PER STANDARDS IN DATA SHEET A2
6.2	ACCEPTANCE TESTS		WATER AND AIR TIGHTNESS
6.3	TYPE TESTS		TEST CERTIFICATES ON SIMILAR UNITS FOR TYPE TEST AS PER STANDARD IN DATA SHEET-A SHOULD BE FURNISHED.(NOT OLDER THAN THREE YEARS)
6.4	TESTS ON COMPONENTS SUCH AS INSULATORS, SEAL-OFF BUSHINGS, BOLTED AND FLEXIBLE JOINTS, BUSBARS, ENCLOSURE MATERIAL, GALVANIZING OF SUPPORTING STRUCTURES, CTS, VTS AND FUSES		TYPE AND ROUTINE TEST CERTIFICATES SHOULD BE FURNISHED.
7.0	<u>START-UP AND ESSENTIAL SPARES</u>		

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
7.1	BUS SUPPORT INSULATORS	NOS.	ONE SET
7.2	FLEXIBLE CONNECTOR	NOS.	ONE SET OF EACH TYPE/ SIZE (LENGTH)
7.3	ISOLATING LINK	NOS.	ONE SET
7.4	SEAL-OFF BUSHING	NOS.	--
7.5	FUSES	NOS.	--
7.6	DRAIN PLUGS	NOS.	--
7.7	GASKETS	NOS.	THREE SETS OF EACH TYPE.
7.8	CLAMPS	NOS.	SIX
	<u>NOTES</u> :		
	1. ITEMS TICK-MARKED TO BE PROVIDED 2. RECOMMENDED QUANTITIES AND UNIT PRICES TO BE INDICATED BY THE BIDDER IN HIS QUOTATIONS IN RESPECTIVE SCHEDULE.		

5.12. DATA SHEET A2 DISTRIBUTION TRANSFORMER

SL. NO.	ITEM	
1.0	<u>APPLICABLE STANDARDS</u>	
1.1	Bus Conductor material	<input checked="" type="checkbox"/> IS 5082 <input type="checkbox"/> BS 159 <input type="checkbox"/> IEC 60105
1.2	Water and Air Tightness tests	<input checked="" type="checkbox"/> IS 8084
1.3	Current Transformer	<input type="checkbox"/> IS 2705 <input type="checkbox"/> BS 7626 <input type="checkbox"/> IEC 60044
1.4	Voltage Transformers	<input type="checkbox"/> IS 3156 <input type="checkbox"/> BS 7625 <input type="checkbox"/> IEC 60186
1.5	HV Porcelain Bushing	<input type="checkbox"/> IS 2099 <input type="checkbox"/> IEC 60137 <input type="checkbox"/> BSEN 60137
1.6	Porcelain Post Insulators	<input type="checkbox"/> IS 2544 <input type="checkbox"/> BS 3297 (Part I & II) <input type="checkbox"/> IEC 60168 <input type="checkbox"/> BSEN 60168
1.7	Reactor	<input type="checkbox"/> IS 5553 <input type="checkbox"/> IEC 60289 <input type="checkbox"/> BSEN 60289
1.8	Hot Dip Galvanizing	<input checked="" type="checkbox"/> IS 2629 & 2633 <input type="checkbox"/> BS 729
1.9	Interconnecting Bus Bars for A.C. Voltage above 1 kV upto and including 36 kV	<input type="checkbox"/> IS 8084
1.10	Fuses	<input type="checkbox"/> IS 13703, 9385, 2692 & 88 <input type="checkbox"/> IEC 60269 & 60282
2.0	<u>NOTES</u>	
2.1	Equipment, Accessories, Component Parts, Raw Materials and Tests shall in General Confirm to <input checked="" type="checkbox"/> IS <input type="checkbox"/> BS <input type="checkbox"/> IEC	

5.13. DATA SHEET A1 XLPE INSULATED H.V. POWER CABLES

1.0 GENERAL REQUIREMENTS

TCE Group Desig- nation	Voltage Grade	No.of Cores	Conductor A/C	Armour W/F/AW/AS	Remarks
A3/1	1.9 / 3.3 kV	Three	___NA___	___NA___	
A3/2	1.9 / 3.3 kV	Single	___NA___	___NA___	
A3/3	3.8 / 6.6 kV	Three	___NA___	___NA___	
A3/4	3.8 / 6.6 kV	Single	___NA___	___NA___	
A3/5	6.35/ 11 kV	Three	___NA___	___NA___	
A3/6	6.35/ 11 kV	Single	___NA___	___NA___	
A3/7	11 / 11 kV	Three	___NA___	___NA___	
A3/8	11 / 11 kV	Single	___NA___	___NA___	
A3/9	12.7/ 22 kV	Three	___NA___	___NA___	
A3/10	12.7/ 22 kV	Single	___NA___	___NA___	
A3/11	19 / 33 kV	Three	<u>ALUMINIUM GALVANISED STEEL DOUBLE STRIP ARMOURING</u>		
A3/12	19 / 33 kV	Single	___NA___	___NA___	

2.0 SYSTEM DETAILS

2.1 Nominal Power System Voltage kV 33

2.2 Maximum System Voltage for
continuous operation kV 36

2.3 System Neutral Earthing UE/E E

2.4 Design ambient air temperature °C 50

3.0 FRLS PVC outer sheath required ☒ YES ☐ NO

4.0 NOTES

5.14. DATA SHEET A1 1100V XLPE POWER CABLES

1.0 GENERAL REQUIREMENTS (POWER CABLES)

TCE Group Desig- nation	Voltage Grade	Core A/C	Conductor W/F/AW/AS	Armour	Remarks
A4/1	1100	Multi	___Cu___	___W___	UPTO & INCLUDING 6sq.mm
A4/2	1100	Single	___Cu___	___W___	UPTO & INCLUDING 6sq.mm
A4/3	1100	Multi	___Al___	___W___	UPTO & INCLUDING 16sq.mm
A4/4	1100	Single	___Al___	___W___	UPTO & INCLUDING 16sq.mm
A4/5	1100	Multi	___NA_____	___NA_____	
A4/6	1100	Single	___NA_____	___NA_____	
A4/7	1100	Multi	___NA_____	___NA_____	
A4/8	1100	Single	___NA_____	___NA_____	
A4/9	1100	Multi	___NA_____	___NA_____	
A4/10	1100	Single	___NA_____	___NA_____	

2.0 SYSTEM DETAILS

2.1 Nominal Power System Voltage kV 0.415

2.2 Maximum System Voltage for
continuous operation kV 0.457

2.3 System Neutral Earthing UE/E E

2.4 Design ambient air temperature °C 50

3.0 FRLS PVC outer sheath required ☒ YES ☐ ~~NO~~

4.0 NOTES

5.15. 1100V PVC INSULATED CONTROL CABLES

1.0 GENERAL REQUIREMENTS

TCE Group Designation	Cores	Copper Conductor Area, sq.mm (No. of strands/dia)	Armour W/F	Remarks
-----------------------	-------	---	------------	---------

A2/1	Multi upto 10 C	1.5 (7 / 0.5)	W	
------	-----------------	---------------	---	--

A2/2	Multi upto 10 C	1.5 (7 / 0.5)	X	
------	-----------------	---------------	---	--

A2/3	Multi > 10 C	1.5 (7 / 0.5)	F	
------	--------------	---------------	---	--

A2/4	Multi > 10 C	1.5 (7 / 0.5)	X	
------	--------------	---------------	---	--

A2/5	Multi upto 7 C	2.5 (7 / 0.67)	W	
------	----------------	----------------	---	--

A2/6	Multi upto 7 C	2.5 (7 / 0.67)	X	
------	----------------	----------------	---	--

A2/7	Multi > 7 C	2.5 (7 / 0.67)	F	
------	-------------	----------------	---	--

A2/8	Multi > 7 C	2.5 (7 / 0.67)	X	
------	-------------	----------------	---	--

A2/9	Multi > 7 C	4.0 (7 / 0.85)	W	
------	-------------	----------------	---	--

A2/10	Multi > 7 C	4.0 (7 / 0.85)	X	
-------	-------------	----------------	---	--

X Items not required

2.0 SYSTEM DETAILS

2.1 Nominal Power System Voltage kV 0.415

2.2 Maximum System Voltage for continuous operation kV 0.457

2.3 System Neutral Earthing UE/E E

2.4 Design ambient air temperature °C 50

3.0 FRLS PVC outer sheath required ☒ YES ☐ NO

4.0 NOTES

5.16. DATA SHEET A2 CABLING ACCESSORIES, CABLE TRAYS AND CONDUITS /
PIPES

1 CABLE TRAYS		1.1	HOT DIP GALVANISING	<input checked="" type="checkbox"/> IS: 2629
2 CABLE GLANDS		2.1	BRASS GLANDS FOR PVC CABLES	<input checked="" type="checkbox"/> IS: 12943 <input type="checkbox"/> BS: <input type="checkbox"/> IEC <input type="checkbox"/>
		2.2	FLAME-PROOF ENCLOSURES OF ELECTRICAL APPARATUS	<input checked="" type="checkbox"/> IS: 2148 <input type="checkbox"/> BS:4683 <input type="checkbox"/> <input type="checkbox"/>
3 LUGS		3.1	COMPRESSION TYPE TUBULAR TERMINAL ENDS	<input checked="" type="checkbox"/> IS:8309 <input type="checkbox"/> BS:4683 <input type="checkbox"/> IEC <input type="checkbox"/>
4 CONDUITS AND PIPES		4.1	RIGID STEEL CONDUITS	<input checked="" type="checkbox"/> IS:9537 <input type="checkbox"/> BS: <input type="checkbox"/>
		4.2	RIGID NON-METALLIC CONDUITS	<input checked="" type="checkbox"/> IS:9537 <input type="checkbox"/> BS: <input type="checkbox"/> <input type="checkbox"/>
		4.3	ACCESSORIES FOR RIGID STEEL CONDUITS	<input checked="" type="checkbox"/> IS:3837 <input type="checkbox"/> BS: <input type="checkbox"/> <input type="checkbox"/>
		4.4	FITTINGS FOR RIGID STEEL CONDUITS	<input checked="" type="checkbox"/> IS:2667 <input type="checkbox"/> BS: <input type="checkbox"/> <input type="checkbox"/>
		4.5	FITTINGS FOR RIGID NON-METALLIC CONDUITS	<input checked="" type="checkbox"/> IS:3419 <input type="checkbox"/> BS: <input type="checkbox"/> <input type="checkbox"/>
		4.6	FLEXIBLE STEEL CONDUITS	<input checked="" type="checkbox"/> IS:3480 <input type="checkbox"/> BS: <input type="checkbox"/> <input type="checkbox"/>
		4.7	FLEXIBLE NON-METALLIC CONDUITS	<input checked="" type="checkbox"/> IS:6946 <input type="checkbox"/> BS: <input type="checkbox"/> <input type="checkbox"/>
		4.8	ADAPTORS FOR FLEXIBLE STEEL CONDUITS	<input checked="" type="checkbox"/> IS:4649 <input type="checkbox"/> BS: <input type="checkbox"/> <input type="checkbox"/>
		4.9	MILD STEEL TUBES	<input checked="" type="checkbox"/> IS:1239 <input type="checkbox"/> BS: <input type="checkbox"/> <input type="checkbox"/>
5 POWER RECEPTACLES		5.1	PLUGS AND SOCKETS	<input checked="" type="checkbox"/> IS:1293 <input type="checkbox"/> BS: <input type="checkbox"/> IEC <input type="checkbox"/>
		5.2	SWITCHES AND DISCONNECTORS	<input checked="" type="checkbox"/> IS:13947 <input type="checkbox"/> BS: <input type="checkbox"/> IEC <input type="checkbox"/>
		5.3	BOXES FOR ENCLOSURE OF ELECTRICAL ACCESSORIES	<input checked="" type="checkbox"/> IS:5133 <input type="checkbox"/> BS: <input type="checkbox"/> IEC <input type="checkbox"/>

5.17. DATASHEET-A1 UPS SYSTEM

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
1.1	APPLICATION		FOR SUPPLY TO CRITICAL MACHINE LOAD , SERVERS& PC'S.
1.2	POWER RATING AT LOAD PF 0.8 LAGGING		200 KVA CONTINUOUS
1.3	QUANTITY (NOS.)		2 NOS
1.4	METHOD OF ENERGY STORAGE		BATTERY BACK -UP
1.5	TYPE		(a) — NON REDUNDANT — WITH STATIC BY PASS TO REGULATED SUPPLY (b) — PARALLEL — REDUNDANT WITHOUT BYPASS (c) PARALLEL REDUNDANT WITH STATIC BY PASS TO REGULATED SUPPLY
1.6	INSTALLATION		INDOOR , NORMAL VENTILATION
1.7	AMBIENT TEMPERATURE ($^{\circ}\text{C}$)		50 $^{\circ}$ C
1.8	RELATIVE HUMIDITY		UPTO 95% NON CONDENSING
2.0	ENCLOSURE		
2.1	SHEET STEEL THICKNESS		2MM, CRCA FOR DOORS AND 1.6MM CRCA FOR SIDE COVERS
2.2	DEGREE OF PROTECTION AS PER IS-13947		IP42 IF LOCATED IN NON-AIR CONDITIONED AREA /IP31 IF LOCATED IN AIR-CONDITIONED

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
			AREA.
2.3	PAINTING		
	EXTERIOR		RAL 7032/ 631 LIGHT GREY SEMI GLOSSY SHADE
	- INTERIOR		GLOSSY WHITE
2.4	CABLE ENTRY		BOTTOM / TOP
2.5	ACOUSTIC NOISE LEVEL MEASURED AT A DISTANCE OF 1M		60 – 65 DBA UPTO 120KVA 65 – 75DBA ABOVE 120KVA
2.6	SPACE HEATER, 240V, 1 PH		REQUIRED / NOT REQUIRED
3.0	UPS SYSTEM		
3.1	INPUT		
3.1.1	SUPPLY VOLTAGE		415 V, 3 PH, 3 W, 50 HZ AC NON-EFFECTIVELY EARTHED / EFFECTIVELY EARTHED.
3.1.2	ALLOWABLE VARIATION		
	(a) VOLTAGE		$\pm 10\%$
	(b) FREQUENCY		$\pm 5\%$
	(c) COMBINED VOLTAGE + FREQUENCY		<u>10%</u>
3.1.3	HARMONIC CONTENT (INPUT)		<u><5%</u>
3.2	OUTPUT		
3.2.1	OUTPUT VOLTAGE		110V.1 PH, 240 V, 1 PH, 415 V, 3 PH, 4

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
			W
3.2.2	AC VOLTAGE ACCURACY (STEADY STATE) OVER ENTIRE LOAD, LOAD PF & DC VOLTAGE RANGE.		$\pm 2\%$ FOR BALANCED LOAD
3.2.3	TRANSIENT VOLTAGE REGULATION		8% AT 100% LOAD STEP
3.2.4	TRANSIENT RECOVERY		RETURN TO STEADY STATE CONDITION WITHIN 50 MS AFTER DISTURBANCE.
3.2.5	VOLTAGE WAVE FROM		SINUSOIDAL
3.2.6	RANGE OF ADJUSTMENT OF AC OUTPUT VOLTAGE		$\pm 5\%$ AT RATED LOAD
3.2.7	AC HARMONIC CONTENT (THD-VOLTAGE)		AS PER IEEE 519
3.2.8	PHASE DISPLACEMENT FOR THREE PHASE OUTPUT		$120^\circ \pm 1^\circ$ FOR BALANCE LOAD $120^\circ \pm 3^\circ$ FOR 20% UNBALANCED LOAD.
3.2.9	NOMINAL FREQUENCY		50 HZ
3.2.10	FREQUENCY REGULATION (WITHOUT STATIC BY-PASS SOURCE)		$\pm 0.1\%$
3.2.11	FREQUENCY REGULATION (WITH STATIC BY-PASS SOURCE)		± 2 HZ
3.3	AC STANDBY SUPPLY		

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
3.3.1	(a) SERVO CONTROLLED VOLTAGE STABILIZER (SCVS)		REQUIRED /NOT REQUIRED
	(b) RATING		TO MATCH UPS CONTINUOUS RATING
	(B) OVERLOAD CAPACITY		10 TIMES RATED CURRENT FOR 100MS
	(C) INPUT VOLTAGE PHASE & FREQUENCY		415V \pm 10% 3 PH 3 WIRE 50 HZ
	(D) PERCENTAGE VOLTAGE REGULATION		+ 2%
	(e) SPIKE BUSTERS / SURGE SUPPRESSORS AND INPUT FILTERS		REQUIRED /NOT REQUIRED
3.3.2	ISOLATION TRANSFORMER		
	(a) RATING		REQUIRED
	(b) INPUT VOLTAGE PHASE & FREQUENCY		
3.4	MAINTENANCE BY PASS SWITCH		REQUIRED /NOT REQUIRED
4.0	RECTIFIER		
4.1	PARALLEL OPERATION		REQUIRED /NOT REQUIRED
4.2	RECHARGE TIME ON BATTERY BOOST CHARGE		AS PER BATTERY MANUFACTURERS RECOMMENDATION

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
5.0	INVERTER		
5.1	OVERLOAD CAPACITY		125% FOR 10 MIN.
			150% FOR 1MIN
			300% FOR 4 MILLI SECONDS
5.2	SYNCHRONISING		
	- BETWEEN INVERTERS		REQUIRED/ NOT REQUIRED
	- BETWEEN INVERTERS AND STANDBY SUPPLY		REQUIRED/ NOT REQUIRED
5.3	PARALLEL OPERATION		REQUIRED/ NOT REQUIRED
5.4	SYNCHRONISING RANGE		50 ± 3 HZ(ADJUSTABLE)
6.0	STATIC SWITCH		
6.1	MAXIMUM TRANSFER TIME		5MS (1/4 CYCLE)
6.2	SHORT TIME CURRENT RATING		1000% FOR 10 MILLI SECONDS
7.0	CIRCUIT BREAKER & LOAD BREAK SWITCHES		
7.1	TYPE		ACB /MCCB

5.18. DATASHEET-A2 UPS SYSTEM

1.	UPS		IEC - 62040 (PART-III)
2.	BASIC CLIMATIC & MECHANICAL DURABILITY TESTS FOR COMPONENTS FOR ELECTRONIC AND ELECTRICAL EQUIPMENT		IS 9000
3.	ENVIRONMENTAL TESTS FOR ELECTRONIC & ELECTRICAL EQUIPMENT		IS 9000
4.	TRANSFORMER AND INDUCTORS (POWER, AUDIO, PULSE & SWITCHING) FOR ELECTRONIC EQUIPMENT		IS 6297
5.	PRINTED WIRING BOARDS		IS 7405
6.	ENVIRONMENTAL REQUIREMENTS FOR SEMICONDUCTOR DEVICES AND INTEGRATED CIRCUITS		IS 6553
7.	TERMINALS FOR ELECTRONIC EQUIPMENT		IS 4007
8.	HRC CARTRIDGE FUSES		IS 9224/IEC 60269.1
9.	INDICATING INSTRUMENTS		IS 1248/IEC 60051
10.	DEGREE OF PROTECTION		IS 13947/IEC60 947-1
11.	SEMICONDUCTOR CONVERTERS		IEC 60146
12.	SEMICONDUCTOR RECTIFIER		IS 6619

	EQUIPMENT CODE		
13.	THYRISTOR CONVERTERS		IS 5082
14.	EMERGENCY STD BY POWER SYSTEMS		IEEE 446
15.	SEALED LEAD ACID CELLS		IEC 60896-2
16.	VENTED TYPE NI-CD BATTERIES		IEC 60623
17.	STATIONARY CELLS OF BATTERIES LEAD ACID TYPE		
18.	(A) TABULAR PLATE		IEC 60896-1
19.	(B) PLANTE PLATE		IEC 60896-1
20.	IEEE RECOMMENDED PRACTICE FOR SIZING NI-CD BATTERIES FOR STATIONARY APPLICATION.		IEEE 1115
21.	1100V CABLES		IS 1554
22.	SURGE WITHSTAND CAPABILITY TEST IN ACCORDANCE WITH		IEC 60255-5
23.	HARMONIC LEVELS		IEEE-519
	SPARE LIST		
1.	<u>MCB/MCCB OF EACH RATING</u>		ONE SET
2.	SEMICONDUCTOR FUSES OF EACH RATING		TWO SETS
3.	CONTROL CARDS		ONE SET

5.	THYRISTORS / POWER TRANSISTORS OF EACH RATING		ONE SET
6.	POWER DIODES OF EACH RATING		ONE SET
7.	AUXILIARY RELAYS & POWER CONTACTORS OF EACH TYPE.		ONE SET
8.	FILTER CAPACITORS		ONE SET
9.	FILTER CHOKE		ONE SET

5.19. DATASHEET-A1 LEAD ACID BATTERY

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
A	GENERAL		
1.	APPLICATION		UPS
2.	TYPE OF BATTERY		VRLA
3.	NOMINAL VOLTAGE	V	230
4.	BATTERY CAPACITY	AH	BY BIDDER
5.	NUMBER OF BATTERY BANKS REQUIRED	NO.	1
6.	NUMBER OF CELLS (APPROXIMATE)	NO.	BY BIDDER
7.	TEMPERATURE		
8.	MIN. TEMP.	⁰ C	5
9.	DESIGN AMBIENT TEMPERATURE	⁰ C	50
B	RATING		
10.	DESIGN MARGIN	%	10
11.	AGEING FACTOR		BY BIDDER
12.	DC SYSTEM VOLTAGE AT DC BUS OF THE SWITCHBOARD.		
a. A	NORMAL	V	BY BIDDER
b.	MAXIMUM	V	BY BIDDER
c.	MINIMUM	V	BY BIDDER

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
13.	END CELL VOLTAGE (VOLTS/CELL)	(V/CELL)	1.85
C	DISCHARGE DUTY		
14.	AMPERE HOUR CAPACITY OF BATTERY AT MIN. TEMPERATURE, 10 HOUR RATE TO GIVE FINAL END CELL VOLTAGE	C10	10
15.	SKETCH NO. SHOWING LOAD DUTY CYCLE DIAGRAM		BY BIDDER
D	LAYOUT AND CONSTRUCTION		
16.	TENTATIVE SIZE OF CABLES TO CONNECT BATTERY TO EXTERNAL CIRCUIT		
a.	TYPE		BY BIDDER
b.	SIZE	MM ²	BY BIDDER
17.	AVAILABLE AREA IN BATTERY ROOM (L X B)	MM X MM	REFER TENDER DRAWING
18.	LAYOUT DRG. NO. (IF ANY)		BY BIDDER
19.	MOUNTING ARRANGEMENT		MULTI TIER
20.	WHETHER METALLIC STANDS TO BE DESIGNED FOR SEISMIC FORCE	YES/NO	YES

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
a.	IF YES, SEISMIC ZONE		GRADE 3
21.	TYPE OF BATTERY CELL CONTAINER		BY BIDDER
22.	BMS TO BE SUPPLIED	YES/NO	YES
E	MISCELLANEOUS		
23.	TAPPED CELL ARRANGEMENT FOR FLOAT CUM BOOST CHARGING ARRANGEMENT.	<i>1.1.a.i.1.1.1.1</i>	REQUIRED

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
24.	DROPPER DIODE ARRANGEMENT FOR FLOAT CUM BOOST CHARGING ARRANGEMENT.	<i>1.1.a.i.1.1.1.1</i>	REQUIRED
25.	SPARES		

SL. NO.	ITEM	UNIT	TECHNICAL PARTICULARS
a.	INTER-CELL / INTER-ROW/ INTER-BANK / CONNECTORS	NOS.	20% OF TOTAL QUANTITY.
b.	NUTS, BOLTS, WASHERS ETC	NOS.	20% OF TOTAL QUANTITY.

5.20. DATASHEET-A2 LEAD ACID BATTERY

1.\	GENERAL REQUIREMENT AND METHOD OF TESTS STATIONARY LEAD ACID BATTERIES -		
a)	WITH TUBULAR POSITIVE PLATE		IS 1651 IEC- 60896
B)	WITH PLANTE POSITIVE PLATE		IS 1652 IEC- 60896
2.	WATER FOR STORAGE BATTERY		IS: 1069
3.	SULPHURIC ACID		IS: 266
4.	RUBBER AND PLASTIC CONTAINERS FOR LEAD ACID STORAGE BATTERY		IS: 1146
5.	SEALING COMPOUND FOR LEAD ACID BATTERIES (BITUMEN BASED)		IS: 3116
6.	SYNTHETIC SEPARATOR FOR LEAD ACID BATTERIES		IS: 6071
7.	GENERAL REQUIREMENTS AND METHODS OF TEST FOR LEAD ACID STORAGE BATTERIES		IS: 8320
8.	RECOMMENDED PRACTICE FOR SIZING LARGE LEAD ACID STORAGE BATTERIES FOR GENERATING STATIONS AND SUBSTATIONS		IEEE: 485
9.	CONTAINERS & VENT PLUGS		UL : 994
10.	BATTERY ENCLOSURES		UL : 1778
11.	RECOMMENDED PRACTICE FOR DESIGN AND INSTALLATION OF VENTED LEAD ACID BATTERIES.		IEEE-484

5.21. DATASHEET-A1 LIGHTING

1.0	GENERAL		
1.1	NORMAL SUPPLY VOLTAGE, PHASE AND FREQUENCY	AC DC	230V,1PH , 50HZ
1.2	VARIATION IN SUPPLY		
	A) VOLTAGE	%	± 10%
	B) FREQUENCY	%	± 3%
	C) COMBINED VOLTAGE & FREQUENCY	%	± 10%
1.3	DESIGN AMBIENT AIR TEMPERATURE	°C	50 °C
1.4	LUMINAIRE TERMINAL SUITABLE FOR		3C X 2.5 SQ.MM CU CONDUCTOR PVC INSULATION
1.4.1	INDOOR NON HAZARDOUS AREA		
	A) CONDUCTOR MATERIAL		XLPE CU , FRLS
	B) WIRE SIZE	CORES X SQ.MM	2R/C X 2.5 +1R X 1.5 SQ.MM CU.WIRE (HFFR) FOR INDOOR
1.4.2	INDOOR HAZARDOUS / OUTDOOR AREA		
	A) CONDUCTOR MATERIAL		XLPE CU , FRLS
	B) CABLE SIZE	CORES X SQ.MM	4C X16 SQ.MM CABLE (FRLS) FOR OUTDOOR. 3C X 2.5SQ.MM CABLE (FRLS) FOR DG YARD AREA.
1.5	LUMINAIRE EARTHING TERMINAL SUITABLE FOR		
	A) CONDUCTOR MATERIAL		GI CU

	B) CONDUCTOR SIZE	SWG	8/ 12 SWG GI / 2.5SQ.MM CU

5.22. DATASHEET-A1 LED LUMINAIRES

SL. NO.	TECHNICAL PARAMETERS	SPECIFIC REQUIREMENT
1	LIGHT SOURCE	HIGH POWER LED
2	MAKE OF LED LAMPS	OSRAM / PHILIPS / LUMILED / CREE/ NICHIA
3	LIGHTING DISTRIBUTION TYPE	CUT OFF/ SEMI CUT OFF TYPE AS PER IESNA TYPE II/ III LIGHTING DISTRIBUTION.
4	LUMINARY EFFICACY	>100 LM/W +/- 5 %
5	OPERATING VOLTAGE RANGE	140- 280V
6	OPERATING VOLTAGE	230V $\pm 10\%$
8	OPERATING FREQUENCY	50 HZ +/- 3% HZ
9	TOTAL HARMONIC DISTORTION	CURRENT < 15%; VOLTAGE < 5%
10	POWER FACTOR	≥ 0.95
11	OPERATING CURRENT	<700 MA
12	USAGE HOURS	DUSK TO DAWN (12 HOURS)
13	AUDIBLE NOISE	SHALL HAVE CLASS-A SOUND RATING WITH AUDIBLE NOISE IN POWER SUPPLY
14	BEAM ANGLE	120 DEGREES (MINIMUM)
15	LIFE SPAN	50000 BURNING HOURS WITH 80% LUMEN MAINTENANCE
16	COLOR TEMPERATURE	5500 - 6000K (SUITABLE FOR “COOL WHITE” LIGHT)

17	COLOR RENDERING INDEX (CRI)	MIN. 70
18	UNIFORMITY RATIO (EMIN/ EAVG)	60%
19	TRANSVERSE UNIFORMITY RATIO (EMIN/EMAX)	40%
20	INGRESS PROTECTION	IP 66 FOR STREET LIGHTING
	DRIVER:	
21	DRIVER EFFICIENCY	>90%
22	OPTICAL EFFICIENCY	> 95%
23	P/N JUNCTION TEMPERATURE	<100 DEGREES C AT JUNCTION POINT AND <60 AT HEAT SINK.
24	SURGE IMMUNITY LEVEL	4.5 KV
25	EARTHING	DRIVER UNIT SHALL HAVE PROVISION FOR PROPER GROUNDING
26	SHORT CIRCUIT PROTECTION	RECOVERS AUTOMATICALLY AFTER FAULT CONDITION IS REMOVED.
27	OVER VOLTAGE PROTECTION	SHOULD BE ABLE TO WITHSTAND 320V FOR MINIMUM 24 HOURS

28	HIGH – LOW VOLTAGE CUTOFF	IN SIDE LUMINARY OR A DEVICE TO BE INSTALLED ON THE POLE IN AN IP PROTECTED BOX SUSTAINING 270V FOR HIGHER SIDE CUTOFF & 140 V ON LOWER SIDE CUTOFF-BEYOND& BELOW IT SHUT DOWN & RESTORE NORMAL WORKING CONDITION WHEN VOLTAGE
29	HOUSING WITH SUPPLIER WORD MARK / NAME	ENGRAVED / EMBOSSING ON THE DIE CAST HOUSING/ BODY PART
30	CONNECTING WIRES & CABLES USED	FRLS THREE CORE COPPER WIRE OF 2.5 MTR OUTSIDE LUMINARIE
31	IMPACT RESISTANCE OF COMPLETE LUMINARIE	IK 05 OR ABOVE
32	REPLACEMENT GUARANTEE OF COMPLETE LUMINARY	5 YEARS AGAINST ANY DEFECTS/FAULTS (IN CASE OF LUMEN DEPRECIATION BEYOND LIMIT OF L70, NON-WORKING ANY LED, DISCOLORATION IN LENS OR GLASS OR POLYCARBONATE COVER RESULTING INTO DEPRECIATION IN LUX LEVEL WITH RESPECT TO L70)
33	FINISH	AESTHETICALLY DESIGNED HOUSING WITH POWDER COATED CORROSION RESISTANT HOUSING
34	WORKING TEMPERATURE	-20 DEGREE TO 50 DEGREE
35	WORKING HUMIDITY	10% TO 90% RH

36	HOUSING	THE FIXTURE SHOULD COMPRISE OF A TOP CANOPY MADE OF DI-CAST HIGH PRESSURE ALUMINUM ALLOY OF ADEQUATE THICKNESS AND A LOWER PART COMPRISES OF UV RESISTANT ACRYLIC BOWL TOP FROSTED FOR VISUAL COMFORT
37	CONSTRUCTION	LED'S ARE MOUNTED ON A CIRCULAR/ ARRAY MCPCB WHICH IS THERMALLY GLUED TO AN ALUMINUM SHEET PROVIDED WITH ALUMINUM FINS FIRMLY CONNECTED TO THE HOUSING FOR EXCELLENT HEAT DISSIPATION.

DATASHEET-B
TO BE FILLED BY BIDDER

5.23. DATASHEET-B HIGH VOLTAGE METAL ENCLOSED SWITCHGEAR

SR.NO.	ITEM	UNIT	
1.0	GENERAL	–	
1.1	MANUFACTURER'S NAME	–	
1.2	APPLICABLE STANDARD (S)	–	
1.3	TYPE OF CIRCUIT BREAKER	–	<input type="checkbox"/> VACUUM <input type="checkbox"/> SF 6
1.4	NOMINAL SYSTEM VOLTAGE	kV	
1.5	MAXIMUM CONTINUOUS VOLTAGE	kV	
1.6	POWER FREQUENCY WITHSTAND (ONE MINUTE) VOLTAGE	kV	
1.7	A) SHORT CIRCUIT WITHSTAND	kV (rms)	
	B) MOMENTARY WITHSTAND	kV (peak)	
1.8	IMPULSE 1.2/50 μ SEC WITHSTAND VOLTAGE	kV (peak)	
1.9	TYPE TEST REPORT	–	<input type="checkbox"/> ENCLOSED <input type="checkbox"/> NOT ENCLOSED
2.0	COMPLIANCE WITH SPECIFICATION	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, DEVIATION ATTACHED
3.0	CONSTRUCTIONAL FEATURES	–	
3.1	DIMENSIONS	–	
	a) SWITCHGEAR CUBICLE	–	Dmm Lx Wx
	b) ADAPTER PANEL	–	Dmm Lx Wx
	c) OVERALL BASED ON (a) & (b)	–	Dmm Lx Wx
3.2	MINIMUM CLEAR. REQUIRED	Mm	Front : mm, Rear : mm

3.3.1	CUBICLE WEIGHT WITH CIRCUIT BREAKER	Kg.	
3.3.2	TOTAL SWITCHGEAR WEIGHT	Kg.	
3.4	DYNAMIC LOADING PER CUBICLE	Kg.	
3.5	PAINTING SPECIFICATION	–	<input type="checkbox"/> ENAMEL <input type="checkbox"/> EPOXY <input type="checkbox"/> POWDER COATED
4.0	BUSBARS	–	
4.1	MATERIAL	–	<input type="checkbox"/> COPPER <input type="checkbox"/> AL-ALLOY
4.2	APPLICABLE STANDARD	–	
4.3	BUSBAR INSULATION	–	
4.4	STANDARD TO WHICH THE BUSBAR ARRANGEMENT CONFORMS	–	
4.5	MINIMUM CLEARANCE :	–	
	A) PHASE TO PHASE	Mm	
	B) PHASE TO EARTH	Mm	
5.0	CIRCUIT BREAKERS	–	COMPLIANCE WITH SPEC. <input type="checkbox"/> YES <input type="checkbox"/> NO, DEVIATIONS ATTACHED
5.1	FEEDER RATINGS	Amps	AS PER SPEC. <input type="checkbox"/> YES <input type="checkbox"/> NO DETAIL ATTACHED
5.2	SWITCHING OVERVOLTAGE	–	
	a) SWITCHING OFF MOTOR RUNNING AT NO LOAD	P.U./ms	
	b) SWITCHING OFF MOTOR WITH ITS ROTOR LOCKED	-----DO-----	
	c) SWITCHING OFF MOTOR RUNNING AT FULL LOAD	-----DO-----	
	d) SWITCHING OFF UNLOADED TRANSFORMER	-----DO-----	Amps

5.2.1	MAXIMUM PERMISSIBLE CHOPPING CURRENT.	—	
5.3	EXTERNAL SWITCHING OVERVOLTAGE LIMITINGS DEVICES REQUIRED	—	<input type="checkbox"/> YES <input type="checkbox"/> NO
5.3.1	DETAILS OF VOLTAGE LIMITING DEVICE :	—	
	a) TYPE	—	
	b) RATED VOLTAGE	—	Volts
	c) CONTINUOUS WITHSTAND VOLTAGE BETWEEN LINE AND EARTH	—	Volts
	d) RESIDUAL VOLTAGE AT DISCHARGE CURRENT OF	—	
	- 100 A	—	Volts
	- 500 A	—	Volts
	- 1000 A	—	Volts
5.4	MAIN CONTACTS :		
	a) TYPE	—	
	b) MATERIAL	—	
	c) SILVER FACING PROCESS	—	
	d) THICKNESS OF THE FACING	MICRON	
	e) DESIGN CONTACT PRESSURE	KG./Sq.cm	
5.5	ARCING CONTACTS :	—	
	A) TYPE	—	
	B) MATERIAL	—	
	C) SILVER FACING PROVIDED	—	
	D) THICKNESS OF THE FACING	Microns	

	E) DESIGN CONTACT PRESSURE	Kg./Sq.Cm	
5.6	TRIP COIL CONSUMPTION AT RATED VOLTAGE	Watts	
5.7	SATISFACTORY OPERATION OF CLOSING BETWEEN 80% - 100% OF RATED CONTROL VOLTAGE	–	<input type="checkbox"/> YES <input type="checkbox"/> NO
5.8	SF6 BREAKER	–	
	a) STANDARD TO WHICH SF6 GAS CONFORMS	–	
	b) SF6 GAS PRESSURE	Kg./Sq.cm	
	c) GAS DENSITY MONITOR PROVIDED & DETAILS ATTACHED.	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, BEING SUBMITTED
	d) LEAKAGE OF SF6 GAS	gm/year	
	e) SF6 GAS LEAKAGE DETECTOR PROVIDED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN
	f) WEIGHT OF SF6 GAS PER POLE	Kg.	
	g) DECOMPOSED GASES AND MOISTURE ABSORBANT PROVIDED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN
5.9	VACUUM BREAKERS	–	
	a) PRESSURE INSIDE THE INTERRUPTER	Mm.Hg.	
	b) CONTACT WEAR INDICATION PROVIDED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN
	c) MECHANICAL FACILITY FOR CHECKING LOSS OF VACUUM PROVIDED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN
	d) VACUUM MONITORING RELAY PROVIDED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN
	e) ADEQUATE SHIELDING AGAINST X-RAY RADIATIONS PROVIDED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN
5.10	TYPE TEST REPORT	–	<input type="checkbox"/> ENCLOSED <input type="checkbox"/> NOT ENCLOSED

6.0	CIRCUIT BREAKER OPERATING MECHANISM	–	
6.1	TYPE OF CLOSING MECHANISM	–	
6.2	SPRING CHARGING MECHANISM :	–	
a)	SPRING CHARGING MOTOR :	–	
	i) RATED VOLTAGE	Volts	
	ii) RATING	Watts	
	iii) SPEED	RPM	
	iv) CLASS OF INSULATION	–	
	v) SATISFACTORY OPERATION OF SPRING CHARGING MOTOR BETWEEN 80% - 100% OF RATED VOLTAGE	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, DEVIATION GIVEN
	vi) TIME REQUIRED TO CHARGE THE SPRING FROM FULLY DISCHARGED CONDITION	SEC.	
	vii) OVERLOAD AND SHORT CIRCUIT PROTECTION PARTICULARS	–	
b)	IS PROVISION MADE FOR IMMEDIATE CHARGING OF CLOSING SPRING AFTER A CLOSURE	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN
c)	ADEQUATE SPRING RESERVE FOR ONE O-C-O OPERATION WITHOUT INTENTIONAL TIME DELAY	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN
d)	MECHANICAL INDICATION FOR SPRING CHARGED CONDITION PROVIDED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN
e)	WHETHER SLOW CLOSING/OPENING IS FEASIBLE FOR MAINTENANCE TESTING	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN

6.3	METHOD OF CLOSING DURING POWER SUPPLY FAILURE	–	
7.0	VACUUM CONTACTORS	–	
7.1	MAKERS NAME AND COUNTRY OF MANUFACTURE	–	
7.2	MANUFACTURER'S TYPE DESIGNATION	–	
7.3	APPLICABLE STANDARDS	–	
7.4	TYPE TEST REPORT	–	<input type="checkbox"/> ENCLOSED <input type="checkbox"/> NOT ENCLOSED
7.5	CLEARANCES	–	
	a) BETWEEN PHASES	mm	
	b) BETWEEN LIVE PARTS AND EARTH	mm	
	c) CENTRE TO CENTRE DISTANCE BETWEEN PHASES	mm	
7.6	WHETHER THE VACUUM CONTACTOR IS MECHANICALLY LATCHED OR ELECTRICALLY HELD	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASONS ATTACHED
7.7	a) TYPE OF OPERATING MECHANISM	–	
	b) POWER FOR OPERATING STATION MECHANISM	Battery or control transformer	
7.8	METHOD OF CLOSING	–	
	a) NORMAL VOLTAGE OF COIL	Volts	
	b) POWER FOR CLOSING MECHANISM	Watts	
7.9	NUMBER OF OPERATIONS THE VACUUM CONTACTOR IS CAPABLE OF PERFORMING WITHOUT INSPECTION	Nos.	
7.10	SWITCHING OVER VOLTAGES BY THE VACUUM CONTACTOR	Per unit peak line to earth	

7.11	METHOD OF CLOSING DURING POWER SUPPLY FAILURE	–	
7.12	WHETHER INSTRUCTION MANUAL IS ENCLOSED	YES / NO	
8.0	INSTRUMENT TRANSFORMERS	–	
8.1	CURRENT TRANSFORMERS - METERING AND PROTECTION	–	COMPLIANCE WITH SPECIFICATION & PROJECT DWGS <input type="checkbox"/> YES <input type="checkbox"/> NO, DEVIATIONS ATTACHED
8.1.1	MAKE	–	
8.1.2	TYPE (BAR / WOUND / ANY OTHER)	–	
8.1.3	APPLICABLE STANDARD	–	
8.1.4	CLASS OF INSULATION	–	
8.1.5	CORE BALANCE CTs. (FOR EACH CT)	–	
	a) RATIO	–	
	b) RATED VA BURDEN	VA	
	c) ACCURACY CLASS	–	<input type="checkbox"/> CL, PS
	d) MINIMUM KNEE-POINT VOLTAGE	Volts	
	e) MAXIMUM MAGNETISATION CURRENT AT PROPOSED SETTING	Ma	
	f) CT SECONDARY RESISTANCE	Ohms	
	g) MAGNETISATION CHARACTERISTIC CURVE ATTACHED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO
	h) DIMENSIONED DRAWING ATTACHED	YES / NO	
	i) APPLICABLE STANDARD	–	
8.1.6	TYPE TEST REPORT FOR ALL CT DESIGNS	–	<input type="checkbox"/> ENCLOSED <input type="checkbox"/> NOT ENCLOSED

8.2	VOLTAGE TRANSFORMERS	–	COMPLIANCE WITH SPEC. PROJECT DWGS <input type="checkbox"/> YES <input type="checkbox"/> NO, DEVIATIONS ATTACHED
8.2.1	MAKE	–	
8.2.2	TYPE	–	
8.2.3	APPLICABLE STANDARD	–	
8.2.4	TYPE OF INSULATION	–	
8.5	TYPE TEST REPORT	–	<input type="checkbox"/> ENCLOSED <input type="checkbox"/> NOT ENCLOSED
9.0	INDICATING METERS	–	COMPLIANCE WITH SPEC. /DWGS <input type="checkbox"/> YES <input type="checkbox"/> NO, DEVIATIONS ATTACHED
9.1	<i>1.1.a.i.1.2 GENERAL</i>	–	
9.1.1	MAKE	–	
9.1.2	APPLICABLE STANDARD	–	
9.1.3	TYPE OF MOVEMENT	–	
9.1.4	SIZE	–	X mm
9.1.5	SCALE SIZE (IN DEGREES)	–	
9.1.6	MOUNTING, FLUSH TYPE OTHER	–	
9.1.7	ACCURACY	–	
9.1.8	RANGE AS PER SPECIFICATION	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, DEVIATIONS ATTACHED
9.1.9	VA BURDEN FOR EACH TYPE	–	
9.2	WATT HOUR METER	–	
9.2.1	MAKE	–	
9.2.2	TYPE	–	
9.2.3	STANDARD TO WHICH IT CONFORMS	–	

9.2.4	MAXIMUM NUMBER OF DIGITS	–	
9.2.5	VOLTAGE COIL RATING	Volts	
9.2.6	CURRENT RATING	Amps.	
9.2.7	VA BURDEN	VA	
9.2.8	ACCURACY	–	
9.2.9	RANGE AS PER SPECIFICATION	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, DEVIATION ATTACHED
9.2.10	DRAW OUT / NON – DRAWOUT TYPE	–	
9.2.11	MOUNTING, FLUSH TYPE OTHER	–	
9.2.12	TEST PLUG/TEST BLOCKS TESTING TERMINALS WITH LINKS	–	<input type="checkbox"/> ELECTROMECHANICAL <input type="checkbox"/> SOLID STATE <input type="checkbox"/> μ P BASE
10.0	<i>1.1.a.i.1.3 PROTECTION RELAYS</i>	–	MAKE TYPE
10.1	INVERSE TIME OVER-CURRENT RELAY	–	
10.2	INSTANTANEOUS OVER-CURRENT RELAY	–	
10.3	THERMAL OVERLOAD PROTECTION RELAY	–	
10.4	LOCKED ROTOR PROTECTION RELAY	–	
10.5	THERMAL OVERLOAD ALARM RELAY	–	
10.6	NEGATIVE SEQUENCE VOLTAGE OPERATED RELAY	–	
10.7	EARTH LEAKAGE RELAY FOR USE WITH CORE BALANCE CT	–	
10.8	EARTH FAULT RELAY FOR USE IN THE RESIDUAL CIRCUIT OF MAIN CTS.	–	
10.9	DIFFERENTIAL RELAY (HIGH STABILITY CIRCULATING CURRENT TYPE)	–	

10.10	DIFFERENTIAL RELAY FOR USE WITH THROUGH-TYPE CTS.	–	
10.11	VOLTAGE OPERATED EARTH FAULT RELAY (NEUTRAL DISPLACEMENT RELAY)	–	
11.0	TERMINATION / WIRING	–	COMPLIANCE WITH SPEC. <input type="checkbox"/> YES <input type="checkbox"/> NO, DEVIATIONS ATTACHED
11.1	COLOUR CODING FOR WIRES FOR :	–	
	a) D.C. CONTROL CIRCUITS	–	
	b) A.C. AUXILIARY POWER CIRCUIT LIKE PANEL SPACE HEATER, PANEL ILLUMINATION ETC.	–	
	c) A.C. METERING CIRCUIT	–	
	d) EARTHING	–	
11.2	NUMBERED FERRULES AT BOTH ENDS	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN
11.3	INSULATED SLEEVES PROVIDED AT WIRE TERMINATIONS	–	<input type="checkbox"/> YES <input type="checkbox"/> NO, REASON GIVEN
11.4	TERMINALS :	–	
	a) MAKE	–	
	b) CURRENT RATING	Amps	
	c) CLAMP TYPE / BOLT TYPE	–	
	d) MOULDED INTER-TERMINAL BARRIERS PROVIDED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO
	e) MAXIMUM CONDUCTOR SIZE AND NUMBER OF CONDUCTORS WHICH IT CAN RECEIVE	sq.mm	
	f) DISCONNECTING TYPE FOR CT CIRCUITS	–	<input type="checkbox"/> YES <input type="checkbox"/> NO

	g) TERMINAL MARKING FACILITY PROVIDED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO
	h) CRIMP TYPE CONNECTORS PROVIDED AT THE TERMINALS	–	<input type="checkbox"/> YES <input type="checkbox"/> NO
	i) 10% SPARE TERMINAL PROVIDED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO
11.5	TYPE TEST REPORT FOR WIRING MATERIALS	–	<input type="checkbox"/> ENCLOSED <input type="checkbox"/> NOT ENCLOSED
12.0	CABLE BOXES / POTHEADS	–	
12.1	INCLUDED IN SCOPE OF SUPPLY	–	
12.2	RATED VOLTAGE	KV	
12.3	APPLICABLE STANDARD	–	
12.4	COMPOUND FILLED/EPOXY RESIN / SHRINKABLE TYPE	–	
12.5	ALL FURNISHING MATERIAL AND ACCESSORIES INCLUDING COMPOUND, TAPES, BINDINGS, WIRES, FILTERS, ARMOUR CLAMPS, BRASS GLAND, ETC. INCLUDED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO
13.0	SPARES	–	
13.1	LIST OF RECOMMENDED SPARES FOR NORMAL MAINTENANCE FOR A PERIOD OF 3 YEARS FURNISHED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO
14.0	TESTS		
14.1	ALL TEST CERTIFICATES ON BOUGHT ITEMS BE FURNISHED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO
14.2	LIST OF ROUTINE TESTS TO BE CARRIED OUT ATTACHED	–	<input type="checkbox"/> YES <input type="checkbox"/> NO
15.0	DRAWINGS AND DATA		

15.1	DRAWINGS SUBMITTED ALONG WITH BID	-	<input type="checkbox"/> YES	<input type="checkbox"/> NO
------	-----------------------------------	---	------------------------------	-----------------------------

5.24. DATASHEET-B LT SWITCHGEAR

1.0	<u>SPECIFIC PARTICULARS</u>		
1.1	SWITCHGEAR DESIGNATIONS		
1.2	SINGLE FRONT OR DOUBLE FRONT	SF/DF	
1.3	APPLICABLE STANDARD		
1.4	FULLY DRAWOUT/SEMI DRAWOUT/FIXED	FD/SD/F	
1.5	TOTAL DIMENSIONS OF EACH COMPLETE SWITCHGEAR L X W X D	MM $\frac{L}{W}$ $\frac{D}{D}$	
1.6.1	WIDTH OF EACH VERTICAL SECTION WITH CABLE ALLEY	MM	
1.6.2	WIDTH OF CABLE ALLEY ONLY	MM	
1.7	MINIMUM CLEAR SPACE REQUIRED A) IN FRONT B) BACK	MM MM	
1.8	MAX. CUBICLE WEIGHT WITH COMPONENTS	KG	
1.9	HAVE ALL THE FEEDERS AND COMPONENTS SPECIFIED IN ENCLOSED DRAWINGS AND DATA SHEETS A - 3 BEEN PROVIDED ?		YES/NO

2.0	GENERAL PARTICULARS		
2.1	<p>SHEET STEEL</p> <p>A) COLD ROLLED/HOT ROLLED</p> <p>B) THICKNESS :</p> <p>I) FRAMES</p> <p>II) DOOR</p> <p>III) REAR COVER</p> <p>IV) SIDE AND TOP COVERS</p> <p>V) PANEL PARTITIONS</p>	<p>MM</p> <p>MM</p> <p>MM</p> <p>MM</p> <p>MM</p>	
2.2	DEGREE OF PROTECTIONS PROVIDED BY THE ENCLOSURE (AS PER IS : 13947)		
2.3	EARTH BUSBAR SIZE	SQ.MM	GI/AL/CU
2.4	<p>BUSBAR</p> <p>A) MATERIAL OF BUSBARS</p> <p>B) SECTION</p> <p>C) CONTINUOUS CURRENT RATING UNDER SITE CONDITIONS</p> <p>D) WHETHER BUSBARS HAVE BEEN INSULATED</p> <p>E) TYPE OF INSULATION</p> <p>F) TEMPERATURE RISE OVER THE REFERENCE AMBIENT WHEN CARRYING RATED CURRENT</p>	<p>SQ.MM</p> <p>A</p> <p>°C</p>	<p>AL/CU</p> <p>PH : N:</p> <p>YES/NO</p>

	G) MATERIAL OF BUSBAR SUPPORTS		
	H) CLEARANCE IN AIR :	MM	
	I) BETWEEN PHASES	MM	
	II) BETWEEN PHASES EARTH	KA	
	I) SHORT TIME RATING (ONE SEC.)	KA	
	J) MOMENTARY RATING (PEAK)		
3.0	CIRCUIT BREAKERS		
3.1	MAKER'S NAME		
3.2	MAKER'S TYPE DESIGNATION		
3.3	APPLICABLE STANDARDS		
3.4	CIRCUIT BREAKERS TYPE (AIR BREAK AND OR MCCB)		
3.5	RATED VOLTAGE	V	
3.6	RATED OPERATING DUTY		
3.7	RATED CURRENT	A	
3.8	DERATING FACTOR FOR OPERATION UNDER SITE CONDITIONS		
3.9	RATED SYMMETRICAL BREAKING CURRENT AT RATED VOLTAGE. (INDICATE POWER FACTOR)	KA P.F.	
3.10	RATED PEAK MAKING CURRENT	KA	
3.11	RATED SHORT TIME WITHSTAND RATING (FOR 1 SEC.) (FOR MCCB, BIDDER TO INDICATE THE TIME)		
3.12	OPERATING MECHANISM TYPE		
3.13	LIMITS OF VOLTAGE FOR SATISFACTORY OPERATION OF THE FOLLOWING DEVICES AS A % OF NORMAL VOLTAGE		
	I) OPERATING MECHANISM	%	
	II) CLOSING AT NORMAL	%	

	VOLTAGE	%	
	IV) TRIP COIL		
3.14	POWER REQUIRED FOR CLOSING AT NORMAL VOLTAGE	W	
3.15	POWER REQUIRED FOR TRIPPING AT NORMAL VOLTAGE	W	
3.16	SPRING CHARGING MOTOR DETAILS : I) RATING II) RATED VOLTAGE III) SPRING CHARGING	KW V, AC/DC SEC.	
3.17	OVERLOAD RELEASE PROVIDED	YES/NO	
3.18	SHORT CIRCUIT RELEASE SETTINGS AND TIME DELAY FEATURES		
3.19	UNDERVOLTAGE RELEASE SETTING		
3.20	HAVE ELECTRICAL AND MECHANICAL ANTI-PUMPING FEATURES BEEN PROVIDED	YES/NO	
3.21	HAVE TYPE TEST CERTIFICATES BEEN ENCLOSED ?	YES/NO	
4.0	AIR BREAK SWITCHES		
4.1	MAKE		
4.2	TYPE		
4.3	RATED VOLTAGE		
4.4	APPLICABLE STANDARDS		
4.5	MAXIMUM PROSPECTIVE FAULT CURRENT WITHSTAND OF COMPOSITE UNIT OF SWITCH AND FUSE	KA (PEAK)	
5.0	FUSES		
5.1	MAKE		
5.2	TYPE		
5.3	APPLICABLE STANDARDS		
5.4	RATED VOLTAGE	V	
5.5	RATED CURRENT FOR INDIVIDUAL CIRCUITS TO BE PROVIDED AS PER REQUIREMENTS OF PROTECTION COORDINATION	YES/NO	

6.0	CONTACTORS		
6.1	MAKE		
6.2	RATED DUTY		
6.3	RATED UTILISATION CATEGORY		
6.4	APPLICABLE STANDARDS		
6.5	RATED (THERMAL) CURRENT PROVIDED AS PER SPECIFICATION	YES/NO	
6.6	RATED VOLTAGE OF AUXILIARY CONTACTS	V	
6.7	RATED VOLTAGE OF COIL	V	
6.8	RATED BREAKING CAPACITY	FACTOR OF RATED CURRENT	
6.9	RATED MAKING CAPACITY	FACTOR OF RATED CURRENT	
6.10	LIMITS OF OPERATION I) SUPPLY VOLTAGE VARIATION II) SUPPLY FREQUENCY VARIATION FOR CLOSING III) DROP OUT VOLTAGE	+ % + % %	
6.11	NO OF AUXILIARY CONTACTS : I) NORMALLY OPEN II) NORMALLY CLOSED		
7.0	SINGLE PHASING PREVENTERS		
7.1	IS IT IN BUILT-IN BIMETAL THERMAL OVERLOAD RELAY	YES/NO	
8.0	CURRENT TRANSFORMERS		
8.1	MAKE		
8.2	APPLICABLE STANDARDS		
8.3	ALL OTHER PARAMETERS OF CT AS PER ENCLOSED SLD/LIST AND SECTION-D	YES/NO	
9.0	VOLTAGE TRANSFORMERS		

9.1	MAKE		
9.2	APPLICABLE STANDARDS		
9.3	RATIO	V/V	
9.4	OUTPUT PER PHASE	VA	
9.5	ACCURACY CLASS		
9.6	OVER VOLTAGE FACTOR		
9.7	CLASS OF INSULATION		
10.0	CONTROL TRANSFORMERS		
10.1	MAKE		
10.2	TYPE		
10.3	APPLICABLE STANDARDS		
10.4	RATIO		
10.5	CLASS OF INSULATION		
10.6	RATED OUTPUT	VA	
11.0	INSTANTANEOUS OVERCURRENT RELAY		
11.1	APPLICATION (PHASE FAULT OR EARTH FAULT)		
11.2	MAKE		
11.3	TYPE DESIGNATION		
11.4	SETTING RANGE		
12.0	INVERSE TIME AND THERMAL OVERCURRENT RELAY		
12.1	APPLICATION		
12.2	MAKE		
12.3	TYPE		
12.4	CURRENT SETTING RANGE		
12.5	TIME SETTING RANGE AT 10 TIMES THE CURRENT SETTING	SEC.	
13.0	UNDERVOLTAGE RELAY		
13.1	MAKE		
13.2	TYPE		
13.3	VOLTAGE RATING	V	
13.4	SETTING RANGE	V	
14.0	AUXILIARY RELAYS AND TIMERS		
14.1	MAKE		
14.2	TYPE		
14.3	COIL VOLTAGE	V	
15.0	CONTROL/SELECTOR SWITCH		
15.1	MAKE		
15.2	TYPE DESIGNATION		
16.0	VOLTMETER		
16.1	MAKE		

16.2	TYPE		
16.3	APPLICABLE STANDARDS		
16.4	ACCURACY CLASS		
17.0	AMMETER		
17.1	MAKE		
17.2	TYPE		
17.3	APPLICABLE STANDARDS		
17.4	ACCURACY CLASS		
18.0	WATTMETER		
18.1	MAKE		
18.2	TYPE		
18.3	APPLICABLE STANDARD		
18.4	ACCURACY CLASS		
19.0	INDICATING LAMPS		
19.1	MAKE		
19.2	TYPE		
19.3	VOLTAGE	V	
19.4	SERIES RESISTOR	OHMS	
19.5	WATTAGE OF LAMP	W	
20.0	PUSH BUTTONS		
20.1	MAKE		
20.2	TYPE DESIGNATION		
20.3	NO OF CONTACTS: I) NORMALLY OPEN II) NORMALLY CLOSED		
20.4	CONTACT RATING	A	
21.0	SPACE HEATER		
21.1	MAKE		
21.2	TYPE		
21.3	RATED VOLTAGE	V	
21.4	HEATER OUTPUT FOR EACH VERTICAL PANEL	W	
21.5	THERMOSTAT AT SETTING °C		
22.0	WIRING AND TERMINAL BLOCKS		
22.1	VOLTAGE GRADE		
22.2	INSULATION		
22.3	MINIMUM SIZE OF CONDUCTOR FOR : I) POWER WIRING	SQ.MM SQ.MM	

	II) CONTROL WIRING		
22.4	TYPE OF TERMINAL BLOCKS : I) FOR WITHDRAWABLE TYPE II) FOR FIXED TYPE		
22.5	MINIMUM CURRENT RATING OF TERMINAL BLOCKS	A	
22.6	WHETHER TERMINALS FOR CT'S HAVE BEEN PROVIDED WITH SHORT CIRCUITING FACILITIES	YES/NO	
23.0	PUSH BUTTON STATION		
23.1	METAL ENCLOSURE : I) DIE-CAST ALUMINIUM/SHEET METAL OF 2MM THICKNESS II) DEGREE OF PROTECTION III) PAINTING, INSCRIPTION EARTHING TERMINALS AS SPECIFIED	YES/NO	
23.2	GLAND PLATE AND CABLE GLANDS PROVIDED	YES/NO	
22.3	FACILITY FOR FIXING ON WALL/STRUCTURE PROVIDED	YES/NO	
23.4	NO. OF CONTACTS : I) NORMALLY OPEN II) NORMALLY CLOSED		
23.5	CONTACT RATING : I) AT 415 V AC II) AT 110 V AC III) AT 220 V DC	A A A	

5.25. DATASHEET-B HT TERMINATIONS

1.0	<u>MANUFACTURER</u>			
2.0	<u>APPLICABLE STANDARDS</u>			
3.0	<u>GUARANTEED PARTICULARS</u>			
	FOR THE NOMINAL (PHASE TO PHASE) SYSTEM VOLTAGES		KV	
3.1	A.C WITHSTAND VOLTAGE (PH / GROUND)		KV	
	TIME DURATION		MINS	
3.2	PARTIAL DISCHARGE AT 2 UO		PC	
3.3	IMPULSE WITHSTAND, 1.2 / 50 μ S		KV	
3.4	LOAD CYCLE TEST			
	(A)	EACH CYCLE – HEATING - DURATION	HRS	
		TEMPERATURE	$^{\circ}$ C	
		COOLING DURATION	HRS.	
	(B)	NUMBNER OF CYCLES		
	(C)	CONTINUOUS PHASE TO GROUND VOLTAGE WITHSTAND	KV	
3.5	THERMAL WITHSTAND SHORT CIRCUIT CURRENT 1 SEC.		KA	
3.6	DYNAMIC SHORT CIRCUIT WITHSTAND		KA/PEAK	
3.7	TYPE TEST REPORT FOR ALL THE TESTS ENCLOSED AS SPECIFIED		YES / NO.	
4.0	<u>KIT PARTICULARS</u>			

4.1	MATERIAL OF THE TUBING / MOULDED PARTY		
4.2	METHOD OF STRESS CONTROL		
4.3	METHOD OF ENVIRONMENTAL SEAL		
4.4	LIST OF ITEMS INCLUDED IN THE KIT		
	(A)	FOR TERMINATIONS	
	(B)	FOR JOINTS	
	(C)	WHETHER HEATING DEVICE INCLUDED	YES / NO.
		(I) HOW MANY SUCH DEVICE INCLUDED	QTY.
	(D)	ALLOWABLE KIT STORAGE TEMPERATURE	⁰ C
	(E)	KIT SHELF LIFE	YEARS
5.0	<u>CABLE TERMINATIONS / JOINTS INSTRUCTION MANUAL ENCLOSED</u>		YES / NO

5.26. DATASHEET-B POWER TRANSFORMER

1.0	TRANSFORMER APPLICATION/ DESIGNATION		
2.0	APPLICABLE STANDARDS		
3.0	QUANTITY REQUIRED		
4.0	FULL LOAD RATING	MVA	
5.0	3 PHASE UNIT / BANK OF THREE (3) 1 PHASE UNITS		
6.0	AUTO WOUND / TWO WINDING TRANSFORMERS / THREE WINDING TRANSFORMERS		
7.0	RATED NO-LOAD VOLTAGES :		
7.1	HV	KV	
7.2	MV	KV	
7.3	LV	KV	
8.0	COOLING (ONAN / ONAF / OFAN / OFAF / OFWF)		
9.0	RATINGS		
9.1	RATINGS OF WINDINGS		
9.1.1	HV	MVA	
9.1.2	MV	MVA	
9.1.3	LV	MVA	
9.2	RATINGS CORRESPONDING TO COOLING METHODS		
9.2.1	ONAN	MVA	
9.2.2	ONAF	MVA	

9.2.3	OFAN	MVA	
9.2.4	OFAF	MVA	
9.2.5	OFWF	MVA	
10.0	GUARANTEED (SUBJECT TO TOLERANCE) IMPEDANCE VOLTAGE AT RATED CURRENT FOR THE PRINCIPAL TAPPING		
10.1	HV – LV	%	
10.2	HV – MV	%	
10.3	MV – LV	%	
11.0	EFFICIENCY AT 750C AT UNITY P.F.		
11.1	AT FULL LOAD	%	
11.2	AT $\frac{3}{4}$ FULL LOAD	%	
11.3	AT $\frac{1}{2}$ FULL LOAD.	%	
12.0	REGULATION AT FULL LOAD, 0.8 P.F AT 750C WINDING TEMPERATURE	%	
13.0	RATED FREQUENCY	HZ.	
14.0	EXTERNAL SHORT CIRCUIT WITHSTAND CAPACITY	MVA	
15.0	CORE :		
15.1	MATERIAL OF CORE LAMINATION		
15.2	THICKNESS OF CORE PLATES.		
15.3	INSULATION OF CORE LAMINATION.		

15.4	INSULATION OF CORE BOLTS		
15.5	INSULATION OF CORE BOLT WASHERS		
15.6	INSULATION OF CORE CLAMPING PLATES.		
16.0	WINDING CONNECTIONS :		
16.1	HV		
16.2	MV		
16.3	LV		
16.4	VECTOR GROUP		
17.0	TAPPINGS ON WINDING		
17.1	ON-LOAD / OFF TAPS		
17.2	ON HV / MV / LV WINDING		
17.3	FULL POWER TAPPING RANGE + %		
17.4	FOR CBVV RATING :		
17.4.1	MAXIMUM VOLTAGE TAPPING AND CORRESPONDING VOLTAGE		
17.4.2	MAXIMUM CURRENT TAPPING AND CORRESPONDING CURRENT		
18.0	IF ON LOAD TAPS, SPECIFY DETAILS OF OLTC GEAR.		
18.1	MANUAL / AUTOMATIC CONTROL		
18.2	REMOTE / LOCAL CONTROL		

18.3	IF REMOTE CONTROL, WHETHER THE REMOTE CONTROL CUBICLE INCLUDED IN BIDDER'S SCOPE OF SUPPLY		
18.4	VOLTAGE CLASS OF THE OLTC		
18.5	CURRENT RATING OF THE OLTC	A	
19.0	TERMINALS OF TERTIARY (STABILISING) WINDING BROUGHT OUT TO BUSHINGS	YES / NO	
20.0	WINDING INSULATION CATEGORY :		
20.1	HV UNIFORM / NON-UNIFORM		
20.2	MV UNIFORM / NON-UNIFORM		
20.3	LV UNIFORM / NON-UNIFORM		
21.0	TYPE OF AXIAL COIL SUPPORTS		
21.1	HV		
21.2	MV		
21.3	LV		
22.0	TYPE OF RADIAL COIL SUPPORTS		
22.1	HV		
22.2	MV		
22.3	LV		
23.0	IMPULSE VOLTAGE WITHSTAND 1.2 / 50 μ S WAVE		
23.1	HV	KV/PEA K	

23.2	MV	KV/PEAK	
23.3	LV	KV/PEAK	
24.0	POWER FREQUENCY WITHSTAND VOLTAGE (DRY AND WET)		
24.1	HV; HV NEUTRAL	KV(RMS)	
24.2	MV	KV(RMS)	
24.3	LV	KV(RMS)	
25.0	GUARANTEED MAXIMUM TEMPERATURE RISE		
25.1	OIL BY THERMOMETERS	⁰ C	
25.2	WINDING BY RESISTANCE FOR :		
25.2.1	ON / OB / OW COOLING	⁰ C	
25.2.2	OFN / OFB COOLING	⁰ C	
25.2.3	OFW COOLING	⁰ C	
26.0	SWITCHING IMPULSE WITHSTAND VOLTAGE FOR HIGHEST EQUIPMENT VOLTAGE > 145 KV).	_____	
27.0	TANK COVER CONVENTIONAL / BELL SHAPED	_____	
28.0	MINIMUM CLEARANCE HEIGHT FOR LIFTING CORE AND WINDINGS FROM TANK	MM _____	
29.0	BUSHINGS	_____	

29.1	RATED VOLTAGE CLASS	KV	
29.2	RATED CURRENT	A	
29.3	1.2 / 50 μ S IMPULSE WITHSTAND	KV(RMS)	
29.4	ONE MINUTE POWER FREQUENCY WITHSTAND DRY AND WET	KV(RMS)	
29.5	MINIMUM CLEARANCE IN AIR	MM	
29.6	MINIMUM CREEPAGE DISTANCE		
29.6.1	TOTAL	MM	
29.6.2	PROTECTED	MM	
29.7	QUANTITY OF OIL IN OIL FILLED BUSHINGS	<u>LITRES</u>	
29.6.8	FREE SPACE REQUIRED AT TOP FOR REMOVAL	<u>MM</u>	
30.0	LOAD LOSS AT RATED CURRENT AT 750C WINDING TEMPERATURE (GUARANTEED SUBJECT TO TOLERANCE AS PER APPLICABLE STANDARD AND EXCLUDING COOLER LOSSES)		
31.0	ESTIMATED MAXIMUM COOLER LOSSES AT FULL LOAD	<u>KW</u>	
32.0	NO LOAD LOSSES (CORE LOSS AND DI-ELECTRIC LOSS) AT 100% RATED VOLTAGE AND FREQUENCY, GUARANTEED SUBJECT TO TOLERANCE AS PER APPLICABLE STANDARD		

33.0	GUARANTEED NO-LOAD CURRENT :	_____	
33.1	WHEN EXCITED FROM LV SIDE AT 100% RATED VOLTAGE	A _____	
33.2	WHEN EXCITED FROM LV SIDE AT 110% RATED VOLTAGE	A _____	
34.0	MAXIMUM FLUX DENSITY		
34.1	AT RATED VOLTAGE	WB/M ² _____	
34.2	AT 110% RATED VOLTAGE	WB/M ² _____	
34.3	OVERFLUXING CAPABILITY.		
35.0	CURRENT DENSITY		
35.1	HV	A/CM ² _____	
35.2	MV	A/CM ² _____	
35.3	LV	A/CM ² _____	
36.0	WHEELS		
36.1	PLAIN / FLANGED	_____	
36.2	UNIDIRECTIONAL / BI- DIRECTIONAL	_____	
36.3	QUANTITY	_____	
36.4	GAUGE (S)	_____	
37.0	VACUUM WITHSTAND CAPABILITY :	_____	
37.1	MAIN TANK	MM OF HG.	

37.2	RADIATORS AND ACCESSORIES	MM OF HG	
38.0	ALL ACCESSORIES SUPPLIED AS SPECIFIED	YES / NO	
39.0	COOLER CONTROL SCHEME CONFORMS TO SPECIFICATION	YES / NO	
40.0	OLTC CONTROL SCHEME CONFORMS TO SPECIFICATION	_____	
41.0	WEIGHTS		
41.1	NET WEIGHT OF THE CORE	YES / NO	
41.2	NET WEIGHT OF COPPER	_____	
41.2.1	HV	KG	
41.2.2	LV	KG	
41.2.3	TERTIARY	KG	
41.2.4	TOTAL	KG	
41.3	OIL	KG	
41.4	TANK, COOLERS AND FITTINGS	KG	
41.5	TOTAL	KG	
41.6	UNTANKING WEIGHT	KG	
42.0	SHEET METAL THICKNESS	_____	
42.1	OUTDOOR COOLER CONTROL CABINET	MM _____	

42.2	INDOOR OLTC CONTROL CABINET	_____	
43.0	COOLING FANS :	_____	
43.1	TYPE		
43.2	QUANTITY	NO.	
43.3	RATING	KW	
44.0	COOLING OIL PUMPS		
44.1	TYPE		
44.2	QUANTITY	NO.	
44.3	RATING	KW	
45.0	COOLING WATER PUMPS		
45.1	TYPE		
45.2	QUANTITY	NO.	
45.3	RATING	KW	
46.0	CAPABILITY OF TRANSFORMER TO REMAIN IN OPERATION FROM HOT CONDITION AFTER FAILURE OF FORCED COOLING	_____	
46.1	FULL LOAD	MINUTE S	
46.2	WITHOUT LOAD CURRENT (FOR TRANSFORMERS WITHOUT ONAN RATING)	MINUTE S	
47.0	ON-LOAD TAP CHANGER		
47.1	MAKE		

47.2	TYPE DESIGNATION		
47.3	SUITABLE FOR AUTO / MANUAL OPERATION	_____	
47.4	RATED VOLTAGE	KV	
47.5	RATED CURRENT	AMP	
47.6	NUMBER OF STEPS		
47.7	STEP VOLTAGE	VOLTS	
47.8	RATED VOLTAGE OF DRIVE MOTOR	V _____	
47.9	RATED VOLTAGE OF CONTROL CIRCUIT	V _____	
47.10	TIME TO COMPLETE TAP CHANGING OPERATION FROM ANY ONE STEP TO NEXT HIGHER OR LOWER STEP	_____	
47.10.1	ON 'AUTO' OPERATION	SEC. _____	
47.10.2	ON 'MANUAL' OPERATION I.E., THROUGH PUSH BUTTON	SEC. _____	
48.0	LIST OF ROUTINE TESTS TO BE CARRIED OUT	_____	
49.0	LIST OF OTHER TESTS WHICH WILL BE CARRIED OUT AGAINST EXTRA PRICE QUOTED ELSEWHERE	_____	
50.0	DRAWING NUMBER OF GENERAL OUTLINE DRAWING ENCLOSED WITH THE BID SHOWING THE TRANSFORMER	_____	

	WITH ALL ITS FITTINGS AND ACCESSORIES IN PLAN, FRONT AND SIDE ELEVATIONS AND OTHER DETAILS		
51.0	SHIPPING SECTION		
51.1	SIZE OF LARGEST PACKAGE (LXBXH)	MM	
51.2	WEIGHT OF THE LARGEST PACKAGE	TONNES	
52.0	MANUFACTURER'S MAINTENANCE PROCEDURE AND SCHEDULE FOR SPARE UNCHARGED TRANSFORMER		
53.0	HYDRAULIC JACK		
53.1	MAKE		
53.2	TYPE		
53.3	NUMBER		
53.4	CAPACITY		
55.0	OVERLOAD CAPACITY OF TRANSFORMER FOR BOTH 100% OFAF COOLERS WORKING SIMULTANEOUSLY.		
56.0	BUSHINGS CTS, IF OFFERED		
56.1	QUANTITY		
56.2	RATIO		
56.3	VA BURDEN		
56.4	ACCURACY CLASS		

56.5	KNEE POINT VOLTAGE	VOLTS	
56.6	MAGNETISING CURRENT AT KNEE-POINT VOLTAGE	AMPS	
56.7	SECONDARY RESISTANCE	OHMS	
57.0	VALUES OF TRANSFER SURGE VOLTAGE WITHSTAND FOR :	_____	
57.1	LIGHTNING SURGES		
57.1.1	AMPLITUDE	KV	
57.1.2	RATE	KV/SEC.	
57.2	SWITCHING SURGES		
57.2.1	AMPLITUDE	KV	
57.2.2	RATE	KV/SEC.	
58.0	TERTIARY WINDING, IF ANY, IF KEPT ISOLATED THEN THE BIDDER TO STATE WHETHER ONE TERMINAL TO BE EARTHED OR NOT.	_____	
59.0	TORQUE FOR COIL CLAMPING BOLTS	KG-M	
60.0	WHETHER NEUTRAL END SURGE DIVERter RECOMMENDED BY THE BIDDER	_____	
61.0	IF YES, DETAILS OF SURGE DIVERter	_____	
61.1	MAKE		

61.2	TYPE		
61.3	KV CLASS		
61.4	KV RATING		
62.0	IF UNIT COOLER ARRANGEMENT OFFERED FOR COOLING, ADVISE ?	_____	
62.1	TOTAL NO. OF UNIT COOLERS PROVIDED.	_____	
62.2	NO. OF UNIT COOLERS WHICH WOULD BE IN SERVICE FOR FULL LOAD OPERATION OF TRANSFORMER.	_____	
62.3	NO. OF 'SPARE' UNIT COOLERS		
62.4	NO. OF FANS IN EACH UNIT COOLER	_____	
62.5	NO. OF PUMPS IN EACH UNIT COOLER	_____	
62.6	RATING OF EACH FAN MOTOR		
62.7	RATING OF EACH OIL PUMP MOTOR	_____	

5.27. DATASHEET-B BUS DUCT

1.0	<u>BUS DUCT</u>		
1.1	MANUFACTURER/ COUNTRY		
1.2	BUS CONDUCTOR		
	(A) BUSBAR GRADE		
	(B) SHAPE OF BUSBAR		
	(C) SIZE OF BUSBAR	MM ²	
1.3	BARRIERS		
	(A) THICKNESS OF PHASE BARRIER	MM	
1.4	PHASE TO PHASE SPACING	MM	
1.5	SIZE OF ENCLOSURE W X H OR DIAMETER IF CIRCULAR	MMXM M/ MM	
1.6	RESISTANCE/METRE/PHASE AT 20°C OF CONDUCTOR	OHM	
1.7	INDUCTIVE REACTANCE/METRE/PHASE AT 20°C	OHM	
1.8	CAPACITIVE REACTANCE/METRE/PHASE AT 20°C	OHM	
1.9	HEAT LOSS IN THE BUS DUCT AT FULL RATED CURRENT	WATTS/ PH/ M	
1.10	WEIGHT OF 3-PHASE DUCT	KG/MET RE	
1.11	STANDARD SECTION LENGTH	M	
1.12	MINIMUM REQUIRED CLEARANCES FROM THE PERIPHERY OF THE BUS DUCT		
	D) TO STRUCTURAL STEEL WORK PARALLEL TO THE DUCT	MM	

	II) TO STRUCTURAL STEEL WORK PERPENDICULAR TO THE DUCT	MM	
2.0	<u>INSULATORS</u>		
2.1	MANUFACTURER/ COUNTRY		
2.2	TYPE		
2.3	CANTILEVER STRENGTH		
	I) UPRIGHT	KG.	
	II) UNDERHUNG	KG.	
2.4	WEIGHT OF EACH INSULATOR	KG.	
3.0	<u>SEAL OFF BUSHINGS</u>		
3.1	MANUFACTURER/ COUNTRY		
3.2	TYPE		
3.3	MECHANICAL STRENGTH		
	I) COMPRESSION	KG.	
	II) TENSION	KG.	
3.4	WEIGHT OF EACH BUSHING	KG.	
4.0	<u>BUS DUCT LAYOUT</u>		
4.1	REFERENCE DRAWING NO.		
4.2	BUS ENCLOSURE - SECTION		
5.0	<u>GENERAL</u>		
5.1	TECHNICAL SPECIFIC REQUIREMENTS CONFORM TO DATA SHEET-A1 AND A2 OF THIS SPECIFICATION		YES/NO

5.2	IF ANY DEVIATION IN TECHNICAL SPECIFIC REQUIREMENTS, IT IS BROUGHT OUT SEPARATELY IN DEVIATION SCHEDULE		YES/NO REFERENCE OF DEVIATION SCHEDULE
-----	---	--	---

5.28. DATASHEET-B CONTROL PANEL

1.0	GENERAL PARTICULARS		
1.1	DESIGNATION		
1.2	LOCATION		(INDOOR / OUTDOOR)
1.3	DESIGN AMBIENT TEMPERATURE	⁰ C	
1.4	TYPE OF MOUNTING		(FLOOR / PEDESTAL / COLUMN /WALL)
1.5	CABLE ENTRY		
	A) TOP / BOTTOM		
	B) GLANDS / CONDUITS -SIZE		
	C) GLANDS IF REQUIRED		YES/NO
1.6	PURCHASER'S EARTHING CONDUCTOR		
	A) MATERIAL		COPPER / ALUMINIUM / G I
	B) TYPE		STRIPS / ROPE / WIRE./ ROD
	C) SIZE		
1.7	PAINTING:		
	A) COLOUR FINISH		
	OUTSIDE		
	INSIDE		
	B) EPOXY PAINT REQUIRED	Yes/No	
1.8	CONTROL SCHEME & BILL OF MATERIAL, ENCLOSED	YES. Ref.No	
	If NO, TO BE FURNISHED BY VENDOR		
2.0	VOLTAGE		
2.1	POWER DEVICES, MOTOR DRIVES, ETC.		
	A) SUPPLY VOLTAGE		415V, 3PH / 3PH-N, 50Hz / 240V, 1PH-N, 50Hz
	B) DUPLICATE FEED		PROVIDED/ NOT PROVIDED
2.2	CONTROL VOLTAGE	V, AC,DC	
2.3	CONTROL TRANSFORMER	REQD. NOT REQD.	

2.4	SPACE HEATER/LIGHTING SUPPLY VOLTAGE		
3.0	OTHER PARTICULARS WHEN APPLICABLE		
3.1	STARTERS TYPE	DOL/R EVY / <	
3.2	CONTACTOR RATED DUTY (AS PER IS:2459 & 8544)		

5.29. DATASHEET-B CABLE SYSTEM INSTALLATION WORKS

			1	2	3	4
			SADDLES TYING	SPACING CORD		
1.0	CLEATING / CLAMPING OF CABLES & CONDUITS					
(A)	MAKE					
(B)	MATERIAL					
(C)	PAINTED / GALVANISED					
2.0	CABLE IDENTIFICATION TAG					
(A)	MAKE					
(B)	MATERIAL					
(C)	THICKNESS	MM				
(D)	BINDING WIRE MATERIAL					
				1	2	
3.0	BURIED CABLES MARKERS / PROTECTIVE COVERS			HV CABLES CABLES	LV	
(A)	APPLICABLE STANDARDS					
(B)	MATERIAL OF PROTECTIVE COVERS					
(C)	MATERIAL OF CABLE ROUTE / JOINT MARKERS					
4.0	CONDUIT & FLOOR OPENINGS SEALING COMPOUNDS					
	MATERIAL & COMPOSITION FOR :					
	(I) WATER PROOFING					
5.0	GROUNDING OF CABLE ARMOUR / SHEATHS TRAYS / CARRIER STRUCTURES / CONDUITS					
(A)	MATERIAL OF CONDUCTOR					
(B)	SIZE					

5.30. DATASHEET-B LIGHTING INSTALLATION WORKS

1.0	ACCESSORIES, PART OF INSTALLATION WORK		
1.1	MISCELLANEOUS ITEMS		
1.1.1	MATERIAL AND GUAGE FOR: A) SADDLES B) SPACER PLATES		

	C) JUNCTION BOXES D) FIXING HARDWARE		
1.1.2	ACCESSORIES GALVANISED.	YES/NO	
1.1.3	JUNCTION / INSPECTION BOXES PROVIDED WITH NECESSARY TERMINALS	YES/NO	
1.1.4	APPLICABLE STANDARDS FOR JUNCTION BOXES		
1.2	MOUNTING / SUSPENSION CONDUITS		
1.2.1	MAKE		
1.2.2	MATERIAL AND GUAGE FOR EACH SIZE		
1.2.3	SIZES	MM	
1.2.4	GALVANISED	YES/NO	
1.2.5	APPLICABLE STANDARDS		
1.3	BOXES FOR HOUSING 2 SWITCHES / SOCKETS		
1.3.1	APPLICABLE STANDARDS		
1.3.2	MATERIAL AND GUAGE		
1.3.3	GALVANISED	YES/NO	
1.3.4	EARTHING TERMINAL PROVIDED	YES/NO	
1.3.5	MATERIAL AND THICKNESS OF COVER SHEET		
1.4	EARTHING CONDUCTOR AND CLAMPS		
1.4.1	MATERIAL		

1.4.2	SIZES FOR A) INDOOR LIGHTING SYSTEM B) OUTDOOR LIGHTING SYSTEM C) HAZARDOUS AREAS	SWG/M M ² SWG/M M ² SWG/M M ²	
1.4.3	WHETHER SUITABLE EARTHING CLAMPS PROVIDED	YES/NO	
2.0	SUPPLY ITEMS TECHNICAL DATA FURNISHED IN DATA SHEET 'B' OF ENCLOSED RELEVANT SPECIFICATION	YES/NO	
3.0	POINT WIRING THE FOLLOWING WILL BE SUPPLIED PER POINT BASIS OF INSTALLATION WORK :		
3.1	WIRE / CABLE : A) MINIMUM SIZE / VOLTAGE GRADE I) INDOOR LIGHTING II) RECEPTACLE III) OUTDOOR LIGHTING IV) HAZARDOUS AREA LIGHTING B) CONDUCTOR MATERIAL	YES/NO	
3.2	CONDUIT A) GALVANISED / BLACK ENAMELED B) MINIMUM SIZE / GUAGE	YES/NO	
3.3	REQUIRED CONTROL SWITCHES	YES/NO	
3.4	REQUIRED SWITCHES AND RECEPTACLES	YES/NO	
3.5	EARTHING SYSTEM	YES/NO	

5.31. DATASHEET-B LEAD ACID BATTERIES

1.0	Manufacturer's name		
2.0	Standards to which battery is manufactured		
3.0	Rated capacity		
3.1	At 27 ⁰ C and 10 hr discharge rate	Ah	
3.2	Capacity at minimum ambient temperature and the formulae used for calculations		
3.3	Capacity at high discharge rate at 27 ⁰ C at different end cell voltages (Enclose capacity rating factor curves)		
3.3.1	15 minutes	Ah	
3.3.2	30 minutes	Ah	
3.3.3	45 minutes	Ah	
3.3.4	1 hour	Ah	
3.3.5	2 hour	Ah	
3.3.6	3 hour	Ah	
3.3.7	4 hour	Ah	
3.3.8	5 hour	Ah	
3.3.9	6 hour	Ah	
3.3.10	7 hour	Ah	
3.3.11	8 hour	Ah	
3.3.12	9 hour	Ah	
3.4	Maximum Momentary current 1 minute	Amps	

3.5	Expected life of battery	Years	
4.0	Recommended charging rate		
4.1	Float charging voltage / current	V / A	
4.2	Trickle charging voltage / current	V / A	
4.3	Normal Boost charging voltage / current and duration (from fully discharged to fully charged state)	V / A	
4.4	Rapid Boost charging voltage / (current in 8 hours duration)	V / A	
4.5	Equalising charge		
	(a) Voltage / current	V/A	
	(b) Duration	Hrs	
	(c) Interval between successive equalising charges and criteria to initiate the same	days	
5.0	Expected fault level at bus due to battery	kVA	
6.1	Internal resistance of each battery cell (fully charged)	Ohms	
6.2	Total Resistance of battery including resistance of inter-cell / inter row connectors	Ohms	
7.1	Ah efficiency at rated load	%	
7.2	Watt hour efficiency	%	
8.1	Type of positive plate		
8.2	No. of positive plates / cell		
8.3	No. of cells per battery, with recommended float voltage		
8.4	Whether the battery can meet the duty		

	cycle requirements with design margin, temperature correction factor , ageing factor etc., as specified (enclose battery sizing calculations)		
8.5	Inter – cell / Inter – row connectors		
	(a) Type (lead, lead plated copper or lead plated aluminium)		
	(b) Thickness of lead plating (shall be not less than 0.025 mm as measured in accordance with IS : 6848).		
8.6	Whether acid level indicators, included (applicable for opaque containers)		
8.7	Type of containers		
8.8	Type of cell		
9.0	Overall dimensions		
9.1	Each cell LxWxH		
9.2	Whether battery room size adequate (enclose dimensioned drawing indicating battery layout)		
10.0	Weight of each cell		
10.1	With electrolyte	kg	
10.2	Without electrolyte	kg	
11.0	Are the vent plugs explosion proof	Yes / No	
12.0	Ventilation requirements No. of air changes required	Changes/ Hr	
13.0	Whether copy of the Type test reports (for a similar type & rating battery) enclosed. (clause 9.2 of write-up)		
14.0	List of spares / accessories enclosed (Ref.	Yes / No	

	CL. 4 and CL. 10 of wirte-up)		
15.0	List of deviation enclosed	Yes / No	

5.32. DATASHEET-B SHUNT CAPACITORS

1.0	<u>CAPACITOR BATTERY</u>		
1.1	NAME OF MANUFACTURER		
1.2	TYPE		ALL PP (DOUBLE LAYER) /MIXED DIELECTRIC
1.3	REFERENCE STANDARDS		
1.4	RATED KVAR CAPACITY OF THE CAPACITOR BATTERY	KVAR	
1.5	RATED VOLTAGE/SERVICE VOLTAGE	VOLTS	
1.6	RATED FREQUENCY	HZ	
1.7	OUTPUT OF THE CAPACITOR BATTERY AT RATED VOLTAGE	KVAR	
1.8	TEMPERATURE RISE OVER THE SPECIFIED AMBIENT TEMPERATURE AS MENTIONED IN DATA SHEET - A	⁰ C	
1.9	A) HOTSPOT TEMPERATURE AT RATED CURRENT	⁰ C	
	B) MAXIMUM OPERATING TEMPERATURE	⁰ C	
1.10	CAPACITANCE	MICRO FARAD S	
1.11	A) RATED LINE CURRENT	AMPS	
	B) MAXIMUM PERMISSIBLE OVERLOAD CURRENT	AMPS	
1.12	CAPACITOR LOSSES		
	A) FOR COMPLETE BATTERY	WATTS	
	B) FOR INDIVIDUAL UNITS	WATTS	
1.13	ELECTRICAL CLEARANCE IN THE BANK		
	A) PHASE TO PHASE	MM	
	B) PHASE TO EARTH	MM	
2.0	<u>UNIT CAPACITORS</u>		
2.1	RATED VOLTAGE	VOLTS	

2.2	RATED OUTPUT	KVAR	
2.3	NO. OF PHASES		
2.4	WHETHER SINGLE BUSHING OR MULTIBUSHING TYPE		
2.5	MAXIMUM OVERVOLTAGE THE UNIT CAPACITOR IS CAPABLE OF WITHSTANDING CONTINUOUSLY	%	
2.6	INSULATION STRENGTH TO EARTH		
2.7	NO OF CAPACITOR ELEMENTS PER CAPACITOR		
2.8	MODE OF INTERNAL CONNECTION OF THE CAPACITOR ELEMENT SKETCH ENCLOSED.	YES / NO	
2.9	a) TYPE OF ACTIVE ELEMENT b) WATT LOSS OF ACTIVE ELEMENT VARIOUS DIELECTRIC TEMPERATURE ENCLOSED c) THICKNESS d) ALTERNATING NOMINAL R.M.S. VOLTAGE STRESS ON THE DIELECTRIC ELEMENT	YES / NO MM VOLTS / MM	
2.10	a) TYPE OF IMPREGNANT USED b) PRESSURE AT WHICH THE IMPREGNANT IS KEPT WITHIN THE UNIT	KG / MM ²	
3.0	<u>CAPACITOR FUSES</u>		
3.1	RATING OF THE FUSE ELEMENT		
	A) CURRENT	A	
	B) VOLTAGE	V	
	C) RATED RESISTANCE	OHM	
	D) RATED CONTINUOUS WATTAGE	W	
	E) TYPE & MATERIAL		
3.2	STRENGTH OF THE FUSE ELEMENTS IN AMP 2 SEC AT WHICH IT MELTS.	AMP2 SEC.	

3.3	a) MATERIAL OF THE FUSE ELEMENT b) TYPE (INTERNAL/EXTERNAL)		
3.4	GRAPH OF THE ALLOWABLE I ² T INTEGRAL OF THE FUSE ELEMENTS ENCLOSED	YES/NO	
4.0	<u>DISCHARGE DEVICE</u>		
4.1	<u>RESISTOR</u> a) RATED VOLTAGE b) RATED RESISTANCE c) RATED CONTINUOUS WATTAGE d) TYPE & MATERIAL	V OHM W	
4.2	<u>VOLTAGE TRANSFORMER</u>		
	A) RATED VOLTAGE	KV	
	B) BASIC IMPULSE LEVEL	KV	
	C) VA BURDEN	VA	
	D) TYPE OF INSULATION USED		
	E) WEIGHT	KG	
	F) DIMENSIONS	MM	
	G) TECHNICAL LITERATURE SHOWING COMPLETE DESIGN FEATURES OF THE VT ENCLOSED	YES/NO	
	<u>H) INDOOR/OUTDOOR</u>		
5.0	<u>SERIES REACTORS</u>		
5.1	SERVICE		
5.2	TYPE		
5.3	NUMBER OF PHASES		
5.4	BASIC IMPULSE LEVEL	KV	
5.5	FREQUENCY	HZ	
5.6	REACTANCE	OHMS	
	(REACTANCE IN % OF CAPACITOR REACTANCE)		
5.7	NOMINAL CURRENT RATING	AMPS	

5.8	CONTINUOUS OVERCURRENT RATING	AMPS	
5.9	MAXIMUM SWITCHING SURGE WITHSTAND FOR EACH BANK		
	A) WITH REACTOR	KV	
	B) WITHOUT REACTOR	KV	
5.10	VOLTAGE RATING	KV	
5.11	SHORT CIRCUIT RATING	KA	
5.12	TYPE OF CONSTRUCTION		
	A) AIR CORE		
	B) IRON CORE		
	I) WITH SHIELDING II) WITHOUT SHIELDING		
5.13	TEMPERATURE RISE ABOVE DESIGN AMBIENT	⁰ C	
5.14	NOISE LEVEL	DB	
5.15	TYPE OF COOLING (N.A.C./M.O.C./S.N.I.L.C. ETC.)		
5.16	QUANTITY OF OIL, IF REQUIRED	LITRES	
5.17	TYPE OF OIL		
6.0	<u>GENERAL</u>		
6.1	OVERALL DIMENSIONS OF BANK AND UNITS	MM	
6.2	LAYOUT AND DIMENSION DRAWINGS ATTACHED	YES/NO	
7.0	<u>BREAKERS/SWITCHFUSE DETAILS</u>		
8.0	<u>PROTECTION SCHEME DETAILS</u>		
9.0	<u>SWITCHING SCHEME DETAILS</u>		
10.0	<u>TYPE TEST CERTIFICATES ENCLOSED</u>	YES/NO	

5.33. DATASHEET-B LED

SL. NO.	TECHNICAL PARAMETERS	SPECIFIC REQUIREMENT	BIDDER TO CONFIRM
1	LIGHT SOURCE	HIGH POWER LED	
2	MAKE OF LED LAMPS	OSRAM / PHILIPS / LUMILED / CREE/ NICHIA	
3	LIGHTING DISTRIBUTION TYPE	CUT OFF/ SEMI CUT OFF TYPE AS PER IESNA TYPE II/ III LIGHTING DISTRIBUTION.	
4	LUMINARY EFFICACY	>100 LM/W +/- 5 %	
5	OPERATING VOLTAGE RANGE	140- 280V	
6	OPERATING VOLTAGE	230V □ +/- 10%	
8	OPERATING FREQUENCY	50 HZ +/- 3% HZ	
9	TOTAL HARMONIC DISTORTION	CURRENT < 15%; VOLTAGE < 5%	
10	POWER FACTOR	>= 0.95	
11	OPERATING CURRENT	<700 MA	
12	USAGE HOURS	DUSK TO DAWN (12 HOURS)	
13	AUDIBLE NOISE	SHALL HAVE CLASS-A SOUND RATING WITH AUDIBLE NOISE IN POWER SUPPLY	

14	BEAM ANGLE	120 DEGREES (MINIMUM)	
15	LIFE SPAN	50000 BURNING HOURS WITH 80% LUMEN MAINTENANCE	
16	COLOR TEMPERATURE	5500 - 6000K (SUITABLE FOR “COOL WHITE” LIGHT)	
17	COLOR RENDERING INDEX (CRI)	MIN. 70	
18	UNIFORMITY RATIO (EMIN/ EAVG)	60%	
19	TRANSVERSE UNIFORMITY RATIO (EMIN/EMAX)	40%	
20	INGRESS PROTECTION	IP 66 FOR STREET LIGHTING	
	DRIVER:		
21	DRIVER EFFICIENCY	>90%	
22	OPTICAL EFFICIENCY	> 95%	
23	P/N JUNCTION TEMPERATURE	<100 DEGREES C AT JUNCTION POINT AND <60 AT HEAT SINK.	
24	SURGE IMMUNITY LEVEL	4.5 KV	
25	EARTHING	DRIVER UNIT SHALL HAVE PROVISION FOR PROPER GROUNDING	

26	SHORT CIRCUIT PROTECTION	RECOVERS AUTOMATICALLY AFTER FAULT CONDITION IS REMOVED.	
27	OVER VOLTAGE PROTECTION	SHOULD BE ABLE TO WITHSTAND 320V FOR MINIMUM 24 HOURS	
28	HIGH – LOW VOLTAGE CUTOFF	IN SIDE LUMINARY OR A DEVICE TO BE INSTALLED ON THE POLE IN AN IP PROTECTED BOX SUSTAINING 270V FOR HIGHER SIDE CUTOFF & 140 V ON LOWER SIDE CUTOFF-BEYOND& BELOW IT SHUT DOWN & RESTORE NORMAL WORKING CONDITION WHEN VOLTAGE	
29	HOUSING WITH SUPPLIER WORD MARK / NAME	ENGRAVED / EMBOSSING ON THE DIE CAST HOUSING/ BODY PART	
30	CONNECTING WIRES & CABLES USED	FRLS THREE CORE COPPER WIRE OF 2.5 MTR OUTSIDE LUMINARIE	
31	IMPACT RESISTANCE OF COMPLETE LUMINARIE	IK 05 OR ABOVE	

32	REPLACEMENT GUARANTEE OF COMPLETE LUMINARY	5 YEARS AGAINST ANY DEFECTS/FAULTS (IN CASE OF LUMEN DEPRECIATION BEYOND LIMIT OF L70, NON-WORKING ANY LED, DISCOLORATION IN LENS OR GLASS OR POLYCARBONATE COVER RESULTING INTO DEPRECIATION IN LUX LEVEL WITH RESPECT TO L70)	
33	FINISH	AESTHETICALLY DESIGNED HOUSING WITH POWDER COATED CORROSION RESISTANT HOUSING	
34	WORKING TEMPERATURE	-20 DEGREE TO 50 DEGREE	
35	WORKING HUMIDITY	10% TO 90% RH	

36	HOUSING	THE FIXTURE SHOULD COMPRISE OF A TOP CANOPY MADE OF DI-CAST HIGH PRESSURE ALUMINUM ALLOY OF ADEQUATE THICKNESS AND A LOWER PART COMPRISES OF UV RESISTANT ACRYLIC BOWL TOP FROSTED FOR VISUAL COMFORT	
37	CONSTRUCTION	LED'S ARE MOUNTED ON A CIRCULAR/ ARRAY MCPCB WHICH IS THERMALLY GLUED TO AN ALUMINUM SHEET PROVIDED WITH ALUMINUM FINS FIRMLY CONNECTED TO THE HOUSING FOR EXCELLENT HEAT DISSIPATION.	

TECHNICAL SPECIFICATIONS – BIDDER TO FILL

FOR

IBMS & IT SYSTEM

6. DATA SHEET FOR INTEGRATED BUILDING MANAGEMENT SYSTEM

6.1. Direct Digital Control (DDC) Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to Specify	
2.	Model No	Bidder to Specify	
B.	FEATURES		
1.	Type	Microprocessor based fully programmable with onboard real time clock	
2.	Local display with DDC	Required <input type="checkbox"/> Not Required <input checked="" type="checkbox"/>	
3.	Communication port	Required <input checked="" type="checkbox"/> Not Required <input type="checkbox"/>	
4.	Memory	Non volatile memory	
5.	Network capability	Required <input checked="" type="checkbox"/> Not Required <input type="checkbox"/>	
6.	Management function as alarm management, trending functions, remote management, access protection levels, time scheduling, data processing etc	Required <input checked="" type="checkbox"/> Not Required <input type="checkbox"/>	
7.	Communication between DDC to DDC	Peer to Peer communication	
8.	Network interface	TCP/ IP	

Sr. No.	Description	Requirement	Bidder Comments
9.	Inputs to DDC	Digital inputs, Analog inputs	
10.	Outputs to DDC	Digital outputs, Analog outputs and PFC to drive auxiliary contactor	
11.	Numbers of I/O module	Refer I/O table sheet	
12.	Facility to expand I/O channels in each DDC	Required <input checked="" type="checkbox"/> Not Required <input type="checkbox"/>	
13.	LED status for each I/O channel	Required <input checked="" type="checkbox"/> Not Required <input type="checkbox"/>	
14.	Power supply	230VAC from UPS	
15.	Data back-up in case of power failure	Required <input checked="" type="checkbox"/> Not Required <input type="checkbox"/>	
16.	Location of the DDC	Please refer floor layout	
17.	Final paint colour (Exterior)	RAL-7032	
18.	Final paint colour (Interior)	Glossy white	
19.	Heat dissipation	Bidder to Specify	
20.	Rating of relay contact	Bidder to Specify	
21.	Analog input/ output	Refer I/O table sheet	
22.	Digital input/ output	Refer I/O table sheet	
C.	CONSTRUCTIONAL FEATURES		
1.	Sheet material	CRCA-cold rolled prefabricated	
2.	Sheet material thickness	2mm	
3.	Gland plate thickness	3mm	

Sr. No.	Description	Requirement	Bidder Comments
4.	Neoprene gaskets for doors / covers	Required <input checked="" type="checkbox"/> Not Required <input type="checkbox"/>	
5.	Cable entry	Bottom <input checked="" type="checkbox"/> Top <input type="checkbox"/> Side <input type="checkbox"/>	
6.	Lighting	Fluorescent (Fluorescent lamp of 40w shall be provided from one end of the panel to the other end at continuous length and shall be operated by the door switches as well as by manual switches.)	
7.	Name plates	Required <input checked="" type="checkbox"/> Not Required <input type="checkbox"/>	
8.	SS metal tags for all instruments (to be tagged at all hardware inside panel)	Required <input checked="" type="checkbox"/> Not Required <input type="checkbox"/>	
9.	Receptacle with fuse switch	Bidder to Specify (Note: Each section of the panels shall be provided with one each 3 pin receptacles for 230V,1P,50C/S)	
10.	Adequate maintenance space	Required <input checked="" type="checkbox"/> Not Required <input type="checkbox"/>	
11.	Weight of the panel (total)	Bidder to Specify	
12.	Panel shall be powder coated with thickness of coating of min. 60 microns	Required <input checked="" type="checkbox"/> Not Required <input type="checkbox"/>	
D.	ENVIRONMENTAL CHARACTERISTICS		

Sr. No.	Description	Requirement	Bidder Comments
1.	Ambient temperature range	0-50°C	
2.	Humidity range	95%	
3.	Weather protection class	Min. IP52 for indoor panels	
E.	SPARE		
1.	Quantity	Required	

6.2. FIRE DETECTION AND ALARM SYSTEM

6.2.1. Fire Alarm Control Panel Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Type	Microprocessor Based	
2.	Panel Location	1. Fire Command Centre, Ground Floor, Administration Building 2. Reception Area, Ground Floor, Training & Production Building 3. Ground Floor, Canteen Building	
B.	DISPLAY ON PANEL		
1.	Type	Backlit LCD	
2.	Lines X Characters	LCD, Alphanumeric, display of addresses, Minimum 80/160 characters	
3.	Parameters to be	1. Addresses	

Sr. No.	Description	Requirement	Bidder Comments
	displayed	2. Fire situation 3. Fire progression 4. Evacuation details 5. Fault Conditions	
4.	LED indication for:	1. Power ON 2. Fire alarm 3. Maintenance 4. Fault conditions	
5.	Programming facility	1. Keypad 2. Touch screen	
6.	Password and selectable access level	Required	
7.	Switches / Push buttons	Acknowledge, Silence and System reset	
C.	PANEL CHARACTERISTICS		
1.	Audio indication on alarm	Required	
2.	Fault isolation capability	Required	
3.	Alarm verification capability	Required	
4.	Sensitivity adjustment	Required	
5.	Sensor self test capability	Required	

Sr. No.	Description	Requirement	Bidder Comments
6.	Zone wise grouping	Required	
7.	Response time	10 Seconds (Max) for full loaded panel. Note: The maximum allowable response delay from activation of an initiating device to receipt and display by the receiver/ fire alarm control unit shall be 10 seconds.	
8.	Fault tolerant wiring capability	Required	
9.	No. of loops / Panel	2 Nos. Loops (Working + Spares for future) Spare cards shall be mounted inside the panel along with working cards	
10.	Expansion capability	Required	
11.	Minimum addressable points per loop	Each loop shall be loaded upto 80% of its capacity. However 20% spare shall be considered in each loop for future additional detectors / devices.	
12.	SLC loop cabling type	Style 6, class 'A' as per NFPA 72	
13.	Loop length supported	Upto 1.5 Km	
14.	Memory	NON-Volatile, NON-Erasable and NON-Rewritable	
15.	Networking	<ol style="list-style-type: none"> 1. Panel to Panel 2. Panel to Repeater Panel 3. Panel to Graphical User Interface (GUI) 	5.

Sr. No.	Description	Requirement	Bidder Comments
		4. PC to printer	
16.	Networking protocol	RS-485 or Ethernet	
17.	Degraded mode operation	Required	
18.	Redundancy for controller	Not Required	
19.	Event recorder	Required	
D.	POWER		
1.	Supply voltage to panel	230V - 10%, 50Hz, UPS mains supply	
2.	Operating current	Bidder to specify	
3.	Output voltage	Bidder to specify	
4.	Wattage consumption	Bidder to specify	
5.	Types of batteries	Sealed Maintenance Free (SMF) Note:- Battery shall be supplied having manufacturing date nearer to the supply date of battery.	
6.	Battery capacity	As per NFPA 72 Note:- Battery shall have sufficient capacity to power the fire alarm system under non alarm condition for a minimum of 24 hours and shall be capable of operating the system during emergency condition for a period of 15 minutes at maximum connected load, upon normal AC power failure. The full load shall consist of simultaneous operation of all sounders, operation	

Sr. No.	Description	Requirement	Bidder Comments
		of detectors at least 25% of zones (with minimum of two zones) and the operation of fault indicators.	
7.	Terminal blocks for mains supply	Required	
8.	Isolated earth bar for shield grounding	Required	
E.	MECHANICAL CHARACTERISTICS		
1.	Dimensions	Bidder to specify	
2.	Weight	Bidder to specify	
3.	Mounting	Wall <input checked="" type="checkbox"/> Surface <input type="checkbox"/> Flush <input type="checkbox"/> Semi Flush <input type="checkbox"/>	
4.	Sheet thickness	1.6mm	
5.	Colour shade	Bidder to specify	
6.	Housing material	CRCA	
F.	ENVIRONMENTAL CHARACTERISTICS		
1.	Ambient temperature range	0-50°C	
2.	Humidity range	95%	
3.	Weather protection class	Min. IP 20 for indoor panels located in air condition space	
G.	APPROVAL / CERTIFICATE		
1.	UL/ FM/ VDS/ EN-54/ LPCB	Required	

Sr. No.	Description	Requirement	Bidder Comments
2.	Make	Bidder to specify	
3.	Model No	Bidder to specify	

6.2.2. Fire Alarm Repeater Panel Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
B.	DISPLAY ON PANEL		
1.	Type	Backlit LCD	
2.	Lines X Characters	Alpha-numeric, LCD display with minimum 80 character, with LED indications	
3.	Parameters to be displayed	<ol style="list-style-type: none"> 1. Addresses 2. Fire situation 3. Fire progression 4. Evacuation details 5. Fault Conditions 	
4.	LED indication for:	<ol style="list-style-type: none"> 1. Power ON 2. Fire alarm 3. Maintenance 4. Fault conditions 	
5.	Programming facility	<ol style="list-style-type: none"> 1. Keypad 	

Sr. No.	Description	Requirement	Bidder Comments
		2. Touch screen	
6.	Password and selectable access level	Required	
7.	Switches / Push buttons	Acknowledge, Silence and System reset	
C.	PANEL CHARACTERISTICS		
1.	Audio indication on alarm	Required	
2.	Alarm verification capability	Required	
3.	Response time	10 Seconds (Max) for full loaded panel. Note: The maximum allowable response delay from activation of an initiating device to receipt and display by the receiver/ fire alarm control unit shall be 10 seconds.	
4.	Memory	NON-Volatile, NON-Erasable and NON-Rewritable	
5.	Networking	Required	
6.	Networking protocol	RS-485 or Ethernet	
D.	POWER		
1.	Supply voltage to panel	230V - 10%, 50Hz, UPS mains supply	
2.	Operating current	Bidder to specify	
3.	Output voltage	Bidder to specify	

Sr. No.	Description	Requirement	Bidder Comments
4.	Wattage consumption	Bidder to specify	
5.	Types of batteries	Sealed Maintenance Free (SMF) Note:- Battery shall be supplied having manufacturing date nearer to the supply date of battery.	
6.	Battery capacity	As per NFPA 72 Note:- Battery shall have sufficient capacity to power the fire alarm system under non alarm condition for a minimum of 24 hours and shall be capable of operating the system during emergency condition for a period of 15 minutes at maximum connected load, upon normal AC power failure. The full load shall consist of simultaneous operation of all sounders, operation of detectors at least 25% of zones (with minimum of two zones) and the operation of fault indicators.	
7.	Terminal blocks for mains supply	Required	
8.	Isolated earth bar for shield grounding	Required	
E.	MECHANICAL CHARACTERISTICS		
1.	Dimensions	Bidder to specify	
2.	Weight	Bidder to specify	
3.	Mounting	Wall <input checked="" type="checkbox"/> Surface <input type="checkbox"/> Flush <input type="checkbox"/> Semi Flush <input type="checkbox"/>	

Sr. No.	Description	Requirement	Bidder Comments
4.	Sheet thickness	1.6mm	
5.	Colour shade	Bidder to specify	
6.	Housing material	CRCA	
F.	ENVIRONMENTAL CHARACTERISTICS		
1.	Ambient temperature range	0-50°C	
2.	Humidity range	95%	
3.	Weather protection class	Min. IP20 for indoor panels located in air condition space	
G.	APPROVAL / CERTIFICATE		
1.	UL/ FM/ VDS/ EN-54/ LPCB	Required	
2.	Make	Bidder to specify	
3.	Model No	Bidder to specify	

6.2.3. Fire Alarm Control Relay Module Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
B.	MODULE CHARACTERISTICS		
1.	Application	Activating conventional Sounder cum Strobe <input checked="" type="checkbox"/>	

Sr. No.	Description	Requirement	Bidder Comments
		To operate the dry contact for third party application <input type="checkbox"/>	
2.	Type	Microprocessor Based	
3.	Addressable	Required	
4.	Number of relay outputs in each module	1 No. <input checked="" type="checkbox"/> 2 No. <input type="checkbox"/> 4 No. <input type="checkbox"/> 8 No. <input type="checkbox"/>	
5.	Type of relay contact / contact rating	Bidder to specify	
6.	Cabling	Two wire signal line circuit style 6, class 'A' as per NFPA-72	
7.	Built-in isolator	Not Required Note: In case of built-in isolator requirement the approval/ certification shall be VDS/ EN-54/ LPCB else UL/ FM approval/ certification shall be applicable.	
C.	POWER		
1.	Operating voltage	24 VDC (Loop powered)	
2.	Operating current	Bidder to specify	
3.	Wattage consumption	Bidder to specify	
D.	MECHANICAL CHARACTERISTICS		
1.	Dimensions	Bidder to specify	

Sr. No.	Description	Requirement	Bidder Comments
2.	Weight	Bidder to specify	
3.	Material of Enclosure	Non Corrosive	
E.	ENVIRONMENTAL CHARCTERISTICS		
1.	Ambient temperature range	0-50°C	
2.	Humidity range	95%	
3.	Enclosure weather protection class	For Indoor IP54 For Outdoor IP65	
4.	Explosion proof enclosure		
5.	Hazardous area classification		
F.	APPROVAL / CERTIFICATE		
1.	UL/ FM/ VDS/ EN-54/ LPCB	Required	

6.2.4. Fire Alarm Heat Detector Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
B.	DETECTOR CHARACTERISTICS		
1.	Type	Microprocessor Based-Combination of Fixed <input checked="" type="checkbox"/>	

Sr. No.	Description	Requirement	Bidder Comments
		Temperature and Rate of Rise of Temperature <input type="checkbox"/> Microprocessor Based-Fixed Temperature <input type="checkbox"/> Microprocessor Based-Rate of Rise of Temperature	
2.	Addressable	Required	
3.	LED Status	Multi colored, multi status LED	
4.	Response Time	The maximum allowable response delay from activation of an initiating device to receipt and display by the receiver/ fire alarm control unit shall be 10 seconds	
5.	Terminals for connecting response indicator	Required (Bidder to consider fault isolator module after every 10 Nos. detectors/ devices for UL/ FM offered panel or inbuilt fault isolator base shall be provided for EN-54/ VDS/ LPCB offered panel. Bidder to provide necessary provision to connect the response indicator for any type of fire detectors.)	
6.	Sensor Coverage	Bidder to specify	
7.	Alarm set point for Heat	For fixed temperature type - 55°C For rate of rise of temp.	

Sr. No.	Description	Requirement	Bidder Comments
		type 7°C / Minutes	
8.	Sensitivity Adjustment	Required	
9.	Immune to false alarm	Required	
10.	Cabling	Two wire signal line circuit style 6, class 'A' as per NFPA-72	
11.	Built-in isolator	Not Required Note: In case of built-in isolator requirement the approval/ certification shall be VDS/ EN-54/ LPCB else UL/ FM approval/ certification shall be applicable.	
C.	POWER		
1.	Operating voltage	24 VDC (Loop powered)	
2.	Operating current	Bidder to specify	
3.	Wattage consumption	Bidder to specify	
D.	MECHANICAL CHARACTERISTICS		
1.	Dimensions	Bidder to specify	
2.	Weight	Bidder to specify	
3.	Material of Enclosure	Non Corrosive	
4.	Colour	Bidder to specify	
E.	ENVIRONMENTAL CHARACTERISTICS		
1.	Ambient temperature range	0-50°C	
2.	Humidity range	95%	

Sr. No.	Description	Requirement	Bidder Comments
F.	APPROVAL / CERTIFICATE		
1.	UL/ FM/ VDS/ EN-54/ LPCB	Required	

6.2.5. Fire Alarm Multi-Sensor Detector Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
B.	DETECTOR CHARACTERISTICS		
1.	Type	Microprocessor based, combination of smoke and heat detector (Fixed and Rate of Rise of Temperature type)	
2.	Addressable	Required	
3.	LED Status	Multi colored, multi status LED	
4.	Remote / Local Test Capability	Required	
5.	Response Time	The maximum allowable response delay from activation of an initiating device to receipt and display by the receiver/ fire alarm control unit shall be 10 seconds	
6.	Terminals for connecting	Required	

Sr. No.	Description	Requirement	Bidder Comments
	response indicator	(Bidder to consider fault isolator module after every 10 Nos. detectors/ devices for UL/ FM offered panel or inbuilt fault isolator base shall be provided for EN-54/ VDS/ LPCB offered panel. Bidder to provide necessary provision to connect the response indicator for any type of fire detectors.)	
7.	Sensor Coverage	Bidder to specify	
8.	Alarm set point for Heat	For fixed temperature type - 55°C For rate of rise of temp. type 7°C / Minutes	
9.	Sensitivity Adjustment	Required	
10.	Immune to false alarm	Required	
11.	Cabling	Two wire signal line circuit style 6, class 'A' as per NFPA-72	
12.	Built-in isolator	Not Required Note: In case of built-in isolator requirement the approval/ certification shall be VDS/ EN-54/ LPCB else UL/ FM approval/ certification shall be applicable.	
C.	POWER		
1.	Operating voltage	24 VDC (Loop powered)	
2.	Operating current	Bidder to specify	

Sr. No.	Description	Requirement	Bidder Comments
3.	Wattage consumption	Bidder to specify	
D.	MECHANICAL CHARACTERISTICS		
1.	Dimensions	Bidder to specify	
2.	Weight	Bidder to specify	
3.	Material of Enclosure	Non Corrosive	
4.	Colour	Bidder to specify	
E.	ENVIRONMENTAL CHARACTERISTICS		
1.	Ambient temperature range	0-50°C	
2.	Humidity range	95%	
F.	APPROVAL / CERTIFICATE		
1.	UL/ FM/ VDS/ EN-54/ LPCB	Required	

6.2.6. Fire Alarm Beam Type Smoke Detector Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
B.	DETECTOR CHARACTERISTICS		
1.	Type	Reflective beam <input checked="" type="checkbox"/> type smoke detector <input type="checkbox"/> Projected beam	

Sr. No.	Description	Requirement	Bidder Comments
		type smoke detector	
2.	Addressable	Required Note: In case bidders offers conventional beam detector, same shall be made addressable by providing addressable monitor module.	
3.	LED Status	Multi colored, multi status LED	
4.	Remote / Local Test Capability	Required	
5.	Response Time	The maximum allowable response delay from activation of an initiating device to receipt and display by the receiver/ fire alarm control unit shall be 10 seconds	
6.	Sensor Coverage	Bidder to specify	
7.	Alarm set point for Heat	Bidder to specify	
8.	Sensitivity Adjustment	Required	
9.	Immune to false alarm	Required	
10.	Cabling	Two wire signal line circuit style 6, class 'A' as per NFPA-72	
C.	POWER		
1.	Operating voltage	24 VDC	

Sr. No.	Description	Requirement	Bidder Comments
2.	Operating current	Bidder to specify	
3.	Wattage consumption	Bidder to specify	
D.	MECHANICAL CHARACTERISTICS		
1.	Dimensions	Bidder to specify	
2.	Weight	Bidder to specify	
3.	Material of Enclosure	Non Corrosive	
4.	Colour	Bidder to specify	
5.	Spacing & mounting	As per the norms of NFPA 72,2010 edition & as per manufacturer's instructions	
E.	ENVIRONMENTAL CHARACTERISTICS		
1.	Ambient temperature range	0-50°C	
2.	Humidity range	95%	
3.	Weather protection class	For indoor application: IP 54	
F.	APPROVAL / CERTIFICATE		
1.	UL/ FM/ VDS/ EN-54/ LPCB	Required	

6.2.7. Fire Alarm Smoke Detector Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
B.	DETECTOR CHARACTERISTICS		
1.	Type	Microprocessor Base-Photoelectric Type	
2.	Addressable	Required	
3.	LED Status	Multi colored, multi status LED	
4.	Remote / Local Test Capability	Required	
5.	Response Time	<p>10 Seconds Max. For Full Loaded Panel. Detectors Response Time Shall Be Suitable For The Same.</p> <p>Note: The maximum allowable response delay from activation of an initiating device to receipt and display by the receiver/ fire alarm control unit shall be 10 seconds.</p>	
6.	Terminals for Connecting Response Indicator	Required	
7.	Sensor Coverage	Bidder to specify	
8.	Sensitivity Adjustment	Required	
9.	Immune to false alarm	Required	

Sr. No.	Description	Requirement	Bidder Comments
10.	Cabling	Two wire signal line circuit style 6, class 'A' as per NFPA-72	
11.	Detector Mounting Base	With Isolator <input type="checkbox"/> Without Isolator <input checked="" type="checkbox"/>	
C.	POWER		
1.	Operating voltage	Bidder to specify	
2.	Operating current	Bidder to specify	
3.	Wattage consumption	Bidder to specify	
4.	Loop Powered	Required	
D.	MECHANICAL CHARACTERISTICS		
1.	Dimensions	Bidder to specify	
2.	Weight	Bidder to specify	
3.	Material of Enclosure	Non Corrosive	
4.	Colour	Bidder to specify	
5.	Spacing & mounting	As per the norms of NFPA 72,2010 edition & as per manufacturer's instructions	
E.	ENVIRONMENTAL CHARACTERISTICS		
1.	Ambient temperature range	0-50°C	
2.	Humidity range	95%	
3.	Weather protection class	For indoor application: IP 65	
F.	APPROVAL / CERTIFICATE		

Sr. No.	Description	Requirement	Bidder Comments
1.	UL/ FM/ VDS/ EN-54/ LPCB	Required	

6.2.8. Fire Alarm Monitor Module Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
B.	MODULE CHARACTERISTICS		
1.	Application	To normally open dry-contact alarm activation devices	
2.	Type	Microprocessor Based	
3.	Addressable	Required	
4.	Number of relay outputs in each module	1 No. <input checked="" type="checkbox"/> 2 No. <input type="checkbox"/> 4 No. <input type="checkbox"/> 8 No. <input type="checkbox"/>	
5.	Response time	The maximum allowable response delay from activation of an initiating device to receipt and display by the receiver/ fire alarm control unit shall be 10 seconds	
6.	Cabling	Two wire signal line circuit style 6, class 'A' as per NFPA-72	
7.	Built-in isolator	Not Required	

Sr. No.	Description	Requirement	Bidder Comments
		Note: In case of built-in isolator requirement the approval/ certification shall be VDS/ EN-54/ LPCB else UL/ FM approval/ certification shall be applicable.	
C.	POWER		
1.	Operating voltage	24 VDC (Loop powered)	
2.	Operating current	Bidder to specify	
3.	Wattage consumption	Bidder to specify	
D.	MECHANICAL CHARACTERISTICS		
1.	Dimensions	Bidder to specify	
2.	Weight	Bidder to specify	
3.	Material of Enclosure	Non Corrosive	
E.	ENVIRONMENTAL CHARCTERISTICS		
1.	Ambient temperature range	0-50°C	
2.	Humidity range	95%	
3.	Enclosure weather protection class	For Indoor IP54 For Outdoor IP65	
4.	Explosion proof enclosure	Bidder to specify	
5.	Hazardous area classification	Bidder to specify	
F.	APPROVAL / CERTIFICATE		
1.	UL/ FM/ VDS/ EN-	Required	

Sr. No.	Description	Requirement	Bidder Comments
	54/ LPCB		

6.2.9. Manual Call Point (MCP) Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
B.	MCP CHARACTERISTICS		
1.	Type	Break glass type <input checked="" type="checkbox"/> Push and pull type <input checked="" type="checkbox"/> Lift and pull type <input checked="" type="checkbox"/>	
2.	Clear and visible operating instructions on the body	Required	
3.	The word "FIRE" indication on the front of MCP in raised letters, 1.75 inches (44 mm) or larger	Required	
4.	Response Time	The maximum allowable response delay from activation of an initiating device to receipt and display by the receiver/ fire alarm control unit shall be 10 seconds	
5.	Cabling	Two wire signal line circuit style 6, class 'A'	

Sr. No.	Description	Requirement	Bidder Comments
		as per NFPA-72	
6.	Built-in isolator	Not Required Note: In case of built-in isolator requirement the approval/ certification shall be VDS/ EN-54/ LPCB else UL/ FM approval/ certification shall be applicable.	
C.	POWER		
1.	Operating voltage	24 VDC (Loop powered)	
2.	Operating current	Bidder to specify	
3.	Wattage consumption	Bidder to specify	
D.	MECHANICAL CHARACTERISTICS		
1.	Dimensions	Bidder to specify	
2.	Weight	Bidder to specify	
3.	Material of Enclosure	Non Corrosive	
4.	Colour	Bidder to specify	
E.	ENVIRONMENTAL CHARACTERISTICS		
1.	Ambient temperature range	0-50°C	
2.	Humidity range	95%	
3.	Enclosure weather protection class	For Indoor IP54 For Outdoor IP65	
4.	Explosion proof enclosure	Bidder to specify	
5.	Hazardous area classification	Bidder to specify	

Sr. No.	Description	Requirement	Bidder Comments
F.	APPROVAL / CERTIFICATE		
1.	UL/ FM/ VDS/ EN-54/ LPCB	Required	
2.	ATEX/ CCOE	Not Required (For Explosion Proof type)	

6.2.10. SOUNDER cum STROBE Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
B.	SOUNDER/ STROBE CHARACTERISTICS		
1.	Type	Loop Powered <input type="checkbox"/> Externally Powered <input checked="" type="checkbox"/> Note: Externally powered through FACP.	
2.	Addressable	Required	
3.	Response time	The maximum allowable response delay from activation of an initiating device to receipt and display by the receiver/ fire alarm control unit shall be 10 seconds	
4.	dB level	90 db at 10 Feet from device	
5.	Light intensity	15/30/75/110 cd	
6.	Number of selectable tones	Minimum 4	

Sr. No.	Description	Requirement	Bidder Comments
7.	Cabling	Two wire signal line circuit style 6, class 'A' as per NFPA-72	
8.	Built-in isolator	Not Required Note: In case of built-in isolator requirement the approval/certification shall be VDS/ EN-54/ LPCB else UL/ FM approval/certification shall be applicable.	
C.	POWER		
1.	Operating voltage	24 VDC	
2.	Operating current	Bidder to specify	
3.	Wattage consumption	Bidder to specify	
4.	Power Supply	Bidder to specify	
D.	MECHANICAL CHARACTERISTICS		
1.	Dimensions	Bidder to specify	
2.	Weight	Bidder to specify	
3.	Material of Enclosure	Non Corrosive	
4.	Mounting	Wall <input checked="" type="checkbox"/> Surface <input type="checkbox"/> Structure beam <input type="checkbox"/> Note: - All accessories shall be supplied and erected as applicable	
E.	ENVIRONMENTAL CHARCTERISTICS		
1.	Ambient temperature range	0-50°C	

Sr. No.	Description	Requirement	Bidder Comments
2.	Humidity range	95%	
3.	Weather protection class	IP 65	
F.	APPROVAL / CERTIFICATE		
1.	UL/ FM/ VDS/ EN-54/ LPCB	Required	
2.	ATEX/ CCOE	Not Required (For explosion proof type)	

6.2.11. Fire Alarm Fault Isolator Module Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
B.	MODULE CHARACTERISTICS		
1.	Type	Microprocessor Based	
2.	Addressable	Required	
3.	After every numbers of detector/devices	18 nos.	
4.	Automatically resets on correction of short	Required	
5.	Wide viewing angle of LED	Required	
6.	Cabling	Two wire signal line circuit style 6, class 'A' as per NFPA-72	

Sr. No.	Description	Requirement	Bidder Comments
C.	POWER		
1.	Operating voltage	24 VDC (Loop powered)	
2.	Operating current	Bidder to specify	
3.	Wattage consumption	Bidder to specify	
D.	MECHANICAL CHARACTERISTICS		
1.	Dimensions	Bidder to specify	
2.	Weight	Bidder to specify	
3.	Material of Enclosure	Non Corrosive	
E.	ENVIRONMENTAL CHARACTERISTICS		
1.	Ambient temperature range	0-50°C	
2.	Humidity range	95%	
3.	Enclosure Weather protection class	For Indoor IP54 For Outdoor IP65	
F.	APPROVAL / CERTIFICATE		
1.	UL/ FM/ VDS	Required	

6.3. PUBLIC ADDRESS SYSTEM

6.3.1. Microphone Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
3.	Frequency range	100 Hz to 15 kHz	
4.	Sensitivity (mV)	Bidder to specify	
5.	Impedance: ≤ 600 Ohm	Bidder to specify	
6.	Dimensions	Bidder to specify	
7.	Weight	Bidder to specify	
8.	Colour	Bidder to specify	
9.	On/off switch	Required	
10.	Cable length	2 meter minimum	
11.	Connector	Lockable	
12.	Voltage range & current consumption for condenser type microphone	Bidder to specify	
13.	Operating temperature	0° to 50° C	
14.	Relative humidity	< 95%	
15.	Certificate	CE	
16.	Accessories	Bidder shall provide appropriate mounting accessories like microphone holder,	

Sr. No.	Description	Requirement	Bidder Comments
		extension cable, mounting bracket, table stand, floor stand to suit the site requirement and same shall be submitted to purchaser's approval	

6.3.2. Loudspeaker Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
3.	Maximum power (W)		
4.	Rated power/ wattage tapping (W)		
5.	Power tapping/ Rated voltage	100V & 70V	
6.	Sound Pressure Level (SPL)		
7.	Frequency Response		
8.	Colour		
9.	Rated impedance	Bidder to specify	
10.	Dimensions	Bidder to specify	
11.	Weight	Bidder to specify	
12.	Colour	Bidder to specify	
13.	Material	Aluminium/ ABS	
14.	Standards	CE, EN60065	
15.	Operating Temperature	0° to 50° C	

Sr. No.	Description	Requirement	Bidder Comments
16.	Related Humidity	<95%	
17.	IP rating	IP54	
18.	Ex-proof rating		

6.3.3. Desktop Call Station

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
3.	Microphone		
a)	Frequency Response: 100 Hz to 15 kHz		
b)	Sensitivity (mV)	Bidder to specify	
c)	Impedance: <600 Ohm		
d)	Type: Uni-directional Condenser Gooseneck		
e)	Signal to Noise Ratio: >60 dB		
f)	Load	Bidder to specify	
4.	Loudspeaker		
a)	Rated power	Bidder to specify	
b)	Signal to Noise Ratio: >60dB		
c)	Sound Pressure Level: 85 dB		
d)	Frequency Response: 100 Hz to 15 kHz		

Sr. No.	Description	Requirement	Bidder Comments
e)	Rated impedance	Bidder to specify	
5.	Material	Bidder to specify	
6.	Standards: CE, EN60065		
7.	Operating Temperature : 0° to 50° C		
8.	Related Humidity: <95%		
9.	Input voltage	Bidder to specify	
10.	Load (W)	Bidder to specify	
11.	Multi colour multi status LED: Required (for indication of active zones, emergency messages, power ON, error signals)		
12.	Attachment for add-on keypads : Required (No. of keypads shall be decided as per requirement considering no. of zones and multiprogramming key requirement)		
13.	Key station/ keypad: Required (keys shall be used for assigning zones and for multipurpose use)		
14.	Dimensions	Bidder to specify	
15.	Weight	Bidder to specify	
16.	Colour	Bidder to specify	
17.	Mounting: Desk mountable type		
18.	Mute button: Required (for inbuilt loudspeaker)		

Sr. No.	Description	Requirement	Bidder Comments
19.	3.5mm jack for headphone & microphone: Required		

6.4. CLOSED CIRCUIT TELEVISION SYSTEMS

6.4.1. CCTV Camera Specification

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
3.	Camera details	Colour - Day/ Night camera	
4.	Image sensor	1/3" CCD <input type="checkbox"/> 1/3" CMOS <input checked="" type="checkbox"/>	
5.	Lens type	Fixed lens <input checked="" type="checkbox"/> Varifocal lens <input checked="" type="checkbox"/> IR corrected lens <input checked="" type="checkbox"/> Motorized zoom lens <input type="checkbox"/>	
6.	Lens format	Minimum 1/3", shall be compatible with image sensor	
7.	IR cut filter <input checked="" type="checkbox"/> or IR corrected lens <input type="checkbox"/>	Required	
8.	IRIS	Automatic	
9.	F-STOP Range	F/1.4 to F/16	
10.	Sensitivity for usable video	Minimum 0.1 Lux @(F1.2,AGC O N), 0 Lux with IR	
11.	Resolution	WD1 (960×480)	

Sr. No.	Description	Requirement	Bidder Comments
12.	Automatic shutter	Required	
13.	Backlight compensation	Required	
14.	Wide dynamic range (WDR)	Required	
15.	Signal to noise ratio (SNR)	> 50dB (minimum)	
16.	Auto contrast adjustment	Required	
17.	Horizontal & vertical angle of view	70 ⁰ Horizontal Minimum	
18.	White balance	Required	
19.	Video compression H.264 <input checked="" type="checkbox"/> Motion JPEG <input type="checkbox"/>	Bidder to specify	
20.	Video data rate range	Bidder to specify	
21.	Frames per second for viewing	25 FPS	
22.	Frames per second for recording	15 FPS Minimum	
23.	Automatic gain control (AGC) 20 dB Minimum	Bidder to specify	
24.	Power supply	UPS Power	
25.	Housing	Box camera housing for indoor and outdoor use shall be vandal proof, rugged, durable, industrial grade, M.O.C is cast aluminium, with in-built heater /blower & sunshield.	
26.	IP Rating for indoor camera	IP52	

Sr. No.	Description	Requirement	Bidder Comments
27.	IP Rating for outdoor camera	IP66	
28.	Operating temperature	-10 ⁰ C to 60 ⁰ C For Outdoor camera -10 ⁰ C to 50 ⁰ C For Indoor camera	
29.	Operating humidity	95 RH	
30.	Mounting accessories	All necessary accessories are required	
31.	Tampering alarm	Required (tampering such as dis-focus/ move viewing direction/ masking)	
32.	Spares	10% or 1 no. (whichever is higher) shall be provided for each type of camera	
33.	Standards UL, CE	Required	

6.4.2. CCTV MONITOR SPECIFICATION

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
3.	Display size	32"	
4.	Resolution	1920 X 1080	
5.	Dynamic contrast ratio	Required	
6.	Wide colour enhancer	Required	

Sr. No.	Description	Requirement	Bidder Comments
7.	Aspect ratio	16:9	
8.	Audio	Not required	
9.	Connectivity: VGA HDMI : 2 ports (Minimum)	Required	
10.	Mounting	Wall <input checked="" type="checkbox"/> Desk <input type="checkbox"/>	
11.	Power supply	110 V AC <input type="checkbox"/> 230 V AC <input checked="" type="checkbox"/>	
12.	Power consumption	Bidder to specify	
13.	Dimensions : (W x H x D)	Bidder to specify	
14.	Weight	Bidder to specify	
15.	Accessories	As required for proper operation	

6.4.3. DVR (Digital Video Recorder) SPECIFICATION

Sr. No.	Description	Requirement	Bidder Comments
A.	GENERAL		
1.	Make	Bidder to specify	
2.	Model No	Bidder to specify	
B.	Video Input		
1.	Video Compression	H.264	
2.	Video Input	4 Channel 8 Channel 16 Channel	

Sr. No.	Description	Requirement	Bidder Comments
C.	Video Output		
1.	HDMI/VGA Output	1920 X 1080	
2.	Encoding Resolution	WD1	
3.	Frame Rate	25 FPS or better	
D.	Hard Disk		
1.	SATA	2 SATA Interface	
2.	Capacity	Minimum 30 Days	
E.	External Interface		
1.	Network Interface	RJ45	
2.	Serial Interface	RS-485	
3.	USB Interface	USB 2.0	
F.	Power		
1.	Power Supply	12 VDC	
2.	Consumption	20 W	
G.	Mechanical Properties		
1.	Dimensions	Bidder to Specify	
2.	Weight	Bidder to Specify	
H.	Environmental Properties		
1.	Temperature	-10 ⁰ C to 50 ⁰ C	
2.	Humidity	95 RH	

TECHNICAL SPECIFICATIONS – BIDDER TO FILL

FOR

EXTERNAL SERVICES

7. DATA SHEET FOR EXTERNAL SERVICES

7.1. DATA SHEET FOR HORIZONTAL CENTRIFUGAL PUMP

7.1.1. DATA SHEETS B

1.	DESIGNATION		
2.	NUMBER OFFERED		
3.	TAG NUMBERS		
4.	PUMP MAKE AND MODEL NUMBER		
5.	DESIGN CAPACITY	M ³ /Hr	
6.	DIFFERENTIAL HEAD	MLC	
7.	SHUT-OFF HEAD	MLC	
8.	HYDROSTATIC TEST PRESSURE	Kg/cm ² (g)	
9.	NUMBER OF STAGES		
10.	PUMP EFFICIENCY AT DUTY POINT	%	
11.	PUMP SPEED	RPM	
12.	PUMP BKW	KW	
13.	MAXIMUM PUMP POWER REQUIREMENT	KW	
14.	POWER INPUT TO DRIVER AT DUTY POINT	KW	
15.	METHOD OF LUBRICATION		
17.	NPSH REQUIRED	MLC	
18.	DRIVER RATING	KW	
19.	DRIVER SPEED	RPM	
20.	DRIVER EFFICIENCY	%	
21.	SUCTION NOZZLE		

21.1	ORIENTATION		
21.2	SIZE	mm NB	
22.	DISCHARGE NOZZLE		
22.1	ORIENTATION		
22.2	SIZE	mm NB	
23.	TYPE AND MAKE OF MECHANICAL SEAL		
24.	TYPE OF COUPLING		
25.	MINIMUM CAPACITY FOR CONTINUOUS OPERATION	M ³ /Hr	
26.	MAXIMUM ALLOWABLE SIZE OF SOLIDS	mm	
27.	EXTERNAL WATER REQUIREMENT FOR COOLING		
27.1	FLOW RATE	M ³ /Hr	
27.2	PRESSURE	Kg/cm ² (g)	
28.	EXTERNAL WATER REQUIREMENT FOR SEALING		
28.1	FLOW RATE	M ³ /Hr	
28.2	PRESSURE	Kg/cm ² (g)	
29.	WEIGHT OF BARE PUMP	Kg	
30.	WEIGHT OF DRIVER	Kg	
31.	WEIGHT OF COMMON BASE PLATE	Kg	
32.	MOMENT OF INERTIA OF PUMP ROTOR	Kg-M ²	
33.	ACCESSORIES AS PER DATA SHEET		WHETHER INCLUDED

	A TO		
	BE INCLUDED		YES NO
34.	OUTLINE DIMENSIONAL DRAWING TO BE		WHETHER ENCLOSED
	ENCLOSED		YES/NO
35.	FOUNDATION DRAWING WITH STATIC		WHETHER ENCLOSED
	AND DYNAMIC LOADS TO BE ENCLOSED		YES/NO
36.	CROSS-SECTION DRAWING OF PUMP		
	WITH PART LIST AND MATERIALS OF		WHETHER ENCLOSED
	CONSTRUCTION AND RELEVANT		YES/NO
	STANDARDS TO BE ENCLOSED		
37.	PERFORMANCE CURVES FLOW RATE Vs		
	HEAD, BKW, EFFICIENCY, NPSHR AND		WHETHER ENCLOSED
	TORQUE-SPEED CURVE TO BE ENCLOSED		YES/NO
38.	PERFORMANCE GUARANTEE		
38.1	CAPACITY	M ³ /Hr	(+) (-)
38.2	DIFFERENTIAL HEAD	MLC	(+) (-)
38.3	POWER CONSUMPTION	KW	(+) (-)

7.1.2. DATA SHEETS C

Data to be furnished by the vendor after the issue of purchase order

1. List of drawings and documents to be submitted for review, approval and information with scheduled submission dates
2. Quality Assurance Plan (QAP)
3. Detailed dimensioned general arrangement drawing of pump and driver. This drawing shall indicate all the design data and information furnished in data sheets B.
4. Foundation drawing of pump and driver with static and dynamic loads, details of fixing, grouting and all relevant data required for design of foundation
5. Cross-section drawing of the pump with complete part list, materials of construction and relevant standards for each part
6. Pump performance curves flow rate Vs head, BKW, efficiency, NPSHR from zero flow to maximum flow and torque-speed curve
7. Scheme for pump sealing, lubrication and cooling
8. Driver dimensional drawing
9. Surface preparation and painting procedures
10. Catalogues, data sheets and drawings for instruments
11. Installation, operation and maintenance manual along with lubrication schedule.

7.2. DATA SHEET FOR DOSING PUMP

7.2.1. DATA SHEETS B

1.	SYSTEM DESIGNATION		
2.	TAG NUMBERS		
3.	PUMP MAKE AS PER APPROVED SUB-VENDOR LIST/ MODEL NUMBER		

4.	PUMP DESIGN/ MAXIMUM CAPACITY	LPM/LPH	/
5.	MAXIMUM DISCHARGE PRESSURE	Kg/cm ² (g)	
6.	PUMP SPEED - MAXIMUM	RPM OR STROKE S/Hr	
7.	MOTOR RATING	KW	
8.	MOTOR SPEED	RPM	
9.	MOTOR MAKE - AS PER APPROVED SUB-VENDOR LIST		
10.	WEIGHT OF COMPLETE PUMP AND MOTOR ASSEMBLY	Kg	
11.	OUTLINE DIMENSIONAL DRAWING WITH DETAILS OF PUMP AND MOTOR TO BE ENCLOSED		WHETHER ENCLOSED YES/ NO
12.	CROSS-SECTION DRAWING OF PUMP WITH PART LIST AND MOC TO BE ENCLOSED		WHETHER ENCLOSED YES/ NO

7.2.2. DATA SHEETS C

Data to be furnished by the vendor after the issue of purchase order

1. List of drawings and documents to be submitted for review, approval and information with scheduled submission dates
2. Quality Assurance Plan (QAP)
3. Detailed dimensioned general arrangement drawing of pump and driver. This drawing shall indicate all the design data and information furnished in data sheets B.
4. Foundation drawing of pump and driver with static and dynamic loads, details of fixing, grouting and all relevant data required for design of foundation
5. Cross-section drawing of the pump with complete part list, materials of construction and relevant standards for each part
6. Pump performance curves flow rate Vs head, BkW, efficiency, NPSHR from zero flow to maximum flow and torque-speed curve

7. Scheme for pump sealing, lubrication and cooling
8. Driver dimensional drawing
9. Surface preparation and painting procedures
10. Catalogues, data sheets and drawings for instruments
11. Installation, operation and maintenance manual along with lubrication schedule.

7.3. DATA SHEET FOR SUBMERSIBLE PUMP (Raw Sewage from Equalisation Tank)

7.3.1. DATA SHEETS B

	<u>DATA TO BE FURNISHED BY BIDDER</u>		
1.0	<u>GENERAL</u>		
1.1	Make		
1.2	Model		
2.0	<u>PUMP</u>		
2.1	Capacity	M ³ / hr.	
2.2	Total head	MLC	
2.3	Shut - off head	MLC	
2.4	Speed	RPM	
2.5	Combined pump and motor efficiency	%	

2.6	Solid handling capacity	mm	
3.0	<u>MOTOR</u>		
3.1	Motor type		
3.2	Motor rating		
3.3	Motor Cooling Arrangement		
3.4	Class of insulation		
3.5	Output of Motor	kW	
3.6	<u>Power factor</u>		
3.6.1	Full load		
3.6.2	3/4 load		
3.7	Starting current	Amp.	
3.8	Degree of protection		
3.9	Cable size		
3.10	Voltage drop per 10 metre cable length		
4.0	<u>CONSTRUCTION DETAILS</u>		
4.1	Impeller type		

4.2	Number of impeller vanes		
4.4	Moment of inertia with entrained sewage	kg - m ²	
4.5	Weight of pump, motor, and cables	kg	

7.3.2. DATA SHEETS C

Data to be furnished by the vendor after the award of contract

1. Final overall dimensional assembly drawings for the pump set. These shall show all the major parameters of the pump set.
2. Civil drawings, with the details of fixing, grouting, sealing, net weights, clearances and any other relevant data required for the design of civil structure.
3. Cross sectional drawings for pump set with the complete bill of materials.
4. Motor drawings with details of cable entry, grounding etc.
5. Operation and maintenance manual.

Only the drawing listed under item 3 above will be reviewed and approved by PURCHASER. All other data/ drawings are for PURCHASER's reference only.

7.4. DATA SHEET FOR AIR BLOWER

7.4.1. DATA SHEETS B

A.	GENERAL		
1.	DESIGNATION		AIR BLOWER FOR
2.	NUMBER OFFERED		(W + S)
3.	TAG NUMBERS		
4.	MAKE AND MODEL NUMBER		
5.	AMCA ARRANGEMENT NUMBER		

B.	DESIGN AND PERFORMANCE		
6.	CAPACITY (FAD) NORMAL/ MAXIMUM	M ³ /Hr	/
7.	VACUUM CREATED		cm Hg VACUUM
8.	DISCHARGE PRESSURE	Kg/cm ² g	
9.	SELECTED SPEED OF BLOWER	RPM	
10.	CASING MATERIAL/THICKNESS		/ mm
11.	IMPELLER OR ROTOR DIAMETER	mm	
12.	IMPELLER OR ROTOR MATERIAL/ THICKNESS		/ mm
13.	SHAFT MATERIAL/DIAMETER		/ mm
C.	ACCESSORIES		
14.	MATERIAL OF CONSTRUCTION/ EFFICIENCY OF AIR FILTER		/
15.	PRESSURE DROP ACROSS AIR FILTER	mm WC	MAXIMUM
16.	SIZE/MATERIAL OF CONSTRUCTION OF CASING DRAIN VALVE		mm NB/
17.	SIZE/MATERIAL OF CONSTRUCTION OF RELIEF VALVE		INLET__INCH, OUTLET__ INCH ORIFICE____ /
18.	SIZE/MATERIAL OF CONSTRUCTION OF OUTLET DAMPER		mm/
19.	VIBRATION DAMPENING PADS		CUSHYFOOT(DUNLOP)/

D.	DRIVE DATA		MOTOR	COUPLIN G	V-BELT
20.	TYPE				
21.	MAKE				
22.	MODEL NUMBER				

23.	ABSORBED POWER AT SHAFT	KW		NA	NA
24.	POWER INPUT AT DUTY POINT	KW		NA	NA
25.	RATING	KW			
26.	SPEED	RPM			
27.	REDUCTION RATIO		NA	NA	
28.	EFFICIENCY	%		NA	
29.	SERVICE FACTOR		NA		
E.	MISCELLANEOUS				
30.	NOISE LEVEL AT 1.5 M DISTANCE FROM BLOWER	dBA			
31.	WEIGHT OF ENTIRE UNIT MOUNTED ON COMMON BASE PLATE	Kg			
32.	TOTAL DYNAMIC LOAD	Kg			
33.	DOCUMENTS TO BE ENCLOSED			WHETHER ENCLOSED	
34.	GENERAL ARRANGEMENT DRAWING WITH MAJOR DIMENSIONS			YES/NO	
34.1	PART LIST WITH CODES AND MATERIALS OF CONSTRUCTION			YES/NO	
34.2	PERFORMANCE CURVE WITH DUTY POINT MARKED			YES/NO	
34.3	SELECTION CHARTS OR CURVES			YES/NO	
34.4	LIST OF START-UP SPARES			YES/NO	
34.5	LIST OF RECOMMENDED SPARES FOR 2 YEARS NORMAL OPERATION			YES/NO	
F.	PERFORMANCE GUARANTEES				
35.	CAPACITY (FAD)	M ³ /Hr	(+) (-)		
36.	DISCHARGE PRESSURE	Kg/cm ² g	(+) (-)		
37.	POWER CONSUMPTION	KW	(+) (-)		

7.4.2. DATA SHEETS C**Data to be furnished by the vendor after the issue of purchase order**

- 1.0 List of drawings and documents to be submitted for review, approval or information with scheduled submission dates.
- 2.0 Quality Assurance Plan (QAP)
- 3.0 Drawings showing outline dimensions, clearance dimensions for disassembly, weight, part numbers, materials of construction, test pressures, statutory and any special requirements, sizes, tag numbers and quantities. All information covered in data sheets A and B shall be incorporated in this drawing. The PURCHASER'S identifying tag numbers shall be shown on each drawing or on a sheet attached to the drawing with proper cross-references.
- 4.0 Operation and maintenance manuals